

NICE COTE D'AZUR AP, France

WMO: 076900

Lat: 43.6489N

Lon: 7.2089E

Elev: 4

StdP: 101.28

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.1	3.4	-10.8	1.5	6.3	-8.2	1.9	6.6	13.5	13.8	12.3	12.3	5.0	330	0.440

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.3	29.7	22.7	28.8	22.4	27.9	22.2	24.4	28.1	23.7	27.5	23.1	26.9	3.9	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.1	17.9	27.5	22.4	17.1	26.9	21.7	16.3	26.4	73.8	28.3	71.0	27.6	68.4	27.0	26.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.0	10.3	8.5	0.6	33.1	1.6	2.0	-0.5	34.6	-1.5	35.7	-2.3	36.9	-3.5	38.3		
			-2.5	25.2	1.2	0.9	-3.4	25.8	-4.1	26.3	-4.8	26.8	-5.7	27.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.3	9.3	9.7	11.7	14.1	17.7	21.5	24.2	24.4	21.1	17.7	13.2	10.3
	DBStd	5.78	1.98	2.13	1.99	2.09	2.18	2.38	1.98	1.84	2.13	2.20	2.51	2.30
	HDD10.0	101	36	27	8	1	0	0	0	0	0	5	24	
	HDD18.3	1342	279	243	206	128	38	2	0	0	3	38	154	251
	CDD10.0	2387	15	18	61	123	238	344	439	447	333	237	101	32
	CDD18.3	588	0	0	0	1	18	97	181	188	87	17	1	0
	CDH23.3	3474	0	0	0	1	32	427	1304	1382	313	15	0	0
	CDH26.7	540	0	0	0	0	1	48	219	252	21	0	0	0
Wind	WSAvg	4.0	4.6	4.4	4.2	4.0	3.5	3.3	3.4	3.4	3.8	4.1	4.7	4.9
Precipitation	PrecAvg	792	81	65	63	64	44	36	14	26	69	118	121	81
	PrecMax	1267	289	230	243	183	246	138	73	172	214	419	563	210
	PrecMin	319	0	0	0	2	1	0	0	0	1	0	1	0
	PrecStd	226	71	57	53	43	41	32	17	29	61	101	100	57
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.9	17.6	19.6	22.2	26.0	29.8	31.4	32.0	28.7	24.8	20.8	17.8
		MCWB	10.9	10.6	11.8	14.6	17.5	22.1	20.7	21.9	20.2	19.1	15.1	11.9
	2%	DB	15.2	15.4	17.5	20.2	24.1	28.1	29.6	30.0	27.0	23.6	19.5	16.4
		MCWB	10.6	10.6	11.6	14.3	17.9	22.1	22.7	23.2	20.7	18.7	14.9	11.9
	5%	DB	14.2	14.5	16.2	19.0	22.7	26.8	28.7	28.9	26.0	22.6	18.5	15.2
		MCWB	10.2	10.4	11.7	13.9	17.2	21.3	22.6	22.5	20.4	18.0	14.3	11.0
	10%	DB	13.2	13.7	15.5	17.9	21.5	25.7	27.9	28.0	25.1	21.7	17.4	14.1
		MCWB	9.5	10.0	11.5	13.6	16.8	20.6	22.2	22.4	19.7	17.3	13.5	10.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.0	12.8	14.0	16.7	20.1	24.3	25.2	25.7	23.1	20.8	17.2	14.2
		MCDB	14.8	15.3	16.7	19.5	23.4	28.3	28.8	29.1	26.4	23.5	19.5	16.2
	2%	WB	11.9	12.0	13.2	15.6	19.0	23.2	24.4	24.6	22.1	19.7	16.0	12.9
		MCDB	14.5	14.3	15.9	18.5	22.4	26.9	28.1	28.3	25.7	22.6	18.3	15.4
	5%	WB	10.9	11.2	12.7	14.8	18.2	22.2	23.7	23.9	21.3	18.8	15.1	11.7
		MCDB	13.6	13.9	15.3	17.8	21.5	25.8	27.5	27.6	25.1	21.8	17.7	14.4
	10%	WB	9.9	10.4	12.2	14.2	17.5	21.3	23.1	23.3	20.5	17.9	14.1	10.6
		MCDB	12.6	13.3	14.8	17.1	20.7	24.9	26.9	27.1	24.3	21.0	16.7	13.4
Mean Daily Temperature Range	5% DB	MDBR	7.2	7.1	6.9	6.3	6.0	6.0	6.2	6.3	6.8	6.7	7.1	7.1
		MCDBR	8.2	8.0	7.8	7.2	7.0	6.6	7.0	7.0	7.2	7.2	7.6	7.9
		MCWBR	6.4	6.2	5.8	4.9	4.8	4.9	5.4	5.9	5.4	5.4	5.7	6.1
	5% WB	MCDBR	7.4	7.3	6.8	6.1	6.0	5.8	5.9	6.1	6.3	6.5	6.5	7.0
		MCWBR	6.2	6.1	5.5	4.7	4.6	4.9	5.4	5.7	5.3	5.2	5.3	5.8
Clear-Sky Solar Irradiance	taub	0.324	0.347	0.386	0.424	0.432	0.440	0.433	0.424	0.412	0.394	0.354	0.321	
	taud	2.470	2.407	2.319	2.234	2.263	2.284	2.314	2.343	2.352	2.382	2.447	2.491	
	Ebn at Noon	804	842	848	841	843	836	837	833	812	775	756	772	
	Edh at Noon	73	91	113	133	133	131	125	118	108	93	75	66	
All-Sky Solar Radiation	RadAvg	1.78	2.65	3.97	5.07	6.06	6.99	7.10	6.19	4.65	3.02	1.89	1.54	
	RadStd	0.18	0.30	0.39	0.38	0.46	0.34	0.34	0.24	0.27	0.26	0.20	0.17	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (28 neighbors)	+0.30	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page