

CAP FERRAT, France

WMO: 076950

Lat: 43.6829N

Lon: 7.3281E

Elev: 144

StdP: 99.61

Time Zone: 1.00 (EUC)

Period: 86-08

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.0	5.2	-12.5	1.3	7.5	-8.8	1.8	8.7	15.3	12.6	12.7	10.9	3.6	80	0.386

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.8	29.1	22.4	28.1	22.4	27.1	22.1	24.6	27.3	23.9	26.7	23.2	26.0	3.3	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.7	18.9	26.5	23.0	18.1	25.9	22.2	17.2	25.3	75.2	27.3	72.7	26.7	69.8	26.2	27.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.2	9.9	8.0	DB	2.2	31.6	2.8	1.8	0.2	32.8	-1.5	33.9	-3.0	34.9	-5.0	36.1	(4)
(5)			WB	-1.5	25.4	1.8	1.1	-2.8	26.2	-3.9	26.8	-4.9	27.4	-6.2	28.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.4	10.0	10.2	11.4	13.6	17.7	20.9	23.8	24.0	21.2	17.9	14.0	11.4
	DBStd	5.49	2.09	2.41	2.35	2.18	2.35	2.67	1.84	2.00	1.88	2.28	2.43	2.14
	HDD10.0	76	24	23	14	1	0	0	0	0	0	0	3	11
	HDD18.3	1270	257	227	215	142	39	6	0	0	3	34	131	216
	CDD10.0	2406	26	28	57	111	239	327	428	433	337	244	123	53
	CDD18.3	560	0	0	0	1	20	83	170	174	91	21	1	0
	CDH23.3	2259	0	0	0	0	29	292	879	916	139	3	0	0
	CDH26.7	279	0	0	0	0	1	21	123	132	2	0	0	0
Wind	WSAvg	3.3	3.5	3.5	3.4	3.7	3.5	3.1	3.0	3.1	2.8	3.3	3.2	3.3
Precipitation	PrecAvg	809	82	55	49	65	45	34	15	23	83	123	142	94
	PrecMax	1421	342	166	244	150	127	113	54	86	236	323	571	210
	PrecMin	347	1	0	0	6	4	0	1	1	1	25	2	2
	PrecStd	233	77	46	51	46	32	31	16	20	63	81	117	67
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.1	17.4	18.7	21.2	26.0	28.9	30.2	31.5	26.9	23.8	20.9	17.5
		MCWB	10.3	13.5	13.7	13.4	17.7	21.2	21.5	20.2	21.1	18.8	15.2	11.0
	2%	DB	14.6	15.2	16.8	19.5	23.8	27.4	29.0	29.5	26.0	22.6	18.7	16.1
		MCWB	10.2	11.8	11.7	13.5	17.8	21.9	22.2	22.4	20.9	18.7	14.2	11.6
	5%	DB	13.6	13.9	15.6	18.1	22.5	26.5	28.1	28.3	25.0	21.7	17.7	15.0
		MCWB	9.9	10.2	11.5	12.8	17.2	21.7	22.1	22.9	20.3	17.9	13.9	11.2
	10%	DB	12.8	13.0	14.5	16.9	21.2	25.3	27.1	27.3	24.1	20.8	16.9	14.2
		MCWB	9.6	9.9	11.0	12.8	16.3	21.0	21.9	22.6	19.5	17.3	13.6	10.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.7	14.6	15.7	16.5	20.3	24.0	25.2	25.8	23.1	20.8	16.7	14.7
		MCDB	14.3	17.2	18.0	18.6	23.4	27.0	27.9	28.4	25.5	22.7	19.0	15.3
	2%	WB	11.8	12.9	13.9	15.2	19.4	23.2	24.5	24.9	22.3	19.7	15.7	13.6
		MCDB	13.3	14.6	15.6	17.3	22.2	26.1	27.2	27.5	24.6	21.4	17.5	14.6
	5%	WB	11.1	11.6	12.6	14.3	18.2	22.5	23.9	24.2	21.7	18.9	15.0	12.4
		MCDB	12.9	12.9	14.0	16.5	21.1	25.4	26.6	26.9	23.9	20.6	16.9	14.2
	10%	WB	10.4	10.7	11.9	13.6	17.4	21.7	23.1	23.5	21.0	18.3	14.2	11.4
		MCDB	12.1	12.3	13.5	15.9	19.9	24.6	25.7	26.3	23.1	20.0	16.4	13.4
Mean Daily Temperature Range	5% DB	MDBR	3.9	4.1	4.5	4.4	4.7	4.8	5.0	4.8	4.4	3.9	3.9	3.8
		MCDBR	4.5	4.9	5.7	5.5	5.8	5.4	5.8	5.6	5.2	4.2	4.3	4.5
		MCWBR	3.6	3.8	4.0	3.4	3.4	3.1	4.4	4.0	3.7	3.2	3.4	3.8
	5% WB	MCDBR	3.9	4.9	4.8	4.9	5.1	4.9	5.2	4.9	4.9	3.9	3.8	3.9
		MCWBR	3.1	3.9	3.8	3.4	3.5	3.0	4.0	3.7	3.4	3.1	3.2	3.4
Clear-Sky Solar Irradiance	taub	0.316	0.338	0.375	0.411	0.418	0.427	0.420	0.412	0.400	0.383	0.344	0.313	
	taud	2.485	2.429	2.350	2.271	2.299	2.315	2.341	2.369	2.379	2.411	2.470	2.506	
	Ebn at Noon	815	854	861	854	856	847	849	844	824	789	770	784	
	Edh at Noon	71	89	109	128	128	127	122	115	105	90	73	64	
All-Sky Solar Radiation	RadAvg	1.76	2.64	3.95	5.04	6.03	6.95	7.06	6.15	4.63	3.01	1.88	1.53	
	RadStd	0.18	0.30	0.39	0.38	0.45	0.35	0.33	0.24	0.27	0.26	0.20	0.17	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (27 neighbors)	+0.31	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page