

ILE ROUSSE, France

WMO: 077530

Lat: 42.6331N

Lon: 8.9228E

Elev: 145

StdP: 99.60

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	3.5	5.0	-8.2	1.9	7.3	-6.0	2.3	7.9	19.5	11.9	18.0	12.4	7.5	80	0.464

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.4	30.1	21.4	28.8	21.7	27.8	21.3	24.2	27.7	23.6	27.0	22.9	26.3	5.1	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.1	18.1	26.8	22.4	17.4	26.2	21.6	16.6	25.6	73.7	27.8	71.0	26.9	68.3	26.3	26.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.8	15.2	13.2	2.0	34.3	1.3	1.8	1.0	35.5	0.2	36.6	-0.5	37.6	-1.5	38.8		
(5)			-0.9	25.1	1.0	1.0	-1.6	25.8	-2.2	26.4	-2.8	27.0	-3.6	27.7	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.0	10.4	10.2	12.3	14.7	18.1	22.0	24.6	24.5	21.9	18.6	14.6	11.9	(6)	(7)
	DBStd	5.67	2.59	2.67	2.50	2.29	2.53	2.61	2.10	1.94	2.02	2.37	2.71	2.67	(7)	(8)
	HDD10.0	77	26	26	9	1	0	0	0	0	0	0	2	13	(8)	(9)
	HDD18.3	1148	246	227	189	111	34	2	0	0	2	24	113	199	(9)	(10)
	CDD10.0	2641	38	32	79	142	251	360	452	451	356	267	141	73	(10)	(11)
	CDD18.3	670	0	0	1	2	27	112	193	192	107	33	2	0	(11)	(12)
	CDH23.3	3230	0	0	1	8	63	471	1243	1143	266	35	1	0	(12)	(13)
	CDH26.7	528	0	0	0	1	7	77	229	194	18	2	0	0	(13)	(14)
(14) Wind	WSAvg	5.0	5.7	5.4	6.1	5.2	4.5	4.2	4.5	4.2	4.6	4.4	5.1	5.8	(14)	(15)
(15) Precipitation	PrecAvg	625	54	46	56	55	38	32	9	22	55	79	110	69	(15)	(16)
	PrecMax	854	130	135	109	117	107	117	38	110	185	223	196	126	(16)	(17)
	PrecMin	411	2	2	0	8	5	0	0	1	3	2	22	4	(17)	(18)
	PrecStd	116	30	32	28	29	29	30	9	24	39	50	47	35	(18)	(19)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.5	17.5	21.3	23.8	27.4	31.3	32.1	32.3	28.6	26.2	22.5	19.2	(19)	(20)
		MCWB	12.2	11.1	13.0	15.2	17.1	19.9	20.7	20.4	20.1	18.2	15.3	12.9	(20)	(21)
	2%	DB	16.8	15.8	18.4	20.9	25.0	28.6	30.1	29.9	26.8	24.2	20.2	17.4	(21)	(22)
		MCWB	11.5	10.5	11.8	13.6	16.6	20.4	21.6	21.8	20.4	17.9	14.8	12.3	(22)	(23)
	5%	DB	15.1	14.5	16.8	19.3	23.3	27.1	28.9	28.6	25.8	22.8	19.0	16.3	(23)	(24)
		MCWB	10.8	10.2	11.1	13.3	16.5	20.4	22.2	21.8	19.9	17.8	14.5	11.9	(24)	(25)
	10%	DB	13.8	13.5	15.5	18.0	21.7	25.9	27.8	27.6	24.8	21.7	18.0	15.2	(25)	(26)
		MCWB	9.9	9.7	10.8	13.1	16.2	20.0	21.5	21.6	19.3	17.1	14.0	11.3	(26)	(27)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.1	12.6	13.8	16.7	19.6	23.9	25.0	25.2	23.0	20.4	17.5	14.2	(27)	(28)
		MCDB	16.8	15.6	18.4	20.5	23.4	27.3	28.8	28.7	26.5	23.5	19.7	17.3	(28)	(29)
	2%	WB	12.0	11.7	13.0	15.4	18.5	22.9	24.3	24.3	22.1	19.5	16.2	13.2	(29)	(30)
		MCDB	15.6	14.4	16.3	18.8	22.3	26.2	27.9	27.7	25.3	22.3	18.7	16.0	(30)	(31)
	5%	WB	11.2	10.9	12.4	14.6	17.7	22.0	23.7	23.6	21.2	18.7	15.3	12.6	(31)	(32)
		MCDB	14.5	13.5	15.4	17.8	21.4	25.3	27.2	26.9	24.3	21.5	18.0	15.3	(32)	(33)
	10%	WB	10.4	10.2	11.8	13.9	17.0	21.0	23.0	22.9	20.5	18.0	14.6	11.9	(33)	(34)
		MCDB	13.3	12.8	14.6	16.8	20.6	24.6	26.4	26.3	23.6	20.8	17.3	14.7	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	4.0	4.4	4.8	5.3	5.5	5.7	5.4	5.3	5.0	4.7	4.3	3.9	(35)	(36)
		MCDBR	5.0	5.4	6.2	7.0	7.4	7.0	6.6	6.2	5.8	5.7	5.1	4.7	(36)	(37)
	5% WB	MCWBR	3.9	4.2	4.0	4.4	4.6	5.0	5.1	5.5	4.5	4.2	3.8	3.7	(37)	(38)
		MCWBR	4.6	4.9	5.2	6.0	6.1	5.8	5.7	5.5	5.2	5.0	4.4	4.2	(38)	(39)
(39) Clear-Sky Solar Irradiance	taub	taub	0.317	0.333	0.360	0.396	0.405	0.401	0.399	0.396	0.386	0.366	0.345	0.319	(39)	(40)
		taud	2.535	2.487	2.427	2.330	2.346	2.395	2.400	2.420	2.439	2.493	2.503	2.537	(40)	(41)
	Ebn at Noon	Ebn at Noon	829	870	883	872	870	872	870	862	845	819	783	792	(41)	(42)
		Edh at Noon	70	86	102	121	123	117	115	110	100	85	72	65	(42)	(43)
(43) All-Sky Solar Radiation	RadAvg	RadAvg	1.70	2.60	3.87	5.25	6.33	7.18	7.31	6.34	4.76	3.15	1.92	1.50	(43)	(44)
	RadStd	RadStd	0.16	0.27	0.39	0.32	0.45	0.34	0.28	0.29	0.21	0.25	0.17	0.17	(44)	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (21 neighbors)	+0.24	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+74	N/A

Nomenclature: See separate page