

AJACCIO BONAPARTE AP, France

WMO: 077610

Lat: 41.9181N

Lon: 8.7928E

Elev: 18

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 32.5	(c) 35.2	(d) 20.3	(e) 15.3	(f) 39.6	(g) 24.6	(h) 18.7	(i) 40.1	(j) 26.6	(k) 53.5	(l) 22.3	(m) 53.2	(n) 8.1	(o) 50	(p) 0.442

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 19.3	(c) 88.1	(d) 72.8	(e) 86.0	(f) 73.1	(g) 84.1	(h) 72.6	(i) 76.5	(j) 84.8	(k) 75.1	(l) 83.4	(m) 73.8	(n) 82.2	(o) 10.0	(p) 210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.6	125.3	83.4	72.1	118.8	82.1	70.7	113.1	81.0	39.9	85.1	38.5	83.4	37.4	82.4	81.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 20.7	(b) 17.0	(c) 14.5	(e) 28.6	(f) 95.9	(g) 2.3	(h) 3.6	(i) 26.9	(j) 98.5	(k) 25.6	(l) 100.6	(m) 24.3	(n) 102.6	(o) 22.6	(p) 105.2		
			DB	WB	25.9	78.1	2.3	1.3	24.3	79.0	22.9	79.8	21.6	80.5	20.0	81.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	60.3	48.6	48.4	51.4	56.0	62.4	69.1	73.7	74.2	69.0	63.7	56.1	50.7
	DBStd	10.15	4.11	4.07	3.72	3.94	4.09	4.53	3.93	3.71	3.98	4.30	5.04	4.62
	HDD50	230	74	69	26	3	0	0	0	0	0	0	11	47
	HDD65	2579	508	465	420	272	102	12	1	1	12	74	268	444
	CDD50	4003	31	24	70	182	383	574	734	749	569	425	194	68
	CDD65	881	0	0	0	2	21	137	270	285	130	34	2	0
	CDH74	7641	0	0	4	20	132	1076	2580	2737	917	167	8	0
	CDH80	1865	0	0	0	5	27	202	706	794	116	15	0	0
(14) Wind	WSAvg	7.4	7.0	7.3	7.5	7.5	7.4	7.6	7.9	7.7	7.6	7.0	7.2	7.2
(15) Precipitation	PrecAvg	24.9	2.6	2.4	2.2	2.0	1.5	0.7	0.3	0.7	2.0	3.4	3.9	2.9
	PrecMax	38.8	6.0	6.9	6.3	5.6	5.6	4.0	1.9	4.0	5.4	9.7	8.7	8.1
	PrecMin	14.8	0.0	0.1	0.0	0.3	0.0	0.0	0.0	0.0	0.0	0.1	0.4	0.2
	PrecStd	5.8	1.5	1.6	1.4	1.3	1.3	0.7	0.5	0.9	1.4	2.4	2.3	1.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.3	63.6	68.7	75.6	83.3	89.3	91.8	92.2	85.7	81.7	74.6	66.5
		MCWB	55.4	53.7	55.8	58.1	63.7	68.8	71.5	71.2	70.6	66.4	60.6	56.8
	2%	DB	60.6	60.3	63.9	70.0	76.9	84.4	88.0	88.1	82.9	77.7	70.5	63.4
		MCWB	54.2	53.6	55.7	59.5	64.7	71.8	73.3	73.9	70.7	67.5	61.2	56.1
	5%	DB	58.8	59.0	62.3	67.4	74.3	82.1	85.9	86.0	81.0	75.5	67.9	61.3
		MCWB	52.9	52.7	55.3	58.7	64.3	71.1	73.7	73.8	69.9	66.2	60.1	55.1
	10%	DB	57.1	57.5	60.7	65.4	72.1	79.8	83.9	84.2	79.1	73.5	65.7	59.3
		MCWB	51.4	51.4	54.3	57.9	63.3	70.1	73.0	73.0	68.8	64.8	58.7	53.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.6	56.6	58.7	63.4	69.2	76.1	78.1	78.3	74.6	71.1	65.0	59.3
		MCDB	60.9	61.3	64.1	69.6	76.5	83.1	86.4	86.1	82.1	77.2	70.0	62.7
	2%	WB	55.4	55.1	57.3	61.2	67.0	74.2	76.5	76.8	72.8	69.0	62.5	57.5
		MCDB	59.3	59.2	62.2	67.1	74.3	81.6	84.9	85.3	80.7	75.6	68.2	61.6
	5%	WB	53.8	53.7	56.1	59.8	65.4	72.4	75.1	75.3	71.3	67.3	60.8	56.1
		MCDB	58.0	58.1	61.0	65.7	72.4	79.9	83.6	83.8	79.5	74.1	66.9	60.5
	10%	WB	52.1	52.2	55.0	58.5	64.0	70.6	73.8	73.9	69.7	65.6	59.1	54.4
		MCDB	56.6	56.7	59.9	64.3	70.8	78.4	82.2	82.7	77.9	72.5	65.0	58.7
(35) Mean Daily Temperature Range	MDBR		16.2	17.0	17.7	17.5	17.7	18.4	18.7	19.3	18.7	18.2	16.8	16.2
	5% DB	MCDBR	17.0	18.3	19.6	20.5	20.9	21.4	21.3	21.7	20.5	19.6	18.5	17.4
		MCWBR	12.5	13.5	14.0	13.3	12.8	13.5	14.0	15.1	13.6	12.9	12.2	12.1
	5% WB	MCDBR	15.6	17.0	17.8	18.2	18.6	18.9	19.1	20.2	19.2	18.3	17.4	15.4
		MCWBR	12.2	13.2	13.3	12.6	12.5	13.4	13.7	15.1	13.6	12.9	12.2	11.6
(40) Clear-Sky Solar Irradiance	taub		0.335	0.354	0.385	0.420	0.433	0.421	0.422	0.418	0.409	0.389	0.367	0.337
	taud		2.484	2.419	2.342	2.245	2.251	2.331	2.333	2.353	2.369	2.408	2.411	2.476
	Ebn at Noon		257	269	272	270	268	271	270	267	261	252	240	245
	Edh at Noon		24	30	36	42	43	40	39	37	34	30	26	22
(44) All-Sky Solar Radiation	RadAvg		556	843	1267	1691	2032	2324	2359	2034	1529	1036	631	493
	RadStd		54	84	113	106	153	103	82	97	61	82	50	52

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	+0.54	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+173	+104
(47) Regional (14 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page