

LA CHIAPPA, France

WMO: 077680

Lat: 41.5951N

Lon: 9.3630E

Elev: 223

StdP: 14.58

Time Zone: 1.00 (EUC)

Period: 82-91

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	38.9	41.2	27.0	21.1	43.0	29.8	24.1	45.1	34.0	58.7	29.5	53.8	9.6	20	0.408

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.8	86.7	73.3	84.9	73.8	83.2	73.4	77.8	83.5	76.5	82.2	75.3	80.9	9.9	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.1	137.2	82.0	74.7	130.9	80.6	73.5	125.5	79.5	41.3	83.7	40.1	82.4	38.9	81.1	85.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
29.8	25.3	21.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	62.4	51.1	50.3	52.9	57.0	63.0	70.4	77.0	76.8	72.7	65.8	57.6	53.3
	DBStd	10.36	4.56	5.02	4.18	3.22	4.20	3.51	3.07	2.90	3.49	4.23	4.46	4.09
	HDD50	135	39	54	21	1	0	0	0	0	0	0	4	16
	HDD65	2182	430	412	376	241	88	4	0	0	1	44	224	362
	CDD50	4658	74	61	110	210	404	611	836	831	681	489	232	119
	CDD65	1230	0	0	0	0	27	164	371	366	232	68	2	0
	CDH74	6682	0	0	0	0	35	512	2672	2495	913	55	0	0
	CDH80	1350	0	0	0	0	1	58	623	569	98	1	0	0
(14) Wind	WSAvg	8.8	10.1	9.7	9.6	9.4	7.8	7.2	6.8	7.6	8.4	8.8	10.0	9.8
(15) Precipitation	PrecAvg	27.5	2.9	2.2	2.7	2.4	1.9	0.7	0.3	0.7	2.5	3.7	3.9	3.4
	PrecMax	43.7	7.0	6.0	8.5	5.6	8.3	2.0	1.0	3.3	6.2	6.7	10.2	7.8
	PrecMin	18.3	0.4	0.4	0.4	0.4	0.4	0.0	0.0	0.0	0.2	0.2	0.7	0.3
	PrecStd	6.5	1.5	1.5	2.1	1.4	1.7	0.5	0.3	0.7	1.7	1.7	1.9	2.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	63.2	64.8	66.3	70.6	78.0	85.1	90.8	90.1	85.6	78.0	71.4	65.6
		MCWB	55.3	57.9	55.9	59.2	65.8	69.8	71.2	73.2	71.3	67.8	61.2	59.1
	2%	DB	60.8	61.8	63.1	67.1	74.4	81.8	87.1	86.8	82.4	75.5	67.9	62.6
		MCWB	54.0	56.2	55.1	58.1	65.0	70.6	73.6	73.0	71.4	67.6	61.2	57.6
	5%	DB	58.7	59.3	60.6	64.4	72.3	79.2	85.1	85.1	80.6	73.5	65.8	60.4
		MCWB	52.9	54.5	53.6	57.5	63.8	69.1	74.6	73.9	71.8	67.3	60.2	55.6
	10%	DB	57.2	57.2	58.9	62.3	70.1	77.0	83.4	83.5	78.9	71.7	63.9	59.1
		MCWB	52.6	52.8	53.3	56.2	62.2	68.2	73.9	74.0	70.9	66.7	59.3	54.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.4	59.1	59.6	62.0	69.3	77.0	80.5	79.1	76.2	71.9	64.4	61.0
		MCDB	59.8	63.5	64.0	66.6	75.4	81.0	84.9	85.1	81.1	74.5	67.6	63.8
	2%	WB	56.2	56.9	57.2	60.0	67.2	73.0	78.3	77.7	74.7	70.5	62.9	58.9
		MCDB	58.7	60.9	59.8	64.6	72.5	78.3	83.6	83.6	79.4	72.8	65.8	61.6
	5%	WB	54.8	55.2	55.9	58.5	65.3	71.1	76.8	76.5	73.6	69.3	61.5	56.9
		MCDB	57.6	58.6	58.6	62.6	70.4	76.3	82.7	82.3	78.2	71.6	64.6	59.5
	10%	WB	53.4	53.5	54.4	57.3	63.6	69.7	75.5	75.5	72.4	68.0	60.0	55.6
		MCDB	56.4	56.3	57.5	60.8	68.5	75.1	81.1	81.3	76.9	71.0	63.2	58.1
(35) Mean Daily Temperature Range	5% DB	MDBR	8.9	8.5	9.3	10.1	10.6	12.1	12.8	12.8	11.4	9.0	7.9	7.7
		MCDBR	10.0	11.2	12.2	13.6	13.8	15.3	15.0	14.8	13.7	11.1	10.5	9.4
		MCWBR	7.8	7.6	8.0	8.9	7.7	8.1	8.3	8.1	8.2	6.9	7.0	7.1
	5% WB	MCDBR	9.2	10.1	10.6	11.6	12.4	12.7	13.2	12.8	12.4	8.7	8.3	8.0
		MCWBR	7.5	7.6	7.8	8.3	8.0	8.2	8.7	8.2	8.4	6.4	6.4	6.6
(40) Clear-Sky Solar Irradiance	taub		0.334	0.352	0.382	0.417	0.429	0.415	0.417	0.414	0.408	0.389	0.367	0.337
	taud		2.491	2.432	2.357	2.264	2.270	2.354	2.355	2.373	2.385	2.417	2.419	2.481
	Ebn at Noon		258	270	274	271	270	273	271	269	262	253	241	246
	Edh at Noon		24	29	35	41	42	39	38	37	34	30	26	23
(44) All-Sky Solar Radiation	RadAvg		562	845	1250	1659	1992	2275	2313	2004	1506	1030	634	502
	RadStd		54	80	117	101	147	107	86	98	68	85	50	51

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (16 neighbors)	+0.43	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+155	N/A

Nomenclature: See separate page