

LA CHIAPPA, France

WMO: 077680

Lat: 41.5951N

Lon: 9.3630E

Elev: 68

StdP: 100.51

Time Zone: 1.00 (EUC)

Period: 82-91

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	3.8	5.1	-2.8	3.0	6.1	-1.2	3.4	7.3	15.2	14.8	13.2	12.1	4.3	20	0.408

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.1	30.4	22.9	29.4	23.2	28.5	23.0	25.5	28.6	24.7	27.9	24.1	27.2	4.4	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.5	19.6	27.8	23.7	18.7	27.0	23.0	17.9	26.4	78.2	28.7	75.3	28.0	72.6	27.3	29.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.3	11.3	9.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.9	10.6	10.1	11.6	13.9	17.2	21.3	25.0	24.9	22.6	18.8	14.2	11.9		
	DBStd	5.76	2.53	2.79	2.32	1.79	2.33	1.95	1.71	1.61	1.94	2.35	2.48	2.27		
	HDD10.0	75	22	30	12	1	0	0	0	0	0	0	2	9		
	HDD18.3	1212	239	229	209	134	49	2	0	0	1	24	124	201		
	CDD10.0	2588	41	34	61	117	224	339	464	462	378	272	129	66		
	CDD18.3	683	0	0	0	0	15	91	206	203	129	38	1	0		
	CDH23.3	3712	0	0	0	0	19	284	1484	1386	507	31	0	0		
	CDH26.7	750	0	0	0	0	1	32	346	316	54	1	0	0		
(14) Wind	WSAvg	3.9	4.5	4.3	4.3	4.2	3.5	3.2	3.1	3.4	3.8	3.9	4.5	4.4		
(15) Precipitation	PrecAvg	698	74	57	68	62	48	19	8	17	63	93	99	87		
	PrecMax	1111	178	153	217	141	211	50	26	84	157	169	259	199		
	PrecMin	465	11	9	9	11	9	1	0	0	6	4	19	7		
	PrecStd	164	38	38	54	36	44	13	7	18	42	44	49	51		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.4	18.2	19.0	21.4	25.5	29.5	32.7	32.3	29.8	25.6	21.9	18.7		
		MCWB	13.0	14.4	13.3	15.1	18.8	21.0	21.8	22.9	21.8	19.9	16.2	15.0		
	2%	DB	16.0	16.5	17.3	19.5	23.6	27.7	30.6	30.4	28.0	24.2	20.0	17.0		
		MCWB	12.2	13.4	12.8	14.5	18.3	21.4	23.1	22.8	21.9	19.8	16.2	14.2		
	5%	DB	14.8	15.2	15.9	18.0	22.4	26.2	29.5	29.5	27.0	23.1	18.8	15.8		
		MCWB	11.6	12.5	12.0	14.2	17.7	20.6	23.7	23.3	22.1	19.6	15.7	13.1		
	10%	DB	14.0	14.0	14.9	16.9	21.2	25.0	28.5	28.6	26.0	22.1	17.7	15.0		
		MCWB	11.4	11.5	11.8	13.5	16.8	20.1	23.3	23.3	21.6	19.3	15.1	12.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.1	15.1	15.3	16.7	20.7	25.0	26.9	26.2	24.5	22.2	18.0	16.1		
		MCDB	15.4	17.5	17.8	19.2	24.1	27.2	29.4	29.5	27.3	23.6	19.8	17.7		
	2%	WB	13.5	13.9	14.0	15.6	19.6	22.8	25.7	25.4	23.7	21.4	17.2	14.9		
		MCDB	14.8	16.1	15.5	18.1	22.5	25.7	28.7	28.7	26.4	22.6	18.8	16.4		
	5%	WB	12.7	12.9	13.3	14.7	18.5	21.7	24.9	24.7	23.1	20.7	16.4	13.8		
		MCDB	14.2	14.8	14.8	17.0	21.3	24.6	28.2	28.0	25.7	22.0	18.1	15.3		
	10%	WB	11.9	12.0	12.5	14.1	17.5	21.0	24.2	24.1	22.4	20.0	15.5	13.1		
		MCDB	13.6	13.5	14.2	16.0	20.3	23.9	27.3	27.4	24.9	21.7	17.4	14.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.9	4.7	5.1	5.6	5.9	6.7	7.1	7.1	6.3	5.0	4.4	4.3		
		MCDBR	5.6	6.2	6.8	7.6	7.7	8.5	8.3	8.2	7.6	6.1	5.9	5.2		
	5% WB	MCWBR	4.3	4.2	4.4	4.9	4.3	4.5	4.6	4.5	4.5	3.8	3.9	4.0		
		MCWBR	5.1	5.6	5.9	6.4	6.9	7.0	7.3	7.1	6.9	4.9	4.6	4.4		
(40) Clear-Sky Solar Irradiance	taub	taub	0.334	0.352	0.382	0.417	0.429	0.415	0.417	0.414	0.408	0.389	0.367	0.337		
		taud	2.491	2.432	2.357	2.264	2.270	2.354	2.355	2.373	2.385	2.417	2.419	2.481		
	Edn at Noon	Edn at Noon	814	852	863	854	850	861	855	847	826	798	761	775		
		Edh at Noon	75	92	111	130	133	122	121	116	107	93	81	71		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.77	2.66	3.94	5.23	6.28	7.17	7.29	6.32	4.75	3.25	2.00	1.58		
	RadStd	RadStd	0.17	0.25	0.37	0.32	0.46	0.34	0.27	0.31	0.21	0.27	0.16	0.16		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (16 neighbors)		+0.24	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+86	N/A	

Nomenclature: See separate page