

FIGARI SUD CORSE AP, France

WMO: 077800

Lat: 41.5053N

Lon: 9.1036E

Elev: 87

StdP: 14.65

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	28.4	31.0	21.7	16.4	37.5	25.3	19.4	36.8	31.0	54.2	27.9	53.4	2.8	40	0.522

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.9	94.2	71.3	91.3	71.0	88.8	70.9	75.7	87.3	74.5	85.7	73.2	84.2	11.1	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.1	119.3	81.9	70.8	114.0	81.1	69.5	108.7	80.0	39.2	87.4	38.0	85.9	36.8	84.2	80.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
26.9	23.5	21.0	DB	23.1	100.7	2.4	3.5	21.4	103.2	20.0	105.3	18.7	107.2	17.0	109.7
			WB	22.2	77.7	2.4	1.5	20.5	78.8	19.1	79.6	17.7	80.5	15.9	81.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	60.9	47.9	47.9	51.8	56.7	63.3	70.9	76.0	75.6	69.6	63.8	55.7	50.1	(6)
(7)		DBStd	11.29	5.33	5.25	5.29	4.31	4.88	5.29	4.40	4.55	4.92	5.29	5.72	5.67	(7)
(8)		HDD50	339	107	96	43	4	1	0	0	0	0	0	17	71	(8)
(9)		HDD65	2614	531	480	408	249	88	12	1	1	15	85	281	463	(9)
(10)		CDD50	4297	40	35	100	205	414	627	806	794	587	428	187	74	(10)
(11)		CDD65	1102	0	0	0	1	37	189	342	331	152	48	2	0	(11)
(12)		CDH74	11768	0	0	2	16	360	1955	3924	3910	1387	212	2	0	(12)
(13)		CDH80	4605	0	0	1	0	66	675	1747	1781	322	13	0	0	(13)
(14)	Wind	WSAvg	9.5	9.2	9.3	10.8	10.4	10.1	9.6	9.9	8.7	8.5	8.7	8.8	9.4	(14)
(15)	Precipitation	PrecAvg	29.6	2.9	2.4	2.6	2.7	2.1	0.9	0.4	0.7	2.4	4.0	4.6	3.7	(15)
(16)		PrecMax	43.5	7.3	6.9	8.4	5.0	8.9	2.8	1.3	3.7	5.5	9.8	10.6	8.3	(16)
(17)		PrecMin	20.2	0.2	0.5	0.0	0.5	0.3	0.0	0.0	0.4	0.0	1.1	0.2	0.2	(17)
(18)		PrecStd	6.3	1.7	1.6	1.8	1.2	1.7	0.7	0.4	0.8	1.4	2.2	2.4	1.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.1	63.6	69.9	76.3	86.3	94.5	97.4	99.1	89.4	82.0	73.1	65.7	(19)
(20)			MCWB	56.0	54.0	56.4	61.1	66.4	69.3	71.2	70.4	69.3	68.0	62.9	57.6	(20)
(21)		2%	DB	61.0	60.9	66.0	72.5	81.2	90.0	93.8	95.0	86.1	78.7	70.1	63.2	(21)
(22)			MCWB	54.5	53.3	55.2	59.6	63.8	69.4	71.6	71.7	69.3	67.4	62.0	56.7	(22)
(23)		5%	DB	59.4	59.3	63.9	69.6	78.1	86.9	91.2	91.6	83.6	76.4	67.7	61.7	(23)
(24)			MCWB	53.6	52.6	54.9	58.4	63.3	69.5	71.2	71.5	68.8	66.4	60.9	55.8	(24)
(25)		10%	DB	57.8	57.8	61.9	67.0	74.9	84.0	88.7	88.9	81.4	74.1	65.6	60.0	(25)
(26)			MCWB	52.4	51.7	54.1	57.3	62.5	68.4	71.0	71.6	67.9	65.1	59.6	54.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.9	56.6	59.2	63.6	68.6	75.4	77.3	77.5	74.3	71.3	65.5	60.0	(27)
(28)			MCD B	61.5	61.7	66.7	73.0	79.6	86.6	89.6	89.3	83.2	77.4	70.2	63.2	(28)
(29)		2%	WB	56.2	55.0	57.4	61.2	66.5	73.3	75.7	76.0	72.5	69.5	63.5	58.4	(29)
(30)			MCD B	59.8	58.9	63.1	69.6	76.2	84.2	87.6	87.5	81.2	75.4	68.2	61.8	(30)
(31)		5%	WB	54.7	53.9	56.2	59.8	64.9	71.6	74.4	74.7	71.2	68.0	61.9	57.0	(31)
(32)			MCD B	58.6	57.9	61.5	67.3	74.4	81.9	86.0	85.9	80.2	73.7	66.4	60.7	(32)
(33)		10%	WB	53.0	52.6	55.1	58.4	63.7	70.0	73.0	73.4	69.7	66.5	60.2	55.5	(33)
(34)			MCD B	57.2	57.0	60.1	65.1	72.6	80.4	84.5	84.6	78.7	72.6	64.8	59.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	17.1	17.9	18.4	19.3	20.8	23.2	23.9	25.5	22.3	19.1	17.2	17.4	(35)
(36)			MCDBR	18.4	19.3	21.5	24.5	27.4	28.2	29.8	30.7	25.7	21.4	19.6	18.6	(36)
(37)			MCWBR	13.5	13.7	13.9	14.5	13.9	13.0	13.7	14.0	13.4	12.5	13.2	13.6	(37)
(38)		5% WB	MCD BR	15.1	17.1	17.4	22.1	23.1	25.2	26.2	28.0	23.0	17.6	16.7	14.4	(38)
(39)			MCWBR	11.8	12.7	12.0	13.9	12.5	12.5	13.0	14.2	13.0	10.8	12.0	11.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.336	0.354	0.384	0.417	0.430	0.415	0.418	0.415	0.409	0.391	0.369	0.339	(40)	
(41)		taud	2.489	2.430	2.359	2.272	2.277	2.361	2.361	2.379	2.389	2.417	2.418	2.477	(41)	
(42)		Ebn at Noon	258	270	273	271	270	273	271	268	262	252	241	246	(42)	
(43)		Edh at Noon	24	29	35	41	42	39	38	36	34	30	26	23	(43)	
(44)	All-Sky Solar Radiation	RadAvg	564	849	1270	1680	2016	2309	2344	2023	1521	1043	639	504	(44)	
(45)		RadStd	55	81	112	104	153	104	82	99	63	84	49	51	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (15 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page