

CAP CORSE, France

WMO: 077850

Lat: 43.005N

Lon: 9.358E

Elev: 113

StdP: 99.97

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	4.0	5.5	-6.0	2.3	7.4	-4.0	2.7	7.9	26.1	12.8	23.8	12.1	8.8	90	0.590

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.2	31.6	22.5	30.4	22.5	29.2	22.3	24.8	29.1	24.2	28.4	23.5	27.7	4.5	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.5	18.6	27.6	22.8	17.7	27.3	22.0	16.9	26.7	76.0	29.2	73.3	28.5	70.6	27.7	28.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.3	20.6	18.0	DB	2.2	35.3	1.8	1.6	1.0	36.4	-0.1	37.3	-1.0	38.2	-2.3	39.3	(4)
(5)			WB	0.0	25.6	1.8	1.0	-1.3	26.3	-2.3	26.9	-3.3	27.4	-4.6	28.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.7	10.9	10.6	12.6	15.4	18.8	22.8	25.7	25.8	22.6	19.4	15.2	12.2
	DBStd	5.88	2.39	2.62	2.26	2.28	2.51	2.67	1.99	1.84	2.25	2.41	2.94	2.48
	HDD10.0	59	18	22	7	0	0	0	0	0	0	0	2	10
	HDD18.3	1047	229	216	178	93	23	1	0	0	1	17	98	192
	CDD10.0	2867	48	39	87	161	272	383	486	488	377	290	158	77
	CDD18.3	813	0	0	0	4	37	133	228	230	128	48	4	0
	CDH23.3	4992	0	0	0	3	104	737	1854	1766	475	52	0	0
	CDH26.7	1201	0	0	0	0	14	168	503	456	57	1	0	0
Wind	WSAvg	7.1	8.0	8.0	8.3	7.1	6.5	6.0	6.1	5.9	6.6	6.5	7.6	8.3
Precipitation	PrecAvg	552	43	44	43	47	31	23	11	13	50	77	109	59
	PrecMax	748	117	131	125	108	125	71	74	40	134	318	270	127
	PrecMin	336	3	6	2	2	2	1	0	0	2	7	10	4
	PrecStd	127	27	30	28	27	28	19	16	13	37	60	71	33
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	17.8	17.1	19.2	23.4	28.5	32.7	33.8	33.3	30.0	26.4	22.0	18.2
		MCWB	13.6	12.2	12.7	14.5	18.0	21.2	22.4	23.1	22.6	20.5	17.1	14.1
	2%	DB	15.8	15.6	17.8	21.5	25.8	30.3	31.6	31.5	28.1	24.7	20.6	16.9
		MCWB	12.0	11.6	12.5	14.7	17.8	21.0	22.5	23.2	21.4	19.6	16.4	13.4
	5%	DB	14.9	14.6	16.6	20.2	24.1	28.4	30.4	30.2	27.0	23.5	19.6	16.0
		MCWB	11.6	11.0	12.0	14.5	17.2	21.0	22.7	23.0	21.0	18.9	15.9	12.8
	10%	DB	14.0	13.7	15.6	18.8	22.7	27.0	29.2	29.1	25.9	22.4	18.7	15.2
		MCWB	11.2	10.5	11.6	13.9	16.7	20.5	22.5	22.6	20.3	18.2	15.3	12.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.7	13.3	14.5	17.6	20.6	24.4	26.1	25.6	24.0	21.5	18.7	14.9
		MCDB	16.0	15.7	17.5	20.9	25.5	29.1	29.6	30.1	28.0	24.7	20.5	17.2
	2%	WB	12.9	12.3	13.6	16.2	19.3	23.2	25.1	24.8	22.8	20.5	17.5	14.1
		MCDB	14.9	14.6	16.3	19.6	23.7	27.5	29.1	29.2	26.7	23.7	19.6	16.1
	5%	WB	12.2	11.7	13.0	15.4	18.4	22.2	24.3	24.2	22.0	19.7	16.5	13.4
		MCDB	14.2	13.8	15.6	18.6	22.5	26.5	28.4	28.5	25.5	22.8	19.1	15.5
	10%	WB	11.5	11.1	12.3	14.6	17.5	21.2	23.6	23.6	21.3	18.9	15.6	12.7
		MCDB	13.5	13.3	14.8	17.7	21.5	25.8	27.8	27.8	24.6	21.7	18.3	14.9
Mean Daily Temperature Range	5% DB	MDBR	3.8	4.1	4.6	5.3	5.8	6.3	6.3	6.2	5.3	4.5	3.9	3.6
		MCDBR	4.8	5.0	5.9	7.0	7.6	8.1	8.0	7.6	6.6	5.7	4.9	4.3
		MCWBR	3.6	3.8	4.3	4.7	5.3	5.4	5.5	5.3	4.6	3.7	3.6	3.4
	5% WB	MCDBR	4.1	4.5	5.3	6.2	6.9	7.2	6.7	6.8	6.1	5.3	4.3	3.7
		MCWBR	3.5	3.6	4.1	4.6	5.3	5.2	5.0	5.1	4.4	3.7	3.6	3.2
Clear-Sky Solar Irradiance	taub	0.315	0.330	0.356	0.393	0.402	0.401	0.398	0.395	0.384	0.364	0.341	0.316	
	taud	2.548	2.506	2.451	2.355	2.375	2.414	2.420	2.440	2.458	2.515	2.526	2.551	
	Ebn at Noon	829	872	886	875	873	872	870	862	846	821	786	793	
	Edh at Noon	69	84	100	118	119	115	113	107	98	83	70	63	
All-Sky Solar Radiation	RadAvg	1.66	2.53	3.82	5.18	6.29	7.11	7.24	6.30	4.73	3.06	1.86	1.45	
	RadStd	0.15	0.26	0.41	0.31	0.46	0.34	0.29	0.28	0.21	0.27	0.17	0.17	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (21 neighbors)	+0.25	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+71	+31

Nomenclature: See separate page