

LA CORUNA, Spain

WMO: 080010

Lat: 43.3658N

Lon: 8.4214W

Elev: 220

StdP: 14.58

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	40.3	42.4	29.7	23.9	44.9	32.5	27.2	46.1	25.4	52.0	23.0	53.2	6.0	150	0.439

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.5	78.6	66.5	75.5	65.5	73.3	64.6	68.3	75.3	67.1	73.1	66.0	71.1	7.3	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.8	95.9	70.9	64.7	92.4	69.8	63.8	89.4	69.0	32.6	75.5	31.6	73.4	30.8	71.3	75.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
21.4	18.9	16.7	DB	36.0	86.4	3.8	3.7	33.3	89.1	31.1	91.3	29.0	93.4	26.3	96.1	
			WB	33.4	72.0	3.4	1.6	30.9	73.1	29.0	74.1	27.1	75.0	24.6	76.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	58.9	51.9	52.0	54.3	55.8	59.3	63.6	66.3	67.3	65.4	61.8	55.9	53.1
	DBStd	6.75	4.20	4.19	4.25	3.85	3.87	3.64	2.84	2.69	3.28	4.01	4.26	4.43
	HDD50	88	28	24	10	2	0	0	0	0	0	0	4	20
	HDD65	2448	407	364	333	278	184	67	15	7	33	115	275	370
	CDD50	3346	86	80	142	175	287	409	506	536	463	366	180	116
	CDD65	232	0	0	1	1	6	27	56	78	46	16	1	0
	CDH74	450	0	0	2	7	23	96	111	116	71	24	0	0
	CDH80	61	0	0	0	1	3	16	20	12	6	3	0	0
Wind	WSAvg	7.7	8.5	8.6	8.8	8.3	7.7	7.3	7.1	6.7	6.6	6.7	8.0	8.0
Precipitation	PrecAvg	39.9	5.0	4.0	3.5	3.3	2.9	1.9	1.1	1.3	2.4	4.5	5.4	4.8
	PrecMax	55.1	11.5	9.8	10.3	9.1	6.8	5.2	3.9	3.9	6.3	12.1	11.7	15.7
	PrecMin	26.5	0.1	0.4	0.0	0.2	0.4	0.0	0.0	0.0	0.1	0.6	0.1	0.8
	PrecStd	7.0	2.6	2.3	2.4	1.8	1.5	1.3	1.0	1.6	2.9	2.6	2.5	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	63.4	67.4	70.8	72.0	77.0	82.2	83.0	81.2	79.7	76.9	69.8	65.3
		MCWB	56.3	55.7	56.8	59.5	63.8	68.5	69.1	68.2	66.3	64.4	61.3	57.3
	2%	DB	61.0	62.3	65.7	67.4	71.2	76.2	76.6	76.9	75.6	72.4	66.5	62.8
		MCWB	56.0	54.2	55.7	57.8	61.1	64.8	66.6	67.2	65.8	63.3	60.8	56.9
	5%	DB	59.4	59.8	62.8	64.3	67.7	72.2	73.4	74.3	73.2	70.0	63.9	61.2
		MCWB	54.8	53.9	55.0	56.5	59.9	63.0	65.3	66.1	64.7	62.6	58.7	56.2
	10%	DB	57.9	57.9	60.7	61.8	65.1	69.2	71.1	72.1	70.9	68.0	61.9	59.6
		MCWB	53.6	53.0	54.3	55.5	58.7	62.0	64.4	65.2	63.7	61.9	57.5	55.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.1	57.6	59.7	60.9	64.7	69.3	69.7	70.7	68.7	67.1	63.9	59.9
		MCDB	61.6	62.2	65.3	68.6	73.7	80.1	79.4	77.9	75.8	71.5	67.5	62.7
	2%	WB	57.2	56.3	57.7	58.9	62.7	66.0	67.5	68.4	67.1	65.3	61.6	58.3
		MCDB	60.0	60.3	63.0	65.0	69.2	73.7	74.8	74.4	73.2	70.0	65.1	61.4
	5%	WB	55.7	54.9	56.3	57.5	61.0	64.2	66.2	67.1	65.8	63.9	59.8	56.9
		MCDB	58.4	58.7	61.4	62.6	66.0	69.7	71.8	72.3	71.0	68.5	63.1	60.2
	10%	WB	54.2	53.6	54.9	56.2	59.5	62.9	65.1	66.1	64.7	62.5	58.1	55.5
		MCDB	57.0	57.3	59.6	60.8	64.0	67.7	70.0	70.5	69.4	66.8	61.4	58.9
Mean Daily Temperature Range	5% DB	MDBR	7.4	8.7	9.5	9.4	9.2	9.3	9.1	9.5	10.1	9.5	7.6	7.7
		MCDBR	7.8	11.6	13.4	14.1	13.6	14.7	13.2	13.0	13.6	12.7	9.4	8.8
		MCWBR	6.1	7.4	8.2	8.3	7.7	7.7	6.6	6.4	6.7	7.0	6.4	6.5
	5% WB	MCDBR	6.5	9.3	11.1	11.9	12.0	12.6	11.5	11.2	11.7	10.3	8.1	7.4
MCWBR		6.2	7.2	7.8	7.9	7.3	7.1	6.4	6.3	6.5	6.7	6.6	6.6	
Clear-Sky Solar Irradiance	taub	0.340	0.345	0.376	0.383	0.385	0.389	0.379	0.377	0.370	0.366	0.346	0.333	
	taud	2.468	2.448	2.368	2.359	2.383	2.392	2.429	2.446	2.462	2.475	2.466	2.479	
	Ebn at Noon	250	269	273	280	282	280	281	279	272	258	244	240	
	Edh at Noon	23	28	34	37	37	37	36	34	31	27	23	22	
All-Sky Solar Radiation	RadAvg	452	738	1108	1507	1804	1962	1965	1758	1405	885	533	417	
	RadStd	51	105	159	148	151	130	116	128	85	101	75	53	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	+0.81	+0.49	N/A	N/A	N/A	N/A	N/A
Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page