

LA CORUNA AP, Spain

WMO: 080020

Lat: 43.307N

Lon: 8.372W

Elev: 323

StdP: 14.53

Time Zone: 1.00 (EUC)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	32.2	34.8	28.3	22.5	39.3	30.6	25.0	40.3	28.4	54.1	24.8	53.0	5.0	180	0.454

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	15.3	83.8	68.8	80.2	67.2	77.0	66.0	70.7	79.7	69.2	76.6	67.7	74.2	7.7	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.0	104.1	74.3	66.4	98.3	72.6	64.8	93.0	71.3	34.8	80.5	33.5	76.8	32.4	74.2	77.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.1	18.3	16.2	DB	28.6	90.7	2.0	3.2	27.2	93.0	26.1	94.8	25.0	96.6	23.6	98.9	(4)
(5)			WB	28.1	73.1	2.1	2.2	26.6	74.6	25.3	75.9	24.1	77.1	22.6	78.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	57.8	49.8	49.7	51.7	54.5	58.9	63.4	67.0	67.1	65.3	60.7	54.0	51.1		
	DBStd	7.97	5.20	4.64	4.49	4.80	4.37	4.14	4.11	3.73	4.45	4.88	5.17	5.21		
	HDD50	242	69	57	32	11	0	0	0	0	0	1	20	52		
	HDD65	2908	470	429	412	318	199	77	21	21	49	148	332	432		
	CDD50	3093	64	48	85	145	275	403	528	530	459	332	139	85		
	CDD65	284	0	0	0	2	8	31	84	86	58	14	1	0		
	CDH74	1466	0	0	6	22	89	197	425	381	282	63	1	0		
	CDH80	319	0	0	0	6	17	42	124	64	55	11	0	0		
(14) Wind	WSAvg	7.0	7.3	7.7	7.9	7.4	7.4	7.0	6.7	6.6	5.9	6.2	7.0	7.3		
(15) Precipitation	PrecAvg	45.0	5.4	3.7	3.5	4.2	3.1	1.8	1.5	1.7	2.7	5.9	6.6	5.0		
	PrecMax	58.2	10.4	7.1	12.1	12.4	7.5	4.7	4.5	3.8	6.3	13.3	12.4	11.9		
	PrecMin	31.0	1.3	0.1	0.0	1.0	0.7	0.0	0.0	0.4	0.6	0.8	0.8	0.8		
	PrecStd	7.5	2.6	2.2	3.0	2.5	1.5	1.3	1.1	1.1	1.7	3.0	3.1	2.4		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.9	68.0	73.6	75.6	82.2	85.5	89.8	85.7	86.3	79.2	71.6	65.0		
		MCWB	57.8	54.4	56.0	61.2	65.9	67.9	73.3	71.0	69.8	64.2	61.5	56.9		
	2%	DB	61.0	62.7	66.5	70.8	75.5	79.1	82.8	81.0	80.4	75.0	66.6	62.7		
		MCWB	56.9	53.0	54.2	59.3	62.4	65.6	70.2	68.3	66.8	63.3	60.4	56.6		
	5%	DB	59.3	59.4	62.7	67.2	70.3	75.2	78.3	78.4	76.9	71.7	64.3	60.8		
		MCWB	55.5	53.2	53.3	57.6	60.7	64.9	67.9	67.6	65.8	62.5	58.6	55.8		
	10%	DB	57.5	57.4	59.4	63.9	66.5	71.5	75.0	75.2	73.8	69.3	61.2	59.1		
		MCWB	53.8	52.4	52.9	56.2	58.7	63.2	66.5	66.5	64.8	62.1	57.2	54.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.8	57.3	58.6	62.6	66.4	70.2	74.1	72.6	71.7	67.4	64.4	60.1		
		MCDB	61.8	61.8	66.4	73.9	78.2	82.1	88.0	81.4	82.5	73.7	67.8	62.6		
	2%	WB	57.9	55.6	56.5	60.3	63.8	67.4	70.8	70.2	69.3	65.6	61.8	58.3		
		MCDB	60.4	60.0	62.9	67.9	73.8	77.0	80.7	77.6	76.3	71.4	65.9	61.0		
	5%	WB	56.0	54.3	55.1	58.7	61.6	65.4	68.9	68.9	67.8	64.1	59.9	56.9		
		MCDB	58.9	59.0	60.8	65.7	68.8	73.0	76.3	75.5	73.9	69.7	63.2	60.0		
	10%	WB	54.6	52.8	53.7	57.1	59.8	63.7	67.2	67.4	66.2	62.8	57.9	55.3		
		MCDB	57.5	57.2	59.4	62.9	65.7	69.8	73.4	73.3	72.3	68.1	61.1	58.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.6	13.7	14.8	15.2	14.3	13.8	13.9	15.3	16.6	16.0	12.6	13.1		
		MCDBR	11.1	18.4	21.9	23.5	22.4	22.1	21.2	21.4	22.4	20.8	15.7	13.6		
		MCWBR	8.1	11.7	12.6	13.4	12.5	11.3	10.3	10.6	10.9	11.3	10.3	9.4		
	5% WB	MCDBR	9.4	14.5	17.7	20.3	19.7	18.4	18.1	18.0	17.8	16.6	12.8	10.1		
		MCWBR	7.7	10.2	11.1	12.5	11.3	10.1	9.6	9.8	9.2	9.9	9.3	8.2		
(40) Clear-Sky Solar Irradiance	taub		0.336	0.342	0.373	0.380	0.383	0.387	0.376	0.375	0.368	0.363	0.343	0.330		
	taud		2.475	2.452	2.372	2.360	2.381	2.390	2.426	2.442	2.459	2.478	2.474	2.487		
	Ebn at Noon		252	271	274	281	282	280	282	279	273	259	246	242		
	Edh at Noon		23	28	34	37	37	37	36	34	31	27	23	21		
(44) All-Sky Solar Radiation	RadAvg		455	741	1109	1505	1802	1965	1970	1766	1408	887	535	419		
	RadStd		54	107	161	151	154	132	118	129	85	103	77	54		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page