

ALBACETE AP, Spain

WMO: 082800

Lat: 38.952N

Lon: 1.863W

Elev: 2302

StdP: 13.51

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.2	26.5	15.7	13.3	37.0	19.8	16.1	36.9	31.6	51.7	28.5	48.8	3.5	170	0.518

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	29.5	97.0	66.6	94.8	66.0	91.8	65.3	70.9	87.9	69.1	85.1	67.8	83.1	10.3	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.5	106.2	74.2	64.7	99.9	72.6	63.2	94.5	72.0	36.1	88.3	34.5	85.2	33.5	82.9	85.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.3	21.8	18.8	16.1	101.9	5.2	2.4	12.3	103.6	9.3	105.1	6.3	106.4	2.5	108.2
			15.4	73.9	5.3	3.3	11.7	76.3	8.6	78.2	5.6	80.1	1.8	82.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	58.3	42.1	44.5	49.8	54.5	61.8	71.2	77.5	76.9	68.5	60.1	48.6	43.2
	DBStd	13.63	5.48	5.57	5.65	5.49	6.22	6.03	4.22	4.15	5.43	5.69	6.02	5.52
	HDD50	826	249	164	73	19	2	0	0	0	0	5	95	219
	HDD65	3590	709	574	472	316	137	17	0	0	28	168	493	676
	CDD50	3859	5	10	66	153	367	637	852	835	555	319	52	8
	CDD65	1148	0	0	0	1	37	204	388	370	132	16	0	0
	CDH74	14157	0	0	17	74	612	2647	4943	4306	1333	223	2	0
	CDH80	6811	0	0	2	5	158	1226	2693	2235	458	34	0	0
	WSAvg	8.1	8.2	9.0	9.0	9.0	8.1	8.0	8.4	7.9	7.2	6.8	7.8	7.4
	PrecAvg	14.1	0.9	1.1	1.1	1.8	1.7	1.5	0.4	0.5	1.1	1.6	1.4	1.2
(15) Precipitation	PrecMax	21.6	2.8	3.5	4.3	4.5	6.3	5.4	1.6	2.1	4.1	6.6	4.6	3.9
	PrecMin	7.4	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	3.8	0.7	0.8	0.9	1.2	1.3	1.3	0.5	0.6	1.0	1.4	1.0	0.9
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.5	67.8	76.6	80.2	89.2	98.4	100.6	100.1	93.4	84.0	70.2	62.3
		MCWB	50.4	51.4	55.4	58.3	63.9	65.9	67.1	66.5	64.9	60.3	55.8	52.3
	2%	DB	58.1	63.3	71.3	75.8	84.2	93.8	97.2	96.5	88.2	79.7	66.1	58.4
		MCWB	48.9	49.4	53.0	56.7	60.9	65.5	66.6	66.7	63.8	59.5	54.1	51.2
	5%	DB	55.2	59.4	66.7	72.2	80.7	90.5	95.1	93.6	85.3	75.7	62.5	55.5
		MCWB	47.9	48.1	51.5	55.3	59.8	65.0	66.0	66.1	63.1	59.0	53.0	49.7
	10%	DB	52.1	55.7	62.7	68.3	77.0	87.5	92.8	91.3	81.9	71.9	59.1	53.1
		MCWB	46.4	47.0	50.1	53.6	58.7	63.9	65.7	65.6	62.5	58.5	52.0	48.0
	0.4%	WB	53.6	53.9	57.6	60.9	65.7	72.2	74.2	74.6	69.7	65.5	59.1	55.4
		MCDB	58.9	62.1	69.6	75.4	83.3	91.2	93.3	90.9	80.5	73.9	65.0	58.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	50.9	51.5	54.8	58.1	63.1	68.7	70.7	70.9	67.7	63.0	56.5	52.5
		MCDB	55.6	59.9	67.2	72.1	79.0	87.8	89.6	86.3	78.8	71.4	62.1	56.4
	5%	WB	49.1	49.5	52.9	56.2	61.3	66.7	68.8	69.2	66.2	61.5	54.7	50.4
		MCDB	53.4	56.9	63.3	69.5	76.4	84.9	86.6	83.9	77.0	69.6	60.0	54.2
	10%	WB	47.2	47.8	51.1	54.5	59.7	65.0	67.4	68.0	64.8	60.1	53.1	48.7
		MCDB	51.5	54.6	60.4	66.0	73.1	82.7	85.0	82.1	75.4	68.0	58.1	52.4
(35) Mean Daily Temperature Range	5% DB	MDBR	19.3	20.8	22.5	22.6	24.3	27.8	29.5	27.6	23.8	21.6	19.2	18.2
		MCDBR	24.6	29.2	31.0	30.6	30.7	32.6	32.7	31.4	29.3	28.4	24.8	21.5
		MCWBR	16.0	16.8	15.5	14.5	12.9	12.6	12.2	11.1	10.4	12.0	14.5	14.5
		MCDBR	19.3	23.3	25.6	27.6	27.5	30.2	30.1	27.6	24.8	21.4	19.3	18.1
	5% WB	MCWBR	13.7	14.4	13.7	13.9	12.7	13.0	12.8	11.1	10.3	10.3	12.2	13.2
(40) Clear-Sky Solar Irradiance	taub		0.280	0.301	0.341	0.350	0.372	0.384	0.370	0.378	0.362	0.339	0.304	0.286
	taud		2.494	2.456	2.352	2.344	2.314	2.307	2.339	2.321	2.369	2.432	2.493	2.498
	Ebn at Noon		287	295	291	294	288	283	286	281	280	276	275	276
	Edh at Noon		24	29	36	39	41	41	39	39	35	30	24	23
(44) All-Sky Solar Radiation	RadAvg		750	1017	1398	1751	2079	2381	2429	2093	1621	1160	808	671
	RadStd		94	125	150	143	158	89	64	83	85	96	97	59

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	-1.39	-1.13	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	N/A	N/A	-2.52	+0.85	N/A	N/A	N/A	N/A	N/A	+99

Nomenclature: See separate page