

IBIZA AP, Spain

WMO: 083730

Lat: 38.876N

Lon: 1.384E

Elev: 56

StdP: 14.67

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	39.6	42.0	28.3	22.3	48.2	31.8	26.3	48.8	29.8	57.1	27.3	57.6	3.1	340	0.416

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.7	88.1	75.0	86.4	74.5	85.1	74.2	78.4	84.7	77.2	83.5	76.1	82.6	9.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.5	138.7	82.4	75.2	132.3	81.8	73.8	126.2	81.1	41.8	85.0	40.6	83.7	39.5	82.6	84.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.8	21.5	18.8	35.4	93.5	2.3	2.6	33.8	95.3	32.5	96.9	31.2	98.3	29.6	100.2
			33.3	80.0	2.3	1.9	31.7	81.4	30.3	82.5	29.0	83.6	27.3	84.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	65.0	53.5	53.5	56.5	60.4	65.8	73.1	78.1	79.3	74.5	68.5	60.3	55.3
	DBStd	9.98	4.13	4.43	3.98	3.37	3.64	3.68	2.76	2.78	3.69	4.07	4.81	4.19
	HDD50	42	14	16	4	0	0	0	0	0	0	0	1	7
	HDD65	1591	358	323	264	142	34	1	0	0	0	15	152	302
	CDD50	5500	121	113	205	312	490	692	871	908	734	574	309	171
	CDD65	1574	0	0	0	4	59	242	406	443	285	124	11	0
	CDH74	11853	0	0	1	5	126	1447	3702	4351	1855	357	9	0
	CDH80	2839	0	0	0	0	6	244	992	1284	295	18	0	0
Wind	WSAvg	8.1	8.6	9.2	9.3	9.0	7.8	7.5	7.3	7.3	7.4	7.4	8.6	8.3
Precipitation	PrecAvg	16.3	1.5	1.1	1.3	1.3	1.0	0.6	0.1	0.9	1.8	2.5	2.0	2.1
	PrecMax	28.3	5.8	3.9	4.8	4.3	3.9	5.7	0.6	3.8	6.6	7.5	6.7	6.7
	PrecMin	6.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	5.5	1.4	1.1	1.3	1.1	1.0	0.9	0.1	1.2	1.9	2.1	1.5	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	67.1	67.9	71.3	74.4	80.4	87.8	90.0	91.4	87.5	82.3	75.0	67.7
		MCWB	56.9	57.0	57.6	60.6	65.1	71.5	73.7	74.9	74.4	71.1	64.5	59.7
	2%	DB	64.3	64.9	67.8	71.4	77.1	84.8	87.6	88.7	84.6	79.3	72.0	65.4
		MCWB	56.4	55.9	57.1	60.0	64.8	71.5	74.5	75.7	73.6	70.2	63.7	58.6
	5%	DB	62.4	62.9	65.6	69.4	75.0	82.7	86.1	86.9	83.1	77.5	70.1	64.0
		MCWB	56.0	55.3	56.8	59.8	64.5	70.7	74.0	75.6	72.8	69.1	62.8	57.9
	10%	DB	60.8	60.9	63.7	67.6	73.3	80.8	84.6	85.6	81.6	75.8	68.2	62.6
		MCWB	54.9	54.3	56.2	59.3	64.0	70.3	73.7	75.1	71.9	67.9	61.9	57.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.3	59.4	61.1	64.3	69.8	77.2	79.2	80.5	77.9	73.9	67.8	62.0
		MCDB	63.3	64.2	65.9	69.1	75.1	83.6	85.7	85.7	83.3	78.9	71.3	64.7
	2%	WB	58.4	58.0	59.7	62.8	68.0	74.4	77.6	79.0	75.9	72.2	65.9	60.7
		MCDB	61.9	62.5	64.5	68.0	73.4	80.9	84.3	85.0	82.0	76.9	69.8	63.6
	5%	WB	57.2	56.8	58.6	61.7	66.7	72.8	76.4	77.9	74.6	70.9	64.3	59.3
		MCDB	60.9	61.0	63.5	67.0	72.3	79.6	83.1	84.1	81.0	75.7	68.8	62.6
	10%	WB	55.9	55.6	57.5	60.5	65.5	71.6	75.4	76.8	73.4	69.5	62.7	58.1
		MCDB	59.8	59.7	62.1	65.8	71.2	78.5	82.3	83.2	79.9	74.4	67.5	61.7
Mean Daily Temperature Range	5% DB	MDBR	13.2	13.3	13.6	13.6	13.7	13.9	13.2	12.7	12.8	12.8	12.4	12.8
		MCDBR	14.0	14.4	15.9	15.6	15.6	16.0	14.6	14.0	13.6	13.9	13.6	13.3
		MCWBR	10.0	9.5	9.7	9.0	8.7	9.0	7.7	7.7	7.1	8.1	8.9	9.5
	5% WB	MCDBR	12.7	13.1	14.2	14.1	13.7	14.3	13.0	12.8	12.5	12.4	12.5	12.1
		MCWBR	10.0	9.5	9.6	9.4	8.5	8.7	7.6	7.7	7.5	8.1	9.0	9.3
Clear-Sky Solar Irradiance	taub	0.325	0.346	0.388	0.405	0.429	0.441	0.456	0.452	0.428	0.397	0.358	0.330	
	taud	2.538	2.482	2.363	2.335	2.296	2.296	2.267	2.284	2.352	2.421	2.488	2.530	
	Ebn at Noon	271	279	276	277	271	267	262	260	259	256	255	259	
	Edh at Noon	24	29	36	39	42	42	43	41	36	30	25	23	
All-Sky Solar Radiation	RadAvg	750	1017	1458	1837	2134	2406	2343	2039	1573	1135	774	648	
	RadStd	55	97	113	109	136	83	66	78	89	83	63	42	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (3 neighbors)	N/A	-1.26	N/A	N/A	N/A	N/A	N/A	+140	N/A	N/A
	N/A	N/A	-2.00	N/A	N/A	-0.97	N/A	N/A	N/A	N/A

Nomenclature: See separate page