

CORDOBA AP, Spain

WMO: 084100

Lat: 37.8489N

Lon: 4.8467W

Elev: 297

StdP: 14.54

Time Zone: 1.00 (EUC)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	31.7	33.9	21.2	16.1	49.4	26.2	20.4	51.1	22.0	57.5	18.9	57.4	1.4	80	0.417

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	30.5	104.8	68.2	102.1	67.6	99.6	67.1	71.0	94.1	70.1	93.0	69.1	91.5	7.8	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.5	95.1	74.0	64.1	90.5	74.0	62.8	86.4	74.0	34.9	93.8	34.1	93.2	33.2	91.5	88.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.3	15.5	13.4	DB	27.8	109.5	1.9	3.4	26.4	112.0	25.3	113.9	24.2	115.8	22.8	118.3	(4)
(5)			WB	26.4	74.6	2.4	4.4	24.7	77.8	23.2	80.4	21.9	82.8	20.1	86.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	65.5	49.4	51.8	56.5	62.2	69.3	77.4	83.0	83.7	76.5	68.3	56.2	51.0		
	DBStd	13.09	4.46	4.89	4.66	5.20	5.51	5.97	3.99	3.95	4.72	5.63	5.47	4.72		
	HDD50	159	63	35	5	0	0	0	0	0	0	0	12	44		
	HDD65	1990	483	369	265	115	23	1	0	0	1	32	267	434		
	CDD50	5829	46	86	206	365	598	823	1023	1044	796	568	199	75		
	CDD65	2182	0	0	1	30	156	373	558	579	346	135	4	0		
	CDH74	28927	0	1	108	503	2120	5076	7971	8105	3739	1265	38	1		
	CDH80	16546	0	0	13	131	958	2937	5056	5087	1903	459	2	0		
(14) Wind	WSAvg	4.8	4.0	4.9	5.1	5.4	5.2	5.6	5.8	5.1	4.6	3.9	3.9	4.0		
(15) Precipitation	PrecAvg	25.7	2.8	2.5	2.4	2.6	1.8	0.5	0.0	0.2	1.5	3.7	3.5	4.1		
	PrecMax	51.9	11.4	10.5	10.8	7.8	5.1	5.1	0.2	1.7	4.2	8.1	12.7	17.0		
	PrecMin	14.0	0.0	0.0	0.0	0.4	0.0	0.0	0.0	0.0	0.1	0.1	0.2	0.0		
	PrecStd	9.3	2.6	2.2	2.6	1.8	1.5	1.1	0.0	0.4	1.2	2.0	2.7	4.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	68.3	72.6	81.3	88.1	97.5	106.8	108.7	108.9	101.8	93.3	78.6	69.7		
		MCWB	56.2	56.1	59.6	63.1	64.5	69.3	68.8	69.2	68.6	63.7	60.5	56.9		
	2%	DB	63.9	68.8	77.1	84.0	93.0	101.5	104.9	104.4	97.2	89.2	74.1	65.9		
		MCWB	53.7	54.7	58.0	61.9	64.1	67.5	68.1	68.1	66.7	63.2	58.7	56.2		
	5%	DB	61.5	65.5	73.1	80.1	89.4	98.5	102.3	101.8	93.8	85.3	70.6	63.2		
		MCWB	52.8	53.7	56.3	60.8	62.7	66.5	67.3	67.6	65.7	63.1	58.0	55.5		
	10%	DB	59.0	62.3	69.3	75.9	85.6	95.0	99.4	99.3	90.3	81.2	67.0	60.6		
		MCWB	52.0	53.2	54.8	59.2	61.9	65.9	67.1	67.3	65.5	62.6	56.8	53.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.1	59.8	62.7	65.8	67.9	71.1	72.3	73.2	71.0	69.0	66.0	61.7		
		MCDB	62.6	64.7	75.8	81.5	87.9	97.5	97.4	93.6	88.3	79.0	72.2	64.7		
	2%	WB	56.7	58.2	59.9	63.8	65.6	69.5	70.8	71.1	69.7	67.0	62.0	59.2		
		MCDB	60.6	62.9	71.0	78.8	86.6	95.1	96.2	93.7	87.4	78.5	69.3	63.7		
	5%	WB	54.9	56.5	58.4	62.1	64.3	68.1	69.7	70.1	68.4	65.6	60.1	56.7		
		MCDB	59.5	61.7	68.5	76.3	84.6	93.3	94.8	93.1	85.4	77.0	66.7	60.9		
	10%	WB	52.9	54.7	56.7	60.4	63.0	66.9	68.6	69.1	67.4	64.2	58.3	54.7		
		MCDB	57.6	60.3	65.9	72.4	81.4	90.5	92.5	91.9	83.4	75.4	64.5	59.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	19.8	21.1	23.8	23.4	27.2	29.4	31.4	30.5	25.4	23.5	20.5	19.6		
		MCDBR	24.2	26.6	32.1	31.4	35.3	34.9	35.8	34.2	31.4	30.5	26.2	23.3		
		MCWBR	14.6	14.4	15.2	12.6	11.5	9.0	8.9	8.6	8.9	10.3	13.0	13.7		
	5% WB	MCDBR	18.0	18.1	25.4	27.6	31.0	31.8	31.2	29.4	25.1	22.8	19.6	17.5		
		MCWBR	11.8	11.2	13.2	11.8	10.7	8.5	8.6	8.2	7.3	8.4	11.0	11.5		
(40) Clear-Sky Solar Irradiance	taub		0.317	0.343	0.380	0.382	0.397	0.407	0.387	0.399	0.392	0.371	0.337	0.319		
	taud		2.485	2.424	2.320	2.335	2.321	2.314	2.354	2.327	2.367	2.432	2.489	2.499		
	Ebn at Noon		275	280	279	285	281	277	281	276	272	266	265	266		
	Edh at Noon		26	31	37	39	41	41	39	39	36	30	25	24		
(44) All-Sky Solar Radiation	RadAvg		786	1049	1419	1766	2128	2438	2499	2196	1689	1195	862	707		
	RadStd		105	143	155	145	174	96	55	62	104	102	91	74		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+97

Nomenclature: See separate page