

CORDOBA AP, Spain

WMO: 084100

Lat: 37.8489N

Lon: 4.8467W

Elev: 91

StdP: 100.24

Time Zone: 1.00 (EUC)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.2	1.0	-6.0	2.3	9.7	-3.2	2.9	10.6	9.8	14.2	8.4	14.1	0.6	80	0.417

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	17.0	40.4	20.1	39.0	19.8	37.5	19.5	21.7	34.5	21.2	33.9	20.6	33.1	3.5	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.6	13.6	23.3	17.8	12.9	23.4	17.1	12.3	23.3	63.2	34.3	61.3	34.0	59.5	33.0	31.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.2	6.9	6.0	-2.3	43.1	1.1	1.9	-3.1	44.4	-3.7	45.5	-4.3	46.6	-5.1	47.9		
			-3.1	23.7	1.4	2.5	-4.1	25.4	-4.9	26.9	-5.6	28.2	-6.6	30.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.6	9.7	11.0	13.6	16.8	20.7	25.2	28.3	28.7	24.7	20.2	13.5	10.6
	DBStd	7.27	2.48	2.72	2.59	2.89	3.06	3.31	2.22	2.19	2.62	3.13	3.04	2.62
	HDD10.0	88	35	19	3	0	0	0	0	0	0	7	24	
	HDD18.3	1106	268	205	147	64	13	1	0	1	18	148	241	
	CDD10.0	3238	26	48	114	203	332	457	568	580	442	316	111	42
	CDD18.3	1212	0	0	1	17	87	207	310	322	192	75	2	0
	CDH23.3	16071	0	1	60	279	1178	2820	4428	4503	2077	703	21	1
	CDH26.7	9192	0	0	7	73	532	1632	2809	2826	1057	255	1	0
Wind	WSAvg	2.1	1.8	2.2	2.3	2.4	2.3	2.5	2.6	2.3	2.1	1.7	1.8	1.8
Precipitation	PrecAvg	654	71	64	62	65	46	13	1	5	39	94	90	105
	PrecMax	1319	289	267	274	197	129	130	6	42	107	206	322	432
	PrecMin	356	0	0	0	9	0	0	0	0	2	2	4	0
	PrecStd	237	65	57	66	45	38	27	1	10	30	52	68	120
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.2	22.6	27.4	31.1	36.4	41.5	42.6	42.7	38.8	34.1	25.9	21.0
		MCWB	13.5	13.4	15.3	17.3	18.1	20.7	20.5	20.7	20.3	17.6	15.8	13.9
	2%	DB	17.7	20.4	25.1	28.9	33.9	38.6	40.5	40.2	36.2	31.8	23.4	18.8
		MCWB	12.1	12.6	14.5	16.6	17.8	19.7	20.1	20.0	19.3	17.3	14.8	13.5
	5%	DB	16.4	18.6	22.9	26.7	31.9	36.9	39.1	38.8	34.3	29.6	21.4	17.4
		MCWB	11.6	12.0	13.5	16.0	17.1	19.2	19.6	19.8	18.7	17.3	14.4	13.1
	10%	DB	15.0	16.8	20.7	24.4	29.8	35.0	37.4	37.4	32.4	27.3	19.4	15.9
		MCWB	11.1	11.8	12.7	15.1	16.6	18.8	19.5	19.6	18.6	17.0	13.8	11.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.1	15.5	17.0	18.8	20.0	21.7	22.4	22.9	21.7	20.6	18.9	16.5
		MCDB	17.0	18.2	24.3	27.5	31.1	36.4	36.3	34.2	31.3	26.1	22.3	18.2
	2%	WB	13.7	14.5	15.5	17.7	18.7	20.8	21.6	21.7	21.0	19.4	16.7	15.1
		MCDB	15.9	17.2	21.7	26.0	30.3	35.0	35.6	34.3	30.8	25.8	20.7	17.6
	5%	WB	12.7	13.6	14.6	16.7	17.9	20.0	21.0	21.2	20.2	18.7	15.6	13.7
		MCDB	15.3	16.5	20.3	24.6	29.2	34.1	34.9	33.9	29.7	25.0	19.3	16.1
	10%	WB	11.6	12.6	13.7	15.8	17.2	19.4	20.3	20.6	19.7	17.9	14.6	12.6
		MCDB	14.2	15.7	18.8	22.5	27.5	32.5	33.6	33.3	28.5	24.1	18.0	15.2
Mean Daily Temperature Range	5% DB	MDBR	11.0	11.7	13.2	13.0	15.1	16.3	17.5	17.0	14.1	13.1	11.4	10.9
		MCDBR	13.5	14.8	17.8	17.4	19.6	19.4	19.9	19.0	17.5	16.9	14.6	12.9
		MCWBR	8.1	8.0	8.5	7.0	6.4	5.0	4.9	4.8	4.9	5.7	7.2	7.6
	5% WB	MCDBR	10.0	10.1	14.1	15.3	17.2	17.7	17.3	16.3	14.0	12.6	10.9	9.7
		MCWBR	6.6	6.2	7.4	6.6	5.9	4.7	4.8	4.6	4.1	4.7	6.1	6.4
Clear-Sky Solar Irradiance	taub	0.317	0.343	0.380	0.382	0.397	0.407	0.387	0.399	0.392	0.371	0.337	0.319	
	taud	2.485	2.424	2.320	2.335	2.321	2.314	2.354	2.327	2.367	2.432	2.489	2.499	
	Ebn at Noon	867	884	880	898	885	873	887	870	856	840	836	838	
	Edh at Noon	81	97	118	124	128	129	123	123	112	95	80	75	
All-Sky Solar Radiation	RadAvg	2.48	3.31	4.47	5.57	6.71	7.68	7.88	6.92	5.32	3.77	2.72	2.23	
	RadStd	0.33	0.45	0.49	0.46	0.55	0.30	0.17	0.20	0.33	0.32	0.29	0.23	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+54

Nomenclature: See separate page