

JEREZ AP, Spain

WMO: 084510

Lat: 36.751N

Lon: 6.056W

Elev: 93

StdP: 14.65

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 33.7	(c) 36.3	(d) 25.3	(e) 19.4	(f) 45.8	(g) 29.8	(h) 23.9	(i) 44.6	(j) 25.0	(k) 57.5	(l) 22.3	(m) 55.4	(n) 2.4	(o) 10	(p) 0.428

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	27.6	99.7	71.6	96.9	71.1	94.3	70.3	75.4	93.3	73.8	91.0	72.5	88.7	8.5	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.1	111.1	81.4	68.8	106.0	79.7	67.6	101.9	78.4	38.8	93.2	37.4	91.5	36.1	88.6	79.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.1	19.0	16.7	29.0	106.1	3.5	2.7	26.5	108.1	24.5	109.6	22.5	111.1	20.0	113.1
			27.8	77.5	3.9	1.7	25.1	78.8	22.8	79.8	20.6	80.7	17.8	82.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	64.9	51.5	53.4	57.7	61.6	67.7	74.2	78.2	79.5	74.4	68.3	58.2	53.6
	DBStd	10.83	4.48	4.70	4.46	4.66	5.27	5.19	4.41	4.40	4.43	4.98	5.48	4.77
	HDD50	82	36	19	3	0	0	0	0	0	0	0	5	19
	HDD65	1720	420	326	227	123	31	1	0	0	0	24	213	355
	CDD50	5523	81	114	243	347	549	726	873	913	731	567	250	129
	CDD65	1685	0	0	2	20	115	277	408	448	281	126	8	0
	CDH74	19108	1	1	77	309	1433	3256	4952	5281	2699	1046	52	1
	CDH80	9499	0	0	6	63	545	1615	2745	2969	1204	349	3	0
(14) Wind	WSAvg	6.5	5.8	6.6	7.6	7.7	7.2	6.9	6.4	6.1	6.0	5.9	6.0	6.0
(15) Precipitation	PrecAvg	21.9	2.8	2.1	1.9	1.9	1.3	0.3	0.0	0.1	1.3	3.4	3.2	3.6
	PrecMax	51.6	12.9	10.6	7.2	5.9	5.3	2.5	0.4	1.1	4.2	8.5	9.0	20.9
	PrecMin	10.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.2
	PrecStd	8.3	2.6	2.1	1.6	1.3	1.3	0.6	0.1	0.2	1.1	2.2	2.4	4.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	69.6	73.0	80.5	85.5	94.5	100.6	103.7	104.1	98.7	91.6	78.9	70.9
		MCWB	56.8	58.9	62.3	64.2	68.1	71.2	72.0	72.9	70.4	68.0	63.4	60.0
	2%	DB	65.9	69.6	75.7	81.4	89.7	96.1	99.1	100.0	94.2	87.7	74.9	67.7
		MCWB	56.9	57.6	60.3	62.5	65.8	69.6	71.6	72.0	70.4	67.3	62.1	59.5
	5%	DB	63.4	66.6	72.0	77.3	86.1	92.8	96.4	97.0	90.7	83.9	71.9	65.3
		MCWB	56.3	56.5	58.3	61.3	64.7	68.6	71.0	71.8	69.6	66.6	61.3	58.8
	10%	DB	61.3	64.0	68.8	73.5	82.3	89.6	93.5	94.0	87.3	79.8	68.7	63.2
		MCWB	55.6	56.0	57.3	60.3	63.5	67.4	70.1	70.9	68.8	65.7	60.5	57.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	61.8	62.5	65.0	67.4	70.2	74.7	77.1	77.4	75.5	71.7	68.4	64.7
		MCDB	64.0	66.4	76.1	79.5	87.4	93.9	95.9	94.9	91.5	82.2	72.7	67.0
	2%	WB	59.8	60.9	62.3	65.0	68.2	72.4	75.0	75.6	73.4	69.9	65.2	62.4
		MCDB	62.4	64.7	70.0	76.9	85.0	90.5	93.3	93.5	88.2	80.5	70.9	65.0
	5%	WB	57.7	59.2	60.7	63.1	66.5	70.7	73.3	74.2	71.8	68.5	63.4	60.3
		MCDB	61.6	63.9	67.6	73.3	82.0	87.7	90.8	91.6	85.5	78.2	68.8	63.6
	10%	WB	56.1	57.2	59.3	61.4	64.8	69.1	71.9	72.7	70.2	67.2	61.8	58.4
		MCDB	60.5	62.8	66.2	70.3	78.6	85.0	88.5	89.2	82.6	76.4	66.8	62.5
(35) Mean Daily Temperature Range	5% DB	MDBR	20.0	21.2	21.2	21.2	24.3	26.3	28.1	27.6	24.0	21.8	19.8	19.2
		MCDBR	23.6	25.5	28.3	29.2	32.0	32.9	33.7	32.7	30.5	29.1	23.8	21.5
		MCWBR	15.8	15.5	15.5	14.2	13.3	12.4	12.3	11.8	11.8	12.9	13.3	14.1
	5% WB	MCDBR	18.2	19.4	21.7	23.9	28.4	28.9	30.1	29.1	25.7	22.8	17.6	15.5
		MCWBR	13.4	12.9	13.0	12.8	13.0	12.3	12.5	12.2	11.8	11.2	11.3	11.8
(40) Clear-Sky Solar Irradiance	taub		0.330	0.353	0.392	0.389	0.402	0.416	0.403	0.419	0.406	0.383	0.349	0.335
	taud		2.488	2.425	2.306	2.338	2.328	2.305	2.334	2.295	2.355	2.426	2.484	2.491
	Ebn at Noon		273	279	276	283	280	275	278	271	268	265	263	263
	Edh at Noon		26	31	38	39	40	41	40	41	36	31	26	25
(44) All-Sky Solar Radiation	RadAvg		845	1117	1490	1868	2230	2485	2528	2229	1735	1251	907	744
	RadStd		86	130	145	124	135	98	49	70	94	105	76	72

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	+2.30	+1.85	+1.22	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+112

Nomenclature: See separate page