

JEREZ AP, Spain

WMO: 084510

Lat: 36.751N

Lon: 6.056W

Elev: 28

StdP: 100.99

Time Zone: 1.00 (EUC)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	0.9	2.4	-3.7	2.8	7.7	-1.2	3.4	7.0	11.2	14.2	10.0	13.0	1.1	10	0.428

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	15.3	37.6	22.0	36.1	21.7	34.6	21.3	24.1	34.1	23.2	32.8	22.5	31.5	3.8	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.2	15.9	27.5	20.4	15.1	26.5	19.8	14.6	25.8	72.3	34.0	69.0	33.1	66.1	31.4	26.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.9	8.5	7.4		-1.7	41.2	1.9	1.5	-3.1	42.3	-4.2	43.1	-5.3	44.0	-6.7	45.1
				-2.3	25.3	2.1	1.0	-3.9	26.0	-5.1	26.5	-6.3	27.1	-7.9	27.8
				DB											
				WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.3	10.8	11.9	14.3	16.4	19.8	23.4	25.6	26.4	23.5	20.2	14.5	12.0
	DBStd	6.02	2.49	2.61	2.48	2.59	2.93	2.88	2.45	2.44	2.46	2.76	3.04	2.65
	HDD10.0	46	20	11	2	0	0	0	0	0	0	0	3	11
	HDD18.3	956	233	181	126	68	17	1	0	0	0	13	118	197
	CDD10.0	3068	45	63	135	193	305	403	485	507	406	315	139	72
	CDD18.3	936	0	0	1	11	64	154	227	249	156	70	4	0
	CDH23.3	10616	1	1	43	172	796	1809	2751	2934	1499	581	29	1
	CDH26.7	5277	0	0	3	35	303	897	1525	1649	669	194	2	0
Wind	WSAvg	2.9	2.6	2.9	3.4	3.5	3.2	3.1	2.8	2.7	2.7	2.6	2.7	2.7
Precipitation	PrecAvg	557	70	54	47	48	34	7	1	3	33	86	82	92
	PrecMax	1310	328	269	183	151	135	64	10	29	106	217	229	532
	PrecMin	267	0	0	0	1	0	0	0	0	0	2	2	6
	PrecStd	211	66	54	40	33	33	15	2	6	28	57	61	113
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.9	22.8	26.9	29.7	34.7	38.1	39.8	40.1	37.0	33.1	26.1	21.6
		MCWB	13.8	14.9	16.8	17.9	20.0	21.8	22.2	22.7	21.3	20.0	17.5	15.6
	2%	DB	18.9	20.9	24.3	27.4	32.0	35.6	37.3	37.8	34.6	30.9	23.9	19.8
		MCWB	13.8	14.2	15.7	17.0	18.8	20.9	22.0	22.2	21.4	19.6	16.7	15.3
	5%	DB	17.5	19.2	22.2	25.2	30.0	33.8	35.8	36.1	32.6	28.8	22.2	18.5
		MCWB	13.5	13.6	14.6	16.3	18.1	20.3	21.6	22.1	20.9	19.2	16.3	14.9
	10%	DB	16.3	17.8	20.4	23.0	28.0	32.0	34.2	34.4	30.7	26.6	20.4	17.3
		MCWB	13.1	13.3	14.1	15.7	17.5	19.7	21.2	21.6	20.5	18.7	15.8	14.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.6	16.9	18.4	19.7	21.2	23.7	25.0	25.2	24.2	22.0	20.2	18.2
		MCDB	17.8	19.1	24.5	26.4	30.8	34.4	35.5	34.9	33.0	27.9	22.6	19.5
	2%	WB	15.4	16.1	16.8	18.3	20.1	22.5	23.9	24.2	23.0	21.0	18.5	16.9
		MCDB	16.9	18.2	21.1	24.9	29.4	32.5	34.1	34.2	31.2	26.9	21.6	18.3
	5%	WB	14.3	15.1	16.0	17.3	19.1	21.5	23.0	23.4	22.1	20.3	17.5	15.7
		MCDB	16.5	17.7	19.8	22.9	27.8	31.0	32.7	33.1	29.7	25.7	20.4	17.6
	10%	WB	13.4	14.0	15.2	16.3	18.2	20.6	22.1	22.6	21.2	19.6	16.5	14.7
		MCDB	15.9	17.1	19.0	21.3	25.9	29.4	31.4	31.8	28.1	24.7	19.3	16.9
Mean Daily Temperature Range	5% DB	MDBR	11.1	11.8	11.8	11.8	13.5	14.6	15.6	15.3	13.4	12.1	11.0	10.6
		MCDBR	13.1	14.2	15.7	16.2	17.8	18.3	18.7	18.2	17.0	16.2	13.2	11.9
		MCWBR	8.8	8.6	8.6	7.9	7.4	6.9	6.8	6.5	6.5	7.2	7.4	7.9
	5% WB	MCDBR	10.1	10.8	12.1	13.3	15.8	16.1	16.7	16.2	14.3	12.7	9.8	8.6
		MCWBR	7.5	7.1	7.2	7.1	7.2	6.8	6.9	6.8	6.6	6.2	6.3	6.5
Clear-Sky Solar Irradiance	taub	0.330	0.353	0.392	0.389	0.402	0.416	0.403	0.419	0.406	0.383	0.349	0.335	
	taud	2.488	2.425	2.306	2.338	2.328	2.305	2.334	2.295	2.355	2.426	2.484	2.491	
	Ebn at Noon	861	880	871	893	882	866	875	853	846	834	829	828	
	Edh at Noon	82	99	121	124	127	130	126	128	114	98	82	78	
All-Sky Solar Radiation	RadAvg	2.66	3.52	4.70	5.89	7.03	7.83	7.97	7.03	5.47	3.94	2.86	2.35	
	RadStd	0.27	0.41	0.46	0.39	0.43	0.31	0.15	0.22	0.29	0.33	0.24	0.23	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	+1.28	+1.03	+0.68	N/A	N/A	N/A	N/A
(47)	Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+62

Nomenclature: See separate page