

BEJA AB, Portugal

WMO: 085610

Lat: 38.0786N

Lon: 7.9267W

Elev: 666

StdP: 14.35

Time Zone: 0.00 (EUW)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	35.4	37.5	25.1	19.6	48.7	29.2	23.8	50.4	24.6	55.4	22.7	52.8	5.6	100	0.495

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	28.3	98.0	68.8	95.1	67.6	92.0	66.7	72.4	91.7	70.9	88.8	69.3	85.6	9.1	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.5	100.0	76.6	65.2	95.7	75.2	64.1	91.8	74.1	36.4	92.1	35.0	88.9	33.7	85.9	79.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.7	19.2	17.4	31.2	104.2	2.3	3.3	29.6	106.6	28.2	108.5	27.0	110.3	25.3	112.7		
(5)			29.9	74.8	2.1	2.6	28.3	76.7	27.1	78.2	25.9	79.7	24.3	81.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	62.3	49.8	50.9	54.7	58.5	64.9	71.3	75.1	76.2	71.9	66.0	56.2	51.3		
	DBStd	10.66	4.28	4.34	4.26	5.00	6.08	6.15	4.77	4.68	4.78	5.29	4.88	4.51		
	HDD50	149	55	39	8	1	0	0	0	0	0	0	7	39		
	HDD65	2221	471	395	319	202	78	11	0	0	2	51	267	425		
	CDD50	4640	48	64	154	257	462	640	778	812	658	495	193	79		
	CDD65	1237	0	0	0	8	75	201	313	347	211	80	2	0		
	CDH74	13997	0	0	12	128	998	2387	3708	4089	2046	626	3	0		
	CDH80	6596	0	0	0	11	359	1134	1903	2152	863	174	0	0		
(14) Wind	WSAvg	8.8	8.0	9.1	9.3	9.1	9.1	9.3	10.0	9.3	8.2	8.2	8.4	8.0		
(15) Precipitation	PrecAvg	23.0	3.1	2.7	2.0	2.3	1.7	0.8	0.1	0.1	1.0	2.6	3.0	3.5		
	PrecMax	41.0	10.8	6.5	5.6	6.0	5.9	3.3	0.7	1.5	4.6	8.4	11.1	11.0		
	PrecMin	14.0	0.0	0.1	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.2		
	PrecStd	6.1	2.5	2.0	1.5	1.5	1.5	0.9	0.2	0.3	1.1	2.1	2.3	2.8		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	63.9	66.7	75.8	81.8	92.9	101.2	102.1	101.7	97.4	89.3	73.8	66.5		
		MCWB	55.5	55.0	58.7	63.4	65.5	66.4	70.5	70.0	68.2	62.7	61.2	57.0		
	2%	DB	60.9	63.7	72.0	77.8	88.5	95.4	97.6	97.7	92.6	84.8	70.1	63.1		
		MCWB	54.8	54.2	56.7	62.8	64.4	67.5	68.1	69.3	65.6	63.2	59.5	58.0		
	5%	DB	59.0	61.4	68.5	74.4	83.8	91.1	94.1	94.7	89.1	80.8	67.1	61.0		
		MCWB	54.2	54.1	56.4	60.8	63.5	66.5	67.7	68.0	65.2	63.0	59.1	56.3		
	10%	DB	57.3	59.3	64.7	70.4	79.7	86.7	90.6	91.2	85.0	76.9	64.6	59.0		
		MCWB	53.4	53.7	54.7	58.9	61.9	65.7	67.2	67.0	64.9	62.7	58.5	55.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.2	59.4	62.4	66.8	70.3	73.4	75.4	74.5	72.6	68.3	65.6	61.4		
		MCDB	61.2	62.3	72.3	77.5	86.6	94.3	97.1	97.0	91.4	76.2	68.6	63.3		
	2%	WB	57.2	57.9	60.0	64.1	67.2	70.6	72.4	71.9	69.9	66.9	63.3	59.1		
		MCDB	58.9	60.5	67.5	75.6	81.5	88.2	91.4	91.7	83.7	74.9	66.2	61.5		
	5%	WB	55.8	56.3	58.3	61.7	65.0	68.4	70.5	70.5	68.2	65.8	61.1	57.4		
		MCDB	57.7	59.5	64.5	71.4	78.7	84.3	87.9	89.3	81.0	74.0	64.6	59.8		
	10%	WB	54.3	54.6	56.4	59.7	63.2	66.9	68.5	69.1	66.8	64.6	59.7	55.9		
		MCDB	56.5	58.3	62.0	68.2	75.9	82.3	84.9	86.4	78.6	72.4	63.5	58.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	14.7	15.9	17.8	18.6	22.4	24.8	28.0	28.3	23.4	19.2	15.6	15.0		
		MCDBR	16.8	18.7	24.6	25.5	30.7	32.0	33.9	33.0	30.0	25.7	19.0	15.8		
	5% WB	MCWBR	10.9	10.9	12.3	11.9	10.9	9.6	10.5	10.2	9.1	9.0	9.7	9.9		
		MCWBR	12.3	14.7	19.4	23.2	26.3	28.3	30.0	29.2	23.3	18.7	13.2	12.8		
(40) Clear-Sky Solar Irradiance	taub		0.315	0.331	0.363	0.370	0.377	0.381	0.360	0.378	0.375	0.353	0.328	0.317		
		taud	2.496	2.449	2.365	2.358	2.363	2.368	2.400	2.362	2.393	2.481	2.509	2.504		
	Ebn at Noon		276	285	285	288	286	284	289	282	277	273	268	266		
		Edh at Noon	25	30	36	38	39	39	37	38	35	29	25	23		
(44) All-Sky Solar Radiation	RadAvg		760	1059	1420	1781	2141	2417	2502	2220	1714	1189	840	679		
	RadStd		96	127	149	153	179	127	69	71	109	100	97	76		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (15 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page