

MINDELO CESARIA EVORA AP, Cape Verde

WMO: 085830

Lat: 16.834N

Lon: 25.055W

Elev: 58

StdP: 14.67

Time Zone: -1.00 (W01)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	65.5	66.1	50.7	55.0	72.9	52.4	58.5	72.3	39.6	73.7	37.8	73.9	13.2	60	0.721

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	9.3	89.3	75.5	87.9	75.7	86.9	75.3	78.3	84.3	77.8	84.0	77.2	83.7	17.9	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.9	140.3	81.0	75.6	134.1	81.5	75.2	132.3	81.6	41.8	84.4	41.2	84.1	40.6	84.1	80.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 35.3	32.5	30.4	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(5)			WB	56.6	78.7	1.8	1.9	55.3	80.1	54.2	81.2	53.2	82.2	51.9	83.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	77.1	73.1	71.8	72.6	74.4	75.9	77.5	79.5	81.6	82.6	81.8	78.3	75.3
	DBStd	4.04	2.24	2.25	1.46	1.76	1.74	1.48	1.51	1.72	1.33	1.71	2.15	2.17
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	9876	715	611	699	731	804	825	916	980	978	985	849	783
	CDD65	4401	250	191	234	281	339	375	451	515	528	520	399	318
	CDH74	31066	672	409	637	1144	1753	2341	3698	5190	5713	5281	2879	1349
CDH80	6908	55	23	17	76	188	340	794	1480	1784	1537	478	136	
Wind	WSAvg	18.5	20.2	21.5	21.5	20.9	21.2	20.6	15.3	13.4	15.7	17.4	16.8	18.0
Precipitation	PrecAvg	7.9	0.4	0.4	0.2	0.2	0.1	0.1	0.5	1.0	2.1	1.3	0.9	0.8
	PrecMax	16.5	2.5	2.5	1.5	1.0	0.3	0.3	2.6	3.0	6.9	5.9	5.2	5.5
	PrecMin	3.9	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.2	0.1	0.1	0.0	0.0
	PrecStd	3.3	0.6	0.5	0.3	0.2	0.1	0.1	0.6	0.7	1.8	1.1	1.2	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	84.4	83.8	82.2	84.5	85.9	86.1	88.1	89.9	89.9	91.2	87.8	84.6
		MCWB	66.6	64.5	65.6	68.8	67.4	71.8	73.4	75.0	76.8	74.3	73.7	71.7
	2%	DB	80.9	79.2	80.0	82.1	83.5	84.3	86.3	88.0	89.2	88.7	85.9	82.7
		MCWB	67.9	66.4	66.3	69.0	69.8	71.6	73.3	76.3	76.6	75.3	73.8	70.5
	5%	DB	79.0	77.9	78.7	80.5	82.2	82.7	85.0	87.0	87.9	87.6	84.2	81.0
		MCWB	67.0	65.9	65.9	68.8	69.7	70.9	72.8	75.8	76.3	75.6	72.7	69.4
	10%	DB	77.3	76.7	77.2	79.0	80.7	82.1	84.1	86.0	86.8	86.2	82.5	80.0
		MCWB	65.9	65.3	65.7	67.7	68.9	70.7	72.5	74.9	76.1	74.9	71.7	68.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.6	69.4	70.5	71.2	72.5	74.1	76.2	79.1	79.2	79.0	76.3	74.1
		MCDB	78.4	76.8	75.1	79.6	82.1	82.2	84.1	84.8	84.7	84.4	82.3	82.4
	2%	WB	69.4	68.4	68.5	70.2	71.5	72.9	75.2	78.2	78.4	77.5	75.2	72.6
		MCDB	76.6	75.9	74.7	78.6	80.5	80.7	83.0	84.3	84.3	84.7	82.3	80.0
	5%	WB	68.5	67.3	67.7	69.5	70.5	72.1	74.4	77.4	78.0	76.7	74.2	71.5
		MCDB	75.8	75.2	74.6	77.9	79.2	80.7	82.1	83.8	84.0	84.6	81.3	78.5
	10%	WB	67.5	66.3	67.0	68.9	69.8	71.4	73.5	76.7	77.4	76.0	73.4	70.1
		MCDB	75.1	74.6	74.6	77.1	78.3	80.4	81.3	83.3	83.5	83.8	80.4	77.3
Mean Daily Temperature Range	5% DB	MDBR	9.4	9.6	10.4	10.0	10.0	9.6	9.4	9.3	9.3	9.7	9.3	9.4
		MCDBR	11.4	11.0	12.0	11.5	11.5	10.5	10.6	10.0	10.4	11.0	10.7	11.0
		MCWBR	4.9	4.7	4.7	4.5	4.6	4.2	3.8	3.7	3.4	4.2	3.9	4.3
	5% WB	MCDBR	10.7	10.7	11.4	10.9	10.1	10.0	9.9	9.3	9.2	10.2	9.8	10.9
MCWBR		5.0	4.8	4.4	4.4	4.3	4.0	3.9	3.8	3.6	4.2	3.9	4.8	
Clear-Sky Solar Irradiance	taub	0.443	0.446	0.468	0.462	0.544	0.645	0.664	0.619	0.578	0.523	0.448	0.447	
	taud	2.179	2.176	2.126	2.222	1.969	1.774	1.762	1.881	1.969	2.071	2.272	2.235	
	Ebn at Noon	266	272	269	270	246	220	216	228	237	247	263	261	
	Edh at Noon	45	47	51	46	59	71	72	64	59	52	41	42	
All-Sky Solar Radiation	RadAvg	1565	1774	2081	2171	2200	2100	1972	1960	1920	1782	1569	1435	
	RadStd	118	120	97	68	59	58	68	54	94	78	108	123	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page