

EGGEBEK, Germany

WMO: 100340

Lat: 54.625N

Lon: 9.346E

Elev: 66

StdP: 14.66

Time Zone: 1.00 (EUC)

Period: 94-03

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	15.2	19.3	12.3	10.3	18.9	15.7	12.2	20.9	27.7	46.2	25.1	44.7	5.8	110	0.612

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	18.8	82.8	67.2	78.9	65.7	75.1	64.2	68.8	78.7	66.9	76.1	65.2	73.3	9.5	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.2	93.3	73.1	63.6	88.1	70.7	62.0	83.3	68.6	32.9	79.4	31.4	76.2	30.1	73.4	75.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.5	22.4	19.8	DB	7.8	89.1	4.1	3.1	4.8	91.3	2.4	93.1	0.0	94.8	-3.0	97.0	(4)
(5)			WB	7.7	73.2	4.1	1.6	4.8	74.3	2.4	75.2	0.0	76.1	-2.9	77.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.4	34.3	35.2	38.5	45.2	52.3	57.5	62.5	63.3	56.3	48.9	40.1	34.1	(6)	
	DBStd	12.17	7.37	7.84	5.27	6.31	5.28	5.37	5.27	5.69	4.77	5.82	5.91	7.54	(7)	
	HDD50	2359	488	415	359	172	37	1	0	0	5	90	298	494	(8)	
	HDD65	6520	953	835	823	595	394	235	114	103	265	498	746	959	(9)	
	CDD50	1419	0	0	1	27	109	228	387	414	194	57	2	0	(10)	
	CDD65	104	0	0	0	0	1	11	36	52	4	0	0	0	(11)	
	CDH74	1010	0	0	0	4	23	119	376	465	23	0	0	0	(12)	
	CDH80	231	0	0	0	0	4	27	89	110	1	0	0	0	(13)	
(14) Wind	WSAvg	8.8	10.0	11.3	11.0	9.3	8.3	8.4	7.7	7.0	7.6	8.7	8.6	8.6	(14)	
(15) Precipitation	PrecAvg	34.0	3.0	2.2	1.8	1.8	2.1	2.8	3.7	3.7	3.3	3.3	3.0	3.3	(15)	
	PrecMax	42.5	6.1	5.0	4.2	4.6	3.8	5.0	7.4	8.9	7.0	7.0	7.1	7.4	(16)	
	PrecMin	20.8	0.0	0.5	0.2	0.3	0.8	0.0	1.1	1.3	0.7	1.1	0.6	1.2	(17)	
	PrecStd	5.1	1.6	0.9	1.0	0.9	0.9	1.3	1.7	1.7	1.7	1.1	1.7	1.5	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.0	51.5	60.1	72.5	76.9	84.3	87.1	86.7	76.9	65.6	56.0	52.4	(19)	
		MCWB	47.5	47.5	49.2	57.6	60.8	69.9	67.6	67.4	65.7	59.9	54.1	51.1	(20)	
	2%	DB	46.8	48.9	53.0	64.2	70.4	77.4	82.4	83.3	72.4	61.6	53.4	49.9	(21)	
		MCWB	45.1	46.1	46.6	53.1	58.5	65.7	66.9	67.2	62.7	57.7	50.7	48.9	(22)	
	5%	DB	44.8	46.8	49.6	60.1	66.9	72.3	78.2	79.3	67.7	59.3	50.6	47.0	(23)	
		MCWB	43.3	45.0	45.5	51.6	56.3	62.0	64.8	66.4	60.4	56.4	48.5	45.8	(24)	
	10%	DB	43.2	45.0	47.0	55.8	63.5	68.2	74.3	75.3	64.5	57.6	48.6	44.9	(25)	
		MCWB	41.9	43.3	43.9	49.7	55.1	59.8	63.7	64.9	58.9	55.0	46.7	43.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.9	48.6	51.0	59.1	62.4	70.9	70.4	71.6	67.1	61.3	54.5	51.5	(27)	
		MCDB	49.3	49.9	55.2	67.7	72.2	82.0	81.4	82.0	75.2	65.3	55.6	52.3	(28)	
	2%	WB	45.3	46.7	48.3	55.1	60.0	66.6	68.3	68.9	63.7	58.5	51.5	48.9	(29)	
		MCDB	46.5	48.1	52.1	61.7	68.6	76.1	79.5	77.8	68.9	60.3	52.9	49.6	(30)	
	5%	WB	43.4	45.0	46.2	52.5	57.8	63.1	66.2	67.2	61.6	57.0	48.8	46.0	(31)	
		MCDB	44.5	46.4	49.0	58.2	64.9	69.8	75.6	76.1	66.3	59.0	50.3	46.7	(32)	
	10%	WB	42.0	43.5	44.0	50.2	55.7	60.9	64.3	65.7	59.9	55.5	47.0	43.8	(33)	
		MCDB	43.0	45.0	46.4	55.3	62.1	66.8	72.6	73.7	63.5	57.3	48.3	44.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.0	9.8	12.0	16.1	17.6	16.5	17.3	18.8	14.6	12.2	9.8	9.0	(35)	
		MCDBR	8.5	9.6	17.7	22.3	25.0	24.0	25.0	25.5	19.6	12.6	10.5	8.3	(36)	
	5% WB	MCWBR	7.4	7.9	12.6	13.3	14.7	13.9	12.2	12.7	11.6	9.5	9.1	7.9	(37)	
		MCWBR	8.1	8.4	15.3	19.5	21.0	21.4	22.2	21.9	16.5	11.7	10.1	8.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.323	0.342	0.369	0.403	0.395	0.392	0.409	0.407	0.384	0.360	0.337	0.313	(40)	
		taud	2.276	2.299	2.261	2.220	2.299	2.331	2.303	2.320	2.365	2.388	2.330	2.273	(41)	
	Ebn at Noon		192	232	252	259	270	271	264	256	246	224	185	168	(42)	
		Edh at Noon	19	25	33	39	38	37	38	35	30	23	18	15	(43)	
(44) All-Sky Solar Radiation	RadAvg		162	364	774	1294	1646	1710	1607	1303	925	495	202	117	(44)	
	RadStd		21	53	69	144	162	141	187	100	101	57	25	9	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (49 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	-248	N/A	N/A

Nomenclature: See separate page