

EGGEBEK, Germany

WMO: 100340

Lat: 54.625N

Lon: 9.346E

Elev: 20

StdP: 101.08

Time Zone: 1.00 (EUC)

Period: 94-03

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-9.4	-7.1	-11.0	1.5	-7.3	-9.1	1.7	-6.2	12.4	7.9	11.2	7.1	2.6	110	0.612

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.5	28.2	19.5	26.0	18.7	23.9	17.9	20.4	26.0	19.4	24.5	18.4	22.9	4.2	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.4	13.3	22.8	17.5	12.6	21.5	16.7	11.9	20.3	58.6	26.4	55.2	24.5	52.2	23.0	24.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.4	10.0	8.8	DB	-13.5	31.7	2.3	1.7	-15.1	32.9	-16.5	33.9	-17.8	34.9	-19.4	36.1	(4)
(5)			WB	-13.5	22.9	2.3	0.9	-15.1	23.5	-16.5	24.0	-17.8	24.5	-19.4	25.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.6	1.3	1.8	3.6	7.3	11.3	14.2	16.9	17.4	13.5	9.4	4.5	1.1
	DBStd	6.76	4.10	4.36	2.93	3.50	2.93	2.98	2.93	3.16	2.65	3.24	3.28	4.19
	HDD10.0	1311	271	231	199	96	21	1	0	0	3	50	166	274
	HDD18.3	3622	529	464	457	331	219	131	63	57	147	277	414	533
	CDD10.0	788	0	0	1	15	61	127	215	230	108	32	1	0
	CDD18.3	58	0	0	0	0	1	6	20	29	2	0	0	0
	CDH23.3	561	0	0	0	2	13	66	209	258	13	0	0	0
	CDH26.7	128	0	0	0	0	2	15	49	61	1	0	0	0
Wind	WSAvg	4.0	4.5	5.0	4.9	4.1	3.7	3.7	3.4	3.1	3.4	3.9	3.8	3.9
Precipitation	PrecAvg	864	76	57	46	45	54	72	95	94	85	84	75	83
	PrecMax	1080	156	126	106	117	97	128	189	226	177	177	180	187
	PrecMin	529	1	12	6	8	20	0	27	33	17	28	15	31
	PrecStd	130	40	24	26	23	23	34	43	44	42	29	43	39
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.0	10.8	15.6	22.5	25.0	29.1	30.6	30.4	25.0	18.7	13.3	11.3
		MCWB	8.6	8.6	9.5	14.2	16.0	21.1	19.8	19.7	18.7	15.5	12.3	10.6
	2%	DB	8.2	9.4	11.7	17.9	21.3	25.2	28.0	28.5	22.4	16.5	11.9	9.9
		MCWB	7.3	7.8	8.1	11.7	14.7	18.7	19.4	19.6	17.1	14.3	10.4	9.4
	5%	DB	7.1	8.2	9.8	15.6	19.4	22.4	25.7	26.3	19.8	15.2	10.4	8.4
		MCWB	6.3	7.2	7.5	10.9	13.5	16.7	18.2	19.1	15.8	13.6	9.2	7.7
	10%	DB	6.2	7.2	8.3	13.2	17.5	20.1	23.5	24.0	18.1	14.2	9.2	7.2
		MCWB	5.5	6.3	6.6	9.8	12.8	15.5	17.6	18.3	14.9	12.8	8.2	6.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.8	9.2	10.6	15.1	16.9	21.6	21.4	22.0	19.5	16.3	12.5	10.9
		MCDB	9.6	10.0	12.9	19.8	22.3	27.8	27.4	27.8	24.0	18.5	13.1	11.3
	2%	WB	7.4	8.2	9.0	12.8	15.6	19.2	20.2	20.5	17.6	14.7	10.8	9.4
		MCDB	8.1	9.0	11.2	16.5	20.3	24.5	26.4	25.4	20.5	15.7	11.6	9.8
	5%	WB	6.4	7.2	7.9	11.4	14.3	17.3	19.0	19.6	16.4	13.9	9.4	7.8
		MCDB	6.9	8.0	9.5	14.5	18.3	21.0	24.2	24.5	19.1	15.0	10.1	8.2
	10%	WB	5.6	6.4	6.7	10.1	13.2	16.1	17.9	18.7	15.5	13.0	8.3	6.6
		MCDB	6.1	7.2	8.0	12.9	16.7	19.3	22.6	23.2	17.5	14.1	9.1	7.1
Mean Daily Temperature Range	5% DB	MDBR	4.5	5.4	6.7	8.9	9.8	9.1	9.6	10.5	8.1	6.8	5.4	5.0
		MCDBR	4.7	5.3	9.8	12.4	13.9	13.4	13.9	14.2	10.9	7.0	5.8	4.6
		MCWBR	4.1	4.4	7.0	7.4	8.1	7.7	6.8	7.1	6.5	5.3	5.0	4.4
	5% WB	MCDBR	4.5	4.7	8.5	10.8	11.7	11.9	12.4	12.2	9.2	6.5	5.6	4.7
		MCWBR	4.0	4.2	6.5	6.8	7.4	7.4	6.7	6.7	5.7	5.2	5.1	4.5
Clear-Sky Solar Irradiance	taub	0.323	0.342	0.369	0.403	0.395	0.392	0.409	0.407	0.384	0.360	0.337	0.313	
	taud	2.276	2.299	2.261	2.220	2.299	2.331	2.303	2.320	2.365	2.388	2.330	2.273	
	Ebn at Noon	604	732	796	818	850	855	831	808	776	705	584	531	
	Edh at Noon	59	80	104	124	121	118	120	111	94	73	56	48	
All-Sky Solar Radiation	RadAvg	0.51	1.15	2.44	4.08	5.19	5.39	5.07	4.11	2.92	1.56	0.64	0.37	
	RadStd	0.07	0.17	0.22	0.46	0.51	0.45	0.59	0.31	0.32	0.18	0.08	0.03	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (49 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	-138	N/A	N/A

Nomenclature: See separate page