

SCHORTENS JEVER, Germany

WMO: 101220

Lat: 53.534N

Lon: 7.889E

Elev: 24

StdP: 14.68

Time Zone: 1.00 (EUC)

Period: 94-11

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	16.2	19.5	12.1	10.2	18.3	15.7	12.2	21.1	25.6	45.0	23.4	42.5	7.6	100	0.573

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	16.6	83.2	67.3	78.6	65.5	75.0	64.0	68.8	79.9	66.7	76.3	65.0	73.1	8.2	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.6	91.4	72.5	63.0	86.3	70.7	61.5	81.8	69.2	32.9	79.8	31.2	76.6	29.9	73.3	77.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
23.2	19.9	17.2	DB	10.9	90.1	5.3	3.4	7.1	92.5	4.0	94.6	1.0	96.5	-2.8	99.0
			WB	10.8	73.1	5.2	2.7	7.0	75.0	4.0	76.6	1.0	78.1	-2.7	80.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.5	35.7	36.9	40.3	46.8	53.4	58.1	62.8	63.6	57.1	49.5	41.7	35.5	(6)
	DBStd	11.91	7.82	7.55	5.88	6.65	6.09	5.77	5.67	5.84	4.91	6.23	5.98	7.71	(7)
	HDD50	2080	444	369	304	140	33	1	0	0	3	84	252	450	(8)
	HDD65	6140	909	787	766	547	363	224	114	98	242	479	698	913	(9)
	CDD50	1541	0	2	4	43	138	243	396	423	217	70	4	1	(10)
	CDD65	126	0	0	0	0	3	16	46	55	6	0	0	0	(11)
	CDH74	1022	0	0	0	5	43	157	373	398	46	0	0	0	(12)
	CDH80	271	0	0	0	0	8	46	102	111	4	0	0	0	(13)
(14) Wind	WSAvg	7.8	9.1	9.9	9.4	7.6	6.8	7.0	6.7	6.4	6.7	7.9	7.7	8.1	(14)
(15) Precipitation	PrecAvg	32.9	2.6	2.1	1.9	1.6	2.2	2.9	3.6	3.4	3.3	3.0	3.1	3.1	(15)
	PrecMax	45.5	5.6	5.0	3.9	4.4	5.1	6.3	6.5	7.6	9.6	7.9	6.4	8.1	(16)
	PrecMin	21.3	0.2	1.0	0.4	0.2	0.5	0.4	1.5	1.1	0.7	0.7	0.3	1.0	(17)
	PrecStd	5.1	1.4	1.0	1.1	0.9	1.0	1.4	1.5	1.4	2.0	1.5	1.6	1.7	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.8	55.8	61.7	72.3	78.6	87.4	88.2	88.5	79.1	67.2	56.7	54.5	(19)
		MCWB	49.2	50.2	51.3	58.1	62.3	69.5	70.1	68.5	65.1	60.0	53.9	51.7	(20)
	2%	DB	50.2	52.2	55.9	66.6	73.2	78.4	82.6	82.9	73.6	62.8	54.3	51.9	(21)
		MCWB	47.4	48.1	49.2	53.5	60.5	64.8	67.4	67.1	62.8	57.9	51.4	50.0	(22)
	5%	DB	47.8	49.8	52.6	62.4	68.7	72.9	77.7	78.3	68.8	60.4	52.1	48.5	(23)
		MCWB	45.3	46.3	47.6	52.8	57.8	62.4	65.6	66.2	60.2	56.2	49.0	46.6	(24)
	10%	DB	45.1	47.0	50.0	58.2	64.8	68.6	73.8	74.0	65.2	58.4	50.1	46.4	(25)
		MCWB	42.9	44.5	46.4	50.5	56.3	60.0	63.6	64.2	58.3	54.9	47.7	44.7	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.9	51.3	53.1	58.4	65.6	70.0	71.2	71.5	66.4	61.3	54.9	52.1	(27)
		MCDB	52.1	54.5	58.4	68.2	75.8	84.2	83.6	83.2	77.4	65.9	56.2	53.6	(28)
	2%	WB	47.7	48.9	50.4	55.5	62.0	66.2	68.8	68.6	63.8	58.6	51.9	49.9	(29)
		MCDB	49.8	51.5	54.2	64.4	71.0	76.5	80.1	78.7	72.4	61.2	53.9	51.8	(30)
	5%	WB	45.1	46.6	48.5	53.4	59.2	63.5	66.6	66.6	61.2	57.1	49.7	46.8	(31)
		MCDB	47.3	49.3	51.8	60.6	66.5	70.6	76.1	75.6	66.7	59.8	51.6	48.2	(32)
	10%	WB	43.1	44.6	46.4	51.3	56.9	61.3	64.5	65.1	59.3	55.4	47.7	44.6	(33)
		MCDB	44.9	46.8	49.9	57.4	63.3	67.5	72.1	72.9	63.8	57.9	49.6	46.3	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	8.3	10.4	12.5	16.0	16.6	16.5	15.8	16.6	14.8	12.6	9.7	8.4	(35)
		MCDBR	9.7	13.1	17.5	22.6	23.7	23.7	22.9	22.4	20.0	13.2	10.8	9.4	(36)
	5% WB	MCWBR	8.3	9.7	11.6	12.5	12.8	12.8	10.6	10.3	10.7	9.2	8.7	8.8	(37)
		MCWBR	9.1	9.7	15.5	20.1	21.4	21.9	21.4	19.8	17.8	12.7	10.3	9.5	(38)
(40) Clear-Sky Solar Irradiance	taub		0.327	0.346	0.375	0.408	0.403	0.402	0.417	0.411	0.387	0.362	0.341	0.320	(40)
		taud	2.313	2.327	2.266	2.231	2.285	2.314	2.288	2.315	2.369	2.398	2.345	2.305	(41)
	Ebn at Noon		200	236	253	260	268	269	262	257	247	227	192	177	(42)
		Edh at Noon	19	26	33	39	39	38	39	36	30	24	19	16	(43)
(44) All-Sky Solar Radiation	RadAvg		181	390	777	1293	1614	1690	1605	1331	949	527	224	138	(44)
	RadStd		18	57	80	137	150	127	195	103	101	55	22	14	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (49 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	-236	N/A	N/A	

Nomenclature: See separate page