

SCHWERIN, Germany

WMO: 101620

Lat: 53.6425N

Lon: 11.3872E

Elev: 196

StdP: 14.59

Time Zone: 1.00 (EUC)

Period: 82-03

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	9.8	15.3	3.8	6.7	12.5	7.9	8.3	17.3	33.0	42.5	27.9	43.7	3.8	90	0.599

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.7	82.0	65.5	78.8	64.2	75.4	62.8	67.6	77.8	65.8	75.5	64.1	72.8	7.9	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.1	90.2	71.3	62.1	84.1	69.4	60.5	79.2	68.3	32.1	78.0	30.6	75.2	29.4	72.8	73.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.6	22.3	19.4	10.2	88.5	9.9	4.2	3.1	91.5	-2.7	94.0	-8.2	96.3	-15.4	99.4		
(5)			9.4	72.1	9.6	1.3	2.4	73.0	-3.2	73.8	-8.6	74.5	-15.6	75.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.8	32.8	32.7	39.2	45.5	54.5	59.5	63.6	63.0	56.5	49.4	40.2	35.7		
	DBStd	12.89	9.76	8.29	6.59	6.26	6.52	6.15	5.68	5.37	4.67	6.03	5.99	6.65		
	HDD50	2372	532	485	337	165	28	1	0	0	3	84	295	442		
	HDD65	6408	997	905	799	586	333	189	98	106	259	485	744	907		
	CDD50	1571	0	1	3	29	166	286	420	402	198	64	2	0		
	CDD65	129	0	0	0	0	6	23	53	43	4	0	0	0		
	CDH74	995	0	0	0	1	64	187	420	300	23	0	0	0		
	CDH80	197	0	0	0	0	3	42	85	65	2	0	0	0		
	WSAvg	8.8	10.7	9.4	9.5	8.2	7.7	7.7	8.1	7.6	8.5	8.7	9.6	10.1		
	PrecAvg	25.8	2.2	1.9	1.7	1.5	2.0	2.6	2.8	2.8	2.1	2.0	2.1	2.4		
(15) Precipitation	PrecMax	35.8	4.6	4.9	4.5	2.9	3.8	5.0	6.1	6.3	5.9	4.6	4.4	5.6		
	PrecMin	18.7	0.0	0.3	0.3	0.0	0.4	0.4	0.8	0.6	0.6	1.1	0.2	0.6		
	PrecStd	4.6	1.1	0.9	0.9	0.7	0.8	1.3	1.5	1.4	1.3	0.8	1.0	1.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.2	55.7	61.5	70.2	79.5	85.7	86.6	85.3	77.2	69.3	54.9	52.4		
		MCWB	48.0	50.3	51.6	56.4	61.9	65.1	67.6	67.4	64.8	61.4	50.6	48.7		
	2%	DB	48.1	50.4	55.0	65.0	75.5	79.3	82.0	81.3	72.0	64.4	52.4	50.1		
		MCWB	45.5	46.5	48.2	53.0	60.1	63.5	65.6	65.8	61.7	58.0	49.4	47.4		
	5%	DB	46.1	45.9	50.9	60.4	71.1	74.9	79.0	77.1	67.8	60.8	50.4	47.9		
		MCWB	43.6	42.6	45.6	50.6	57.9	61.6	64.7	64.7	59.1	55.4	48.0	45.6		
	10%	DB	44.0	42.9	48.1	56.2	66.8	71.2	75.0	73.2	64.5	57.8	48.4	45.5		
		MCWB	41.6	40.2	44.2	48.4	56.2	59.9	63.1	63.0	57.9	53.4	46.2	43.4		
	0.4%	WB	48.3	51.1	52.3	57.5	63.8	69.3	70.5	70.1	66.5	62.2	52.1	49.7		
		MCDB	49.9	55.0	59.6	67.6	76.8	78.2	81.1	81.6	74.2	67.4	54.1	51.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	45.8	46.4	49.1	54.1	61.1	65.7	68.0	67.2	63.3	59.0	49.8	47.8		
		MCDB	47.7	49.9	53.9	62.8	72.0	75.6	78.4	77.6	69.6	63.4	51.7	49.8		
	5%	WB	44.0	42.9	46.6	51.4	59.1	63.4	65.9	65.4	60.9	56.1	48.2	45.7		
		MCDB	45.8	45.4	50.2	59.2	69.9	72.1	75.9	74.6	66.6	59.5	50.1	47.7		
	10%	WB	41.7	40.2	44.3	49.2	56.8	61.0	63.9	63.8	58.6	54.0	46.4	43.4		
		MCDB	43.9	42.5	47.6	55.5	64.8	69.7	73.3	71.4	63.0	57.1	48.2	45.4		
	5% DB	MDBR	7.9	9.2	11.0	14.0	16.0	14.9	15.7	15.2	12.9	11.1	7.8	7.0		
		MCDBR	8.4	11.6	15.7	20.9	22.8	21.2	22.1	20.9	18.3	14.7	9.8	8.5		
		MCWBR	8.0	9.1	10.7	11.9	11.5	9.8	10.4	9.8	10.3	9.6	8.4	8.2		
		MCWBR	8.3	11.6	14.4	18.7	20.7	18.9	19.8	18.3	16.4	13.4	9.2	8.2		
(35) Mean Daily Temperature Range	5% WB	MCWBR	8.2	9.5	10.8	11.7	11.2	10.1	10.8	9.4	10.9	9.7	8.5	8.2		
	taub		0.317	0.338	0.372	0.408	0.402	0.400	0.419	0.414	0.382	0.358	0.335	0.308		
		taud	2.322	2.320	2.258	2.212	2.278	2.306	2.271	2.298	2.368	2.405	2.374	2.316		
(40) Clear-Sky Solar Irradiance	Ebn at Noon		204	238	254	259	268	270	261	255	249	229	196	182		
		Edh at Noon	19	26	34	40	39	39	39	36	30	23	18	16		
	RadAvg		178	391	771	1277	1607	1696	1593	1318	965	527	223	133		
(44) All-Sky Solar Radiation	RadStd		22	55	75	173	200	128	224	101	107	66	24	8		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (54 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	-263	N/A	N/A

Nomenclature: See separate page