

TETEROW, Germany

WMO: 101770

Lat: 53.767N

Lon: 12.617E

Elev: 50

StdP: 100.73

Time Zone: 1.00 (EUC)

Period: 82-03

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-12.1	-9.1	-14.8	1.0	-11.2	-11.9	1.4	-8.7	16.1	6.4	14.2	6.7	2.0	90	0.666

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.2	28.7	19.2	26.7	18.2	24.7	17.6	20.3	26.4	19.1	24.9	18.1	23.3	4.6	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.1	13.1	22.3	17.0	12.2	20.8	16.1	11.5	20.0	58.3	26.3	54.4	24.9	51.2	23.2	24.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.0	11.4	10.2	-13.2	32.8	6.0	3.3	-17.5	35.2	-21.0	37.2	-24.4	39.0	-28.7	41.5		
(5)			-13.6	22.9	6.6	0.6	-18.4	23.3	-22.2	23.6	-25.9	24.0	-30.7	24.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.7	0.9	0.1	3.6	7.3	12.5	15.3	17.6	17.5	13.4	9.5	4.2	1.8
	DBStd	7.24	5.18	4.62	3.88	3.49	3.41	3.26	3.06	3.03	2.54	3.48	3.52	3.74
	HDD10.0	1354	283	279	199	96	13	1	0	0	2	51	176	256
	HDD18.3	3597	542	512	456	332	184	103	52	54	148	275	426	514
	CDD10.0	872	0	1	1	14	90	159	234	232	106	34	1	0
	CDD18.3	71	0	0	0	0	2	12	28	27	2	0	0	0
	CDH23.3	731	0	0	0	0	43	136	301	236	14	1	0	0
	CDH26.7	182	0	0	0	0	3	37	76	64	2	0	0	0
Wind	WSAvg	4.9	6.2	5.3	5.4	4.7	4.1	3.9	4.0	4.1	4.8	5.1	5.3	5.6
Precipitation	PrecAvg	611	49	39	40	34	53	64	69	63	53	45	48	53
	PrecMax	783	96	88	101	67	101	125	312	156	155	75	113	114
	PrecMin	422	1	8	8	4	12	2	4	24	12	23	7	14
	PrecStd	89	26	17	21	16	24	28	54	29	30	15	23	24
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.9	13.2	15.9	21.3	27.0	30.7	31.3	31.4	25.3	21.1	12.9	11.1
		MCWB	9.5	10.6	10.8	13.9	17.0	18.8	20.7	19.8	18.1	16.9	11.1	9.3
	2%	DB	8.9	10.1	12.6	18.1	24.3	27.0	28.6	28.3	22.3	18.1	11.0	9.9
		MCWB	7.6	8.2	9.2	12.0	16.4	17.6	19.5	18.9	16.4	14.8	9.7	8.8
	5%	DB	7.8	7.5	10.5	15.6	22.0	24.5	26.7	26.0	19.8	16.1	9.9	8.6
		MCWB	6.7	5.8	7.7	10.7	15.1	17.2	18.5	18.0	15.3	13.2	8.7	7.5
	10%	DB	6.8	5.9	8.8	13.4	19.5	22.4	24.5	23.5	18.0	14.3	8.7	7.2
		MCWB	5.6	4.5	6.8	9.4	13.8	16.0	17.6	17.3	14.4	12.0	7.6	6.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.5	11.0	11.5	14.6	18.6	20.8	21.9	21.7	19.0	17.2	11.4	9.9
		MCDB	10.6	13.0	14.9	19.9	24.1	27.1	27.8	28.7	23.9	19.9	12.3	10.6
	2%	WB	7.9	8.1	9.7	12.5	17.0	19.0	20.5	20.0	17.4	15.2	9.9	8.9
		MCDB	8.6	9.6	12.2	17.0	22.9	25.0	27.4	25.4	20.9	17.5	10.9	9.7
	5%	WB	6.9	6.1	8.2	11.1	15.6	17.7	19.1	18.9	16.1	13.7	8.9	7.6
		MCDB	7.8	7.3	10.0	15.1	21.0	23.3	25.3	24.3	18.5	15.5	9.8	8.5
	10%	WB	5.7	4.6	6.9	9.8	14.3	16.6	18.0	17.8	14.8	12.3	7.8	6.3
		MCDB	6.7	5.8	8.6	13.0	18.5	21.4	22.9	22.9	17.3	13.9	8.6	7.2
Mean Daily Temperature Range	5% DB	MDBR	4.2	5.1	6.3	8.4	10.2	9.5	10.2	9.6	7.7	6.7	4.5	4.0
		MCDBR	4.6	6.3	8.8	12.1	14.7	14.3	14.6	13.7	11.0	9.2	5.5	4.9
		MCWBR	4.3	5.3	6.2	7.2	8.1	6.8	6.7	6.3	6.2	6.1	4.9	4.6
	5% WB	MCDBR	4.5	6.3	8.3	11.3	13.1	12.5	13.3	12.1	9.1	8.0	5.3	4.7
		MCWBR	4.5	5.6	6.2	7.1	8.0	6.5	6.8	6.0	6.2	5.7	4.9	4.6
Clear-Sky Solar Irradiance	taub	0.314	0.337	0.371	0.396	0.392	0.390	0.409	0.405	0.373	0.359	0.336	0.307	
	taud	2.316	2.312	2.255	2.258	2.305	2.330	2.298	2.320	2.393	2.392	2.368	2.310	
	Ebn at Noon	642	750	800	831	855	859	833	813	795	717	612	571	
	Edh at Noon	59	81	106	120	121	119	121	112	92	75	57	49	
All-Sky Solar Radiation	RadAvg	0.57	1.22	2.43	4.09	5.15	5.45	5.07	4.23	3.08	1.64	0.70	0.39	
	RadStd	0.07	0.18	0.26	0.55	0.60	0.42	0.67	0.33	0.31	0.22	0.08	0.04	

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (46 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	-152	N/A	N/A

Nomenclature: See separate page