

UECKERMUENDE, Germany

WMO: 101930

Lat: 53.7444N

Lon: 14.0697E

Elev: 2

StdP: 101.30

Time Zone: 1.00 (EUC)

Period: 82-03

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-14.4	-10.6	-18.4	0.7	-13.8	-14.4	1.1	-10.1	12.4	8.3	11.3	6.4	1.6	80	0.584

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.5	27.4	18.9	25.3	18.3	23.4	17.4	20.2	25.1	19.2	23.8	18.2	22.4	3.9	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.5	13.3	22.6	17.4	12.4	21.6	16.3	11.6	20.4	57.9	24.9	54.5	23.9	51.2	22.6	24.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.5	9.3	8.3	-14.2	32.0	6.6	2.0	-19.0	33.5	-22.8	34.7	-26.5	35.8	-31.3	37.3
			-14.8	22.3	6.5	1.2	-19.5	23.2	-23.2	23.9	-26.9	24.6	-31.5	25.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.6	0.2	0.0	3.9	7.4	12.2	15.3	17.5	17.1	13.6	9.7	4.3	1.7
	DBStd	7.31	5.95	5.21	4.10	3.54	3.60	3.07	2.77	2.85	2.56	3.52	3.29	3.78
	HDD10.0	1367	303	281	192	96	17	1	0	0	2	48	171	258
	HDD18.3	3606	561	513	448	329	193	101	49	59	146	269	421	517
	CDD10.0	863	0	1	1	17	86	160	232	221	108	37	1	0
	CDD18.3	61	0	0	0	1	3	10	23	22	2	0	0	0
	CDH23.3	419	0	0	0	2	32	75	159	133	17	1	0	0
	CDH26.7	91	0	0	0	0	4	16	36	32	3	0	0	0
(14) Wind	WSAvg	3.8	4.8	4.1	4.2	3.8	3.4	3.3	3.2	3.0	3.6	3.8	4.2	4.5
(15) Precipitation	PrecAvg	564	40	33	37	31	51	61	71	63	51	42	43	42
	PrecMax	721	75	70	78	71	95	106	244	152	107	91	92	81
	PrecMin	433	1	5	10	4	6	25	11	24	14	17	1	8
	PrecStd	81	21	14	17	15	23	27	46	26	24	19	19	18
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.4	14.4	16.4	22.4	26.7	29.0	30.1	29.9	25.5	20.6	13.1	11.7
		MCWB	9.4	10.5	11.0	13.7	17.4	18.7	19.6	19.5	18.1	16.2	10.8	9.2
	2%	DB	9.5	10.7	12.7	17.6	23.3	25.6	27.2	26.8	22.4	18.2	11.3	10.4
		MCWB	7.6	8.2	8.8	11.5	15.5	18.5	19.2	18.9	16.8	14.2	9.7	8.6
	5%	DB	8.2	8.0	10.7	15.2	20.6	23.2	25.0	24.2	19.8	16.2	10.1	9.0
		MCWB	6.6	5.9	7.7	10.5	15.1	17.2	18.6	17.9	15.6	12.9	8.5	7.6
	10%	DB	6.9	6.1	9.2	13.0	18.3	21.0	23.1	22.4	18.1	14.6	8.9	7.2
		MCWB	5.4	4.3	6.6	9.3	13.8	16.0	17.6	17.4	14.6	11.8	7.5	6.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.4	10.9	11.3	14.2	18.0	20.9	21.9	21.2	19.2	16.7	11.4	9.8
		MCDB	11.0	13.4	15.5	20.2	24.6	25.4	26.8	27.0	24.2	19.9	12.4	11.3
	2%	WB	7.9	8.0	9.5	12.5	16.7	19.1	20.4	19.9	17.6	14.7	9.8	8.7
		MCDB	9.2	10.4	12.0	16.5	22.1	24.2	25.2	24.7	21.3	17.7	11.2	10.2
	5%	WB	6.6	6.0	8.0	11.0	15.4	17.6	19.3	19.0	16.3	13.3	8.7	7.6
		MCDB	8.0	7.7	10.6	14.7	19.9	22.1	23.8	23.4	19.1	15.7	10.0	8.9
	10%	WB	5.4	4.5	6.7	9.8	14.2	16.5	18.2	17.9	15.0	12.1	7.6	6.0
		MCDB	6.8	6.1	8.9	12.8	17.8	20.5	22.3	21.9	17.8	14.2	8.7	7.1
(35) Mean Daily Temperature Range	5% DB	MDBR	4.8	5.5	6.3	7.6	8.2	7.8	8.5	8.5	7.7	6.8	4.6	4.1
		MCDBR	4.8	6.9	8.9	11.1	11.8	11.8	12.0	11.8	10.8	8.8	5.5	5.3
	5% WB	MCWBR	4.4	5.2	6.0	6.6	6.8	6.8	6.5	6.6	6.6	5.9	5.0	4.6
		MCDWR	4.8	6.9	8.7	10.4	10.7	10.2	10.7	10.2	9.6	7.7	5.2	4.9
(40) Clear-Sky Solar Irradiance	taub		0.317	0.342	0.373	0.409	0.407	0.403	0.424	0.420	0.385	0.364	0.342	0.312
		taud	2.325	2.317	2.264	2.228	2.285	2.324	2.280	2.299	2.374	2.391	2.367	2.320
	Ebn at Noon		641	746	798	817	841	848	819	798	782	712	605	567
		Edh at Noon	59	81	105	124	123	120	123	114	94	75	57	49
(44) All-Sky Solar Radiation	RadAvg		0.56	1.21	2.42	4.14	5.20	5.50	5.09	4.28	3.11	1.63	0.68	0.39
	RadStd		0.06	0.18	0.27	0.55	0.61	0.43	0.66	0.36	0.33	0.23	0.09	0.04

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (42 neighbors)		+0.38	N/A	N/A	N/A	N/A	N/A	N/A	-146	N/A	N/A	

Nomenclature: See separate page