

DIEPHOLZ, Germany

WMO: 103210

Lat: 52.5881N

Lon: 8.3425E

Elev: 141

StdP: 14.62

Time Zone: 1.00 (EUC)

Period: 94-13

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.4	19.5	10.5	9.5	18.0	14.8	11.7	21.2	29.5	46.3	26.5	45.4	7.8	80	0.557

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.5	85.4	67.1	81.4	66.1	77.7	64.4	69.2	80.7	67.5	78.0	65.9	75.1	7.9	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.5	94.7	72.9	63.8	89.2	71.0	62.4	84.6	69.6	33.3	80.8	32.0	78.2	30.7	75.2	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.2	20.3	17.8	8.4	91.8	8.0	3.1	2.7	94.0	-2.0	95.8	-6.4	97.6	-12.2	99.8
			8.0	72.7	8.0	1.7	2.2	73.9	-2.5	74.9	-7.0	75.8	-12.8	77.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	49.4	35.1	36.9	41.1	48.6	55.4	60.3	64.6	64.2	57.5	49.9	42.3	35.8
	DBStd	12.51	8.59	7.81	6.59	6.74	6.06	5.96	5.84	5.44	5.11	6.48	6.38	8.37
	HDD50	2008	462	370	283	107	18	0	0	0	3	84	239	442
	HDD65	5868	926	788	742	493	303	167	81	83	231	469	680	905
	CDD50	1779	1	2	6	64	186	311	452	439	229	80	8	1
	CDD65	166	0	0	0	0	6	27	68	57	8	0	0	0
	CDH74	1699	0	0	0	11	77	271	704	548	86	2	0	0
	CDH80	481	0	0	0	0	9	62	228	171	11	0	0	0
Wind	WSAvg	7.9	9.3	9.4	8.9	7.5	7.1	7.1	6.9	6.6	6.9	7.9	8.0	8.7
Precipitation	PrecAvg	29.0	2.6	2.0	1.9	1.7	2.2	2.6	2.9	2.9	2.5	2.4	2.4	2.7
	PrecMax	40.0	4.8	4.6	4.9	4.2	4.5	5.8	6.6	6.2	5.8	8.6	4.9	6.3
	PrecMin	22.9	0.3	0.7	0.3	0.0	0.8	0.8	1.3	0.8	0.4	0.4	0.1	0.6
	PrecStd	4.7	1.3	1.1	1.1	0.9	1.0	1.1	1.3	1.3	1.4	1.5	1.3	1.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.8	56.3	63.4	75.4	80.8	86.5	91.2	90.3	81.8	70.1	59.4	55.3
		MCWB	51.1	50.6	52.6	58.1	64.5	68.1	68.3	68.3	66.4	62.1	54.8	52.7
	2%	DB	51.8	52.6	58.7	69.9	75.6	80.9	86.2	84.6	76.4	65.3	56.3	52.0
		MCWB	48.7	49.0	50.4	56.7	60.8	66.2	68.2	66.3	64.7	59.2	53.5	49.7
	5%	DB	48.9	50.2	54.7	65.5	71.7	76.8	81.7	80.3	71.2	62.2	53.8	49.4
		MCWB	46.7	47.3	49.0	54.0	59.0	63.9	66.4	65.6	61.9	57.6	51.0	47.2
	10%	DB	46.5	47.8	51.6	61.2	67.9	72.5	77.3	75.6	67.2	59.5	51.5	47.0
		MCWB	44.4	45.0	47.1	52.3	57.2	61.9	64.6	64.1	59.9	55.9	48.9	45.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.1	52.0	55.0	60.4	66.5	70.3	71.9	71.0	68.1	62.7	55.9	53.0
		MCDB	53.9	54.8	60.6	70.3	77.4	82.2	85.2	82.9	77.8	68.3	57.8	55.0
	2%	WB	49.5	49.8	52.1	57.6	63.2	67.8	69.4	68.7	65.2	60.3	53.9	50.0
		MCDB	51.5	52.1	56.5	67.2	72.6	78.4	81.5	79.3	74.0	64.2	56.3	51.8
	5%	WB	46.7	47.5	49.7	55.6	60.5	65.5	67.6	66.8	63.0	58.3	51.3	47.4
		MCDB	48.6	49.8	54.1	63.4	68.5	74.2	78.5	76.2	69.8	61.3	53.4	49.1
	10%	WB	44.5	45.2	47.4	53.2	58.2	63.2	66.0	65.1	61.0	56.3	49.2	45.0
		MCDB	46.4	47.5	51.1	60.2	65.5	70.2	75.6	73.3	66.0	59.2	51.1	46.8
Mean Daily Temperature Range	5% DB	MDBR	8.4	9.5	13.1	17.0	17.3	17.3	17.5	17.6	16.3	13.9	9.7	8.1
		MCDBR	9.7	11.2	19.4	25.0	24.4	24.7	26.3	25.9	23.0	16.8	11.7	9.6
		MCWBR	8.5	8.8	12.6	13.3	12.4	12.0	11.0	11.2	12.6	11.5	9.5	8.6
	5% WB	MCDBR	9.3	10.0	16.7	21.1	20.7	21.9	23.2	21.3	20.5	15.5	10.7	9.6
		MCWBR	8.4	8.4	11.7	12.1	11.9	11.8	10.5	10.3	11.9	11.3	9.3	8.8
Clear-Sky Solar Irradiance	taub	0.324	0.344	0.376	0.410	0.410	0.409	0.423	0.415	0.388	0.359	0.339	0.317	
	taud	2.347	2.337	2.263	2.213	2.248	2.271	2.246	2.284	2.351	2.407	2.370	2.335	
	Ebn at Noon	209	240	255	260	267	268	261	256	249	232	200	188	
	Edh at Noon	19	26	34	40	41	40	41	37	31	24	19	16	
All-Sky Solar Radiation	RadAvg	200	418	760	1253	1536	1635	1635	1565	1312	955	547	246	157
	RadStd	20	62	88	147	161	124	205	99	115	53	27	15	15

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (53 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page