

POTSDAM, Germany

WMO: 103790

Lat: 52.3814N

Lon: 13.0622E

Elev: 327

StdP: 14.52

Time Zone: 1.00 (EUC)

Period: 82-03

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	9.2	14.0	4.0	6.8	11.4	8.7	8.7	16.5	29.4	44.2	26.2	40.9	8.3	80	0.611

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.0	85.5	66.0	81.8	64.9	78.7	63.8	68.5	80.6	66.8	78.2	65.2	75.4	7.9	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.8	92.8	71.3	62.8	86.5	70.2	61.0	81.2	69.5	32.9	79.6	31.5	78.9	30.2	75.1	80.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.0	21.0	18.6	7.6	92.8	9.1	4.3	1.0	95.9	-4.3	98.4	-9.4	100.8	-16.1	104.0
			6.9	73.4	8.9	2.8	0.5	75.4	-4.8	77.0	-9.8	78.5	-16.3	80.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	48.6	32.5	32.3	40.2	47.1	56.5	61.4	65.6	65.0	57.8	49.5	39.7	34.9	(6)
	DBStd	13.90	9.90	8.93	6.85	6.76	6.84	6.37	5.93	5.91	4.99	6.83	6.35	7.23	(7)
	HDD50	2378	544	497	309	134	20	1	0	0	2	91	312	468	(8)
	HDD65	6186	1009	915	769	538	273	145	67	75	223	480	760	932	(9)
	CDD50	1882	0	2	5	47	222	343	482	464	236	77	3	1	(10)
	CDD65	214	0	0	0	0	9	38	84	74	8	1	0	0	(11)
	CDH74	1973	0	0	0	8	124	383	792	602	60	4	0	0	(12)
	CDH80	520	0	0	0	0	9	97	233	177	4	0	0	0	(13)
(14) Wind	WSAvg	9.8	11.3	10.2	10.5	9.3	8.6	8.7	9.0	8.6	9.8	10.0	10.4	10.9	(14)
(15) Precipitation	PrecAvg	22.9	1.8	1.4	1.5	1.5	2.2	2.6	2.6	2.4	1.8	1.6	1.8	2.0	(15)
	PrecMax	31.5	4.3	3.7	4.6	4.0	6.0	6.6	7.6	7.2	4.9	5.4	3.5	4.9	(16)
	PrecMin	13.6	0.0	0.1	0.3	0.0	0.3	0.3	0.2	0.4	0.2	0.2	0.1	0.4	(17)
	PrecStd	4.3	0.8	0.8	0.9	0.9	1.3	1.4	1.5	1.3	1.1	1.1	0.8	0.9	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.6	57.8	63.6	74.5	80.7	88.1	89.5	90.8	79.9	72.3	56.9	53.1	(19)
		MCWB	48.0	50.3	51.0	56.5	62.3	67.2	68.7	69.1	64.7	62.1	51.3	49.4	(20)
	2%	DB	48.2	51.3	57.4	67.9	77.7	82.6	85.8	84.5	75.1	66.4	53.5	50.5	(21)
		MCWB	45.2	46.6	48.3	54.0	60.4	64.4	66.1	66.4	62.8	58.5	50.2	47.7	(22)
	5%	DB	46.2	46.6	53.3	63.5	74.1	78.4	82.3	80.6	70.6	62.3	50.9	48.3	(23)
		MCWB	43.3	43.3	46.4	51.4	58.7	62.9	65.2	65.3	60.8	56.0	47.9	46.0	(24)
	10%	DB	44.1	43.2	50.2	59.2	70.2	74.2	78.5	76.4	66.8	59.1	48.5	45.6	(25)
		MCWB	41.3	39.8	44.8	49.5	56.9	61.1	64.5	63.6	58.7	53.4	45.9	43.5	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.7	51.1	52.9	57.6	65.3	69.7	71.7	70.8	66.4	62.9	52.6	50.0	(27)
		MCDB	51.5	56.8	59.9	71.4	76.1	79.6	83.2	86.3	77.1	70.1	55.1	52.0	(28)
	2%	WB	45.9	46.8	49.7	54.6	62.3	66.5	68.9	68.3	64.1	59.4	50.4	48.4	(29)
		MCDB	48.1	50.4	55.8	66.2	74.4	78.3	81.1	80.2	72.6	64.8	53.1	50.3	(30)
	5%	WB	43.5	43.6	47.4	52.4	59.8	64.3	66.9	66.7	62.0	56.6	48.3	46.0	(31)
		MCDB	45.8	46.7	52.0	61.8	70.8	74.2	79.0	77.2	68.2	61.2	50.5	48.0	(32)
	10%	WB	41.4	40.2	45.2	50.2	57.8	62.1	64.9	65.0	59.9	54.4	46.2	43.4	(33)
		MCDB	43.8	42.8	49.9	58.1	68.2	72.1	75.5	74.2	65.8	58.2	48.2	45.5	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	8.7	11.0	13.4	16.6	18.4	17.1	18.0	17.6	15.2	13.4	9.3	7.7	(35)
		MCDBR	9.4	14.7	18.8	23.6	24.5	24.7	24.8	24.5	21.5	17.9	11.5	9.6	(36)
		MCWBR	8.0	10.6	11.7	12.3	11.7	11.0	10.9	11.2	11.5	10.8	9.2	8.4	(37)
	5% WB	MCDBR	9.5	14.4	17.5	21.3	22.1	21.6	22.2	21.1	19.2	16.4	11.4	9.4	(38)
		MCWBR	8.3	10.9	11.5	11.4	11.4	10.5	11.1	10.7	11.2	10.6	9.5	8.6	(39)
(40) Clear-Sky Solar Irradiance	taub		0.325	0.350	0.390	0.416	0.414	0.410	0.431	0.424	0.387	0.372	0.347	0.319	(40)
	taud		2.319	2.294	2.200	2.202	2.252	2.285	2.238	2.270	2.353	2.354	2.356	2.329	(41)
	Ebn at Noon		208	238	249	259	266	268	259	254	250	226	198	189	(42)
	Edh at Noon		20	27	36	41	41	40	41	38	31	25	19	17	(43)
(44) All-Sky Solar Radiation	RadAvg		203	423	748	1249	1544	1643	1541	1326	966	538	248	151	(44)
	RadStd		23	73	84	161	184	130	203	107	111	64	32	16	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (42 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page