

POTSDAM, Germany

WMO: 103790

Lat: 52.3814N

Lon: 13.0622E

Elev: 100

StdP: 100.13

Time Zone: 1.00 (EUC)

Period: 82-03

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-12.6	-10.0	-15.6	1.0	-11.4	-13.0	1.2	-8.6	13.1	6.8	11.7	5.0	3.7	80	0.611

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.0	29.7	18.9	27.7	18.3	25.9	17.7	20.3	27.0	19.4	25.6	18.4	24.1	3.5	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.2	13.3	21.8	17.1	12.4	21.2	16.1	11.6	20.8	58.6	26.5	55.4	26.0	52.4	23.9	26.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.7	9.4	8.3	DB	-13.6	33.8	5.1	2.4	-17.2	35.5	-20.2	36.9	-23.0	38.2	-26.7	40.0	(4)
(5)			WB	-13.9	23.0	5.0	1.5	-17.5	24.1	-20.4	25.0	-23.2	25.8	-26.8	27.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.2	0.3	0.2	4.6	8.4	13.6	16.3	18.6	18.3	14.3	9.7	4.3	1.6		
	DBStd	7.72	5.50	4.96	3.81	3.75	3.80	3.54	3.30	3.28	2.77	3.80	3.53	4.01		
	HDD10.0	1321	302	276	172	74	11	1	0	0	1	51	173	260		
	HDD18.3	3437	561	508	427	299	152	81	37	42	124	267	422	518		
	CDD10.0	1046	0	1	3	26	123	191	268	258	131	43	2	1		
	CDD18.3	119	0	0	0	0	5	21	47	41	4	1	0	0		
	CDH23.3	1096	0	0	0	4	69	213	440	334	33	2	0	0		
	CDH26.7	289	0	0	0	0	5	54	129	98	2	0	0	0		
(14) Wind	WSAvg	4.4	5.1	4.6	4.7	4.2	3.9	3.9	4.0	3.8	4.4	4.5	4.7	4.9		
(15) Precipitation	PrecAvg	581	45	36	39	37	56	65	65	62	45	40	46	51		
	PrecMax	799	109	94	117	101	153	167	193	183	124	138	88	124		
	PrecMin	346	0	2	8	0	7	7	5	10	4	5	2	9		
	PrecStd	110	21	21	22	22	32	35	39	34	27	28	20	23		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.5	14.3	17.6	23.6	27.1	31.2	32.0	32.7	26.6	22.4	13.8	11.7		
		MCWB	8.9	10.2	10.5	13.6	16.8	19.5	20.4	20.6	18.2	16.7	10.7	9.7		
	2%	DB	9.0	10.7	14.1	19.9	25.4	28.1	29.9	29.1	24.0	19.1	12.0	10.3		
		MCWB	7.3	8.1	9.0	12.2	15.8	18.0	18.9	19.1	17.1	14.7	10.1	8.7		
	5%	DB	7.9	8.1	11.9	17.5	23.4	25.8	28.0	27.0	21.5	16.8	10.5	9.1		
		MCWB	6.3	6.3	8.0	10.8	14.8	17.2	18.5	18.5	16.0	13.4	8.8	7.8		
	10%	DB	6.7	6.2	10.1	15.1	21.2	23.5	25.9	24.7	19.3	15.0	9.2	7.6		
		MCWB	5.2	4.3	7.1	9.7	13.8	16.2	18.1	17.5	14.9	11.9	7.7	6.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.3	10.6	11.6	14.2	18.5	21.0	22.1	21.5	19.1	17.2	11.5	10.0		
		MCDB	10.8	13.8	15.5	21.9	24.5	26.4	28.4	30.1	25.0	21.2	12.8	11.1		
	2%	WB	7.7	8.2	9.8	12.5	16.8	19.2	20.5	20.1	17.8	15.2	10.2	9.1		
		MCDB	8.9	10.2	13.2	19.0	23.5	25.7	27.3	26.8	22.5	18.2	11.7	10.2		
	5%	WB	6.4	6.4	8.6	11.3	15.4	17.9	19.4	19.3	16.7	13.7	9.0	7.8		
		MCDB	7.7	8.2	11.1	16.6	21.6	23.4	26.1	25.1	20.1	16.2	10.3	8.9		
	10%	WB	5.2	4.6	7.4	10.1	14.3	16.7	18.3	18.3	15.5	12.4	7.9	6.3		
		MCDB	6.6	6.0	9.9	14.5	20.1	22.3	24.1	23.5	18.8	14.6	9.0	7.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.8	6.1	7.5	9.2	10.2	9.5	10.0	9.8	8.5	7.5	5.2	4.3		
		MCDBR	5.2	8.2	10.4	13.1	13.6	13.7	13.8	13.6	11.9	9.9	6.4	5.3		
	5% WB	MCWBR	4.4	5.9	6.5	6.8	6.5	6.1	6.1	6.2	6.4	6.0	5.1	4.7		
		MCWBR	5.3	8.0	9.7	11.8	12.3	12.0	12.4	11.7	10.7	9.1	6.3	5.2		
(40) Clear-Sky Solar Irradiance	taub		0.325	0.350	0.390	0.416	0.414	0.410	0.431	0.424	0.387	0.372	0.347	0.319		
		taud	2.319	2.294	2.200	2.202	2.252	2.285	2.238	2.270	2.353	2.354	2.356	2.329		
	Ebn at Noon		657	750	786	816	838	844	816	800	788	714	624	595		
		Edh at Noon	63	86	114	128	128	125	129	119	98	80	61	53		
(44) All-Sky Solar Radiation	RadAvg		0.64	1.33	2.36	3.94	4.87	5.18	4.86	4.18	3.05	1.70	0.78	0.48		
	RadStd		0.07	0.23	0.27	0.51	0.58	0.41	0.64	0.34	0.35	0.20	0.10	0.05		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (42 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page