

OSCHATZ, Germany

WMO: 104800

Lat: 51.2958N

Lon: 13.0928E

Elev: 493

StdP: 14.44

Time Zone: 1.00 (EUC)

Period: 83-03

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	5.1	12.1	1.5	6.1	6.4	7.5	8.2	12.6	31.4	39.8	28.6	42.7	3.3	70	0.578

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.5	85.9	67.1	82.2	65.4	78.9	64.1	69.0	81.7	67.1	78.4	65.4	75.8	7.0	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.6	92.9	73.3	63.0	87.6	71.4	61.3	82.4	69.8	33.4	81.9	31.8	77.9	30.5	75.9	75.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.4	22.3	19.6	DB	4.8	93.3	12.6	3.9	-4.3	96.1	-11.7	98.3	-18.7	100.5	-27.9	103.3	(4)
(5)			WB	4.4	73.0	12.6	1.8	-4.6	74.3	-12.0	75.3	-19.1	76.3	-28.2	77.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	48.4	32.5	31.9	40.3	46.7	55.4	60.8	64.9	64.7	57.4	49.8	39.9	35.5	
	DBStd	13.85	10.50	10.57	7.48	6.56	6.31	6.08	5.60	6.03	5.03	7.24	6.87	7.85	
	HDD50	2382	544	508	307	139	24	1	0	0	3	95	308	453	
	HDD65	6234	1009	926	765	549	302	155	72	81	233	473	754	915	
	CDD50	1807	1	2	7	40	191	325	463	457	226	88	4	3	
	CDD65	183	0	0	0	0	4	29	70	73	6	1	0	0	
	CDH74	2038	0	0	0	3	102	350	811	702	60	10	0	0	
	CDH80	535	0	0	0	0	4	69	247	210	4	1	0	0	
Wind	WSAvg	8.3	10.6	9.6	9.4	7.7	6.7	7.1	6.8	6.4	7.7	7.9	9.2	10.0	
Precipitation	PrecAvg	23.4	1.7	1.3	1.7	1.3	2.0	2.3	3.1	2.6	2.0	1.6	1.9	1.8	
	PrecMax	31.8	3.2	2.3	4.3	3.9	4.1	5.7	7.2	6.7	5.3	3.1	4.3	3.5	
	PrecMin	14.6	0.1	0.3	0.4	0.1	0.3	0.3	0.7	0.6	0.4	0.4	0.0	0.8	
	PrecStd	3.9	0.8	0.6	1.1	0.8	1.1	1.3	1.5	1.5	1.0	0.7	1.0	0.7	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.0	59.2	64.3	72.7	80.1	86.1	89.9	92.9	80.1	74.5	59.2	55.3	
		MCWB	47.0	50.8	53.1	56.8	63.6	66.4	68.2	69.4	65.4	61.7	51.2	48.1	
	2%	DB	48.8	53.6	58.0	67.3	77.0	81.8	86.2	86.0	75.2	68.4	55.2	52.8	
		MCWB	44.6	47.4	49.9	54.8	60.6	64.0	66.8	68.0	63.0	58.8	49.9	46.8	
	5%	DB	46.5	48.0	53.9	63.3	73.4	78.1	82.5	81.7	71.2	64.1	52.0	49.5	
		MCWB	42.9	43.8	47.2	52.8	59.4	63.0	65.3	66.0	61.6	57.0	47.9	45.3	
	10%	DB	44.0	44.2	50.8	58.8	69.5	74.4	78.6	77.7	67.2	60.7	49.5	46.4	
		MCWB	40.7	40.5	45.5	50.4	57.6	61.3	64.2	64.2	59.4	54.6	46.2	43.4	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.6	50.9	54.2	57.9	65.7	69.3	71.9	71.2	67.3	63.6	52.6	49.7
			MCDB	51.0	57.9	62.7	69.7	76.3	81.1	86.5	89.1	76.4	73.7	57.2	54.2
2%		WB	45.5	47.6	50.6	55.6	62.8	66.5	69.2	69.0	64.3	59.8	50.3	47.0	
		MCDB	48.8	52.9	57.4	66.2	73.4	77.4	81.1	83.1	71.4	66.4	54.2	51.7	
5%		WB	42.9	43.9	47.9	53.2	60.4	64.5	67.0	67.0	62.2	57.5	48.2	45.4	
		MCDB	46.0	47.9	52.7	62.0	70.5	74.8	78.2	78.8	69.4	62.9	51.3	49.4	
10%		WB	40.9	40.7	45.9	50.9	58.3	62.4	65.0	65.4	60.3	55.3	46.2	43.4	
		MCDB	44.1	44.1	50.6	58.0	68.2	71.7	75.7	75.4	66.5	60.2	49.5	46.6	
Mean Daily Temperature Range	5% DB	MDBR	9.2	11.4	12.8	16.1	19.4	18.0	19.5	19.1	16.1	15.5	10.5	8.1	
		MCDBR	10.2	15.1	18.4	24.4	28.2	26.3	28.6	27.0	23.3	20.7	14.6	9.5	
		MCWBR	8.1	10.5	12.2	14.0	15.0	12.1	13.1	11.8	13.2	12.7	10.8	7.1	
	5% WB	MCDBR	10.1	14.6	17.5	22.8	24.8	23.1	25.0	23.2	21.0	19.5	13.5	8.9	
		MCWBR	8.3	10.4	12.0	13.5	14.2	11.3	12.3	10.8	12.4	12.1	10.4	7.2	
Clear-Sky Solar Irradiance	taub	0.312	0.336	0.379	0.414	0.417	0.413	0.430	0.424	0.386	0.362	0.336	0.307		
	taud	2.369	2.340	2.244	2.195	2.227	2.267	2.226	2.262	2.262	2.345	2.386	2.402	2.378	
	Ebn at Noon	223	248	257	261	266	268	260	255	252	235	211	205		
	Edh at Noon	20	27	35	41	42	41	42	38	32	25	19	17		
All-Sky Solar Radiation	RadAvg	237	461	776	1265	1544	1652	1564	1355	975	568	272	182		
	RadStd	33	77	101	163	186	137	193	121	125	67	38	20		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (53 neighbors)		N/A	N/A	N/A	N/A	+0.59	+0.68	N/A	N/A	N/A	+23

Nomenclature: See separate page