

OSCHATZ, Germany

WMO: 104800

Lat: 51.2958N

Lon: 13.0928E

Elev: 150

StdP: 99.53

Time Zone: 1.00 (EUC)

Period: 83-03

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-15.0	-11.1	-16.9	0.9	-14.2	-13.6	1.2	-10.8	14.0	4.3	12.8	5.9	1.5	70	0.578

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.8	30.0	19.5	27.9	18.5	26.0	17.9	20.6	27.6	19.5	25.8	18.6	24.3	3.1	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.1	13.3	23.0	17.2	12.5	21.9	16.3	11.8	21.0	59.8	27.7	56.1	25.5	53.1	24.4	24.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.4	10.0	8.7	DB	-15.1	34.1	7.0	2.1	-20.1	35.6	-24.3	36.9	-28.2	38.1	-33.3	39.6	(4)
(5)			WB	-15.3	22.8	7.0	1.0	-20.4	23.5	-24.4	24.1	-28.4	24.6	-33.4	25.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.1	0.3	0.0	4.6	8.2	13.0	16.0	18.3	18.2	14.1	9.9	4.4	1.9	(6)
(7)		DBStd	7.69	5.83	5.87	4.15	3.64	3.50	3.38	3.11	3.35	2.80	4.02	3.82	4.36	(7)
(8)		HDD10.0	1323	302	282	171	77	13	1	0	0	2	53	171	252	(8)
(9)		HDD18.3	3463	561	514	425	305	168	86	40	45	129	263	419	508	(9)
(10)		CDD10.0	1004	1	1	4	22	106	181	257	254	126	49	2	2	(10)
(11)		CDD18.3	102	0	0	0	0	2	16	39	41	3	1	0	0	(11)
(12)		CDH23.3	1132	0	0	0	2	57	194	451	390	33	6	0	0	(12)
(13)		CDH26.7	297	0	0	0	0	2	38	137	117	2	1	0	0	(13)
(14)	Wind	WSAvg	3.7	4.7	4.3	4.2	3.5	3.0	3.2	3.0	2.8	3.4	3.5	4.1	4.5	(14)
(15)	Precipitation	PrecAvg	594	44	34	43	33	52	59	79	65	50	41	49	46	(15)
(16)		PrecMax	808	81	59	110	100	105	144	183	169	135	80	108	88	(16)
(17)		PrecMin	372	2	8	10	2	7	8	18	14	11	11	0	21	(17)
(18)		PrecStd	98	20	15	27	20	28	32	38	39	26	19	26	18	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.7	15.1	18.0	22.6	26.7	30.1	32.1	33.8	26.7	23.6	15.1	12.9	(19)
(20)			MCWB	8.3	10.4	11.7	13.8	17.5	19.1	20.1	20.8	18.5	16.5	10.6	8.9	(20)
(21)		2%	DB	9.3	12.0	14.4	19.6	25.0	27.7	30.1	30.0	24.0	20.2	12.9	11.6	(21)
(22)			MCWB	7.0	8.5	10.0	12.6	15.9	17.8	19.3	20.0	17.2	14.9	9.9	8.2	(22)
(23)		5%	DB	8.0	8.9	12.2	17.4	23.0	25.6	28.0	27.6	21.8	17.8	11.1	9.7	(23)
(24)			MCWB	6.0	6.6	8.4	11.5	15.2	17.2	18.5	18.9	16.4	13.9	8.8	7.4	(24)
(25)		10%	DB	6.7	6.8	10.5	14.9	20.8	23.6	25.9	25.4	19.5	16.0	9.7	8.0	(25)
(26)			MCWB	4.8	4.7	7.5	10.2	14.2	16.3	17.9	17.9	15.2	12.5	7.9	6.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.7	10.5	12.4	14.4	18.7	20.7	22.2	21.8	19.6	17.6	11.5	9.8	(27)
(28)			MCDWB	10.5	14.4	17.1	20.9	24.6	27.3	30.3	31.7	24.7	23.2	14.0	12.3	(28)
(29)		2%	WB	7.5	8.7	10.3	13.1	17.1	19.2	20.7	20.5	17.9	15.4	10.1	8.4	(29)
(30)			MCDWB	9.3	11.6	14.1	19.0	23.0	25.2	27.3	28.4	21.9	19.1	12.3	10.9	(30)
(31)		5%	WB	6.1	6.6	8.8	11.8	15.8	18.0	19.4	19.4	16.8	14.2	9.0	7.5	(31)
(32)			MCDWB	7.8	8.8	11.5	16.6	21.4	23.8	25.7	26.0	20.8	17.2	10.7	9.6	(32)
(33)		10%	WB	4.9	4.8	7.7	10.5	14.6	16.9	18.4	18.6	15.7	12.9	7.9	6.3	(33)
(34)			MCDWB	6.7	6.7	10.4	14.4	20.1	22.0	24.3	24.1	19.2	15.7	9.7	8.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.1	6.3	7.1	9.0	10.8	10.0	10.8	10.6	8.9	8.6	5.8	4.5	(35)
(36)			MCDBR	5.7	8.4	10.2	13.5	15.6	14.6	15.9	15.0	12.9	11.5	8.1	5.3	(36)
(37)			MCWBR	4.5	5.9	6.8	7.8	8.3	6.7	7.3	6.6	7.3	7.1	6.0	3.9	(37)
(38)		5% WB	MCDWR	5.6	8.1	9.7	12.6	13.8	12.8	13.9	12.9	11.7	10.8	7.5	5.0	(38)
(39)			MCWBR	4.6	5.8	6.7	7.5	7.9	6.3	6.8	6.0	6.9	6.7	5.8	4.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.312	0.336	0.379	0.414	0.417	0.413	0.430	0.424	0.386	0.362	0.336	0.307	(40)	
(41)		taud	2.369	2.340	2.244	2.195	2.227	2.267	2.226	2.262	2.345	2.386	2.402	2.378	(41)	
(42)		Ebn at Noon	702	782	809	822	838	844	820	805	796	741	665	646	(42)	
(43)		Edh at Noon	63	84	111	130	132	128	132	121	100	80	61	54	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.75	1.45	2.44	3.99	4.87	5.21	4.93	4.27	3.07	1.79	0.86	0.57	(44)	
(45)		RadStd	0.10	0.24	0.32	0.51	0.58	0.43	0.61	0.38	0.39	0.21	0.12	0.06	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (53 neighbors)		N/A	N/A	N/A	N/A	+0.33	+0.38	N/A	N/A	N/A	+13		

Nomenclature: See separate page