

GOERLITZ, Germany

WMO: 104990

Lat: 51.1622N

Lon: 14.9506E

Elev: 240

StdP: 98.48

Time Zone: 1.00 (EUC)

Period: 82-03

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-14.2	-10.9	-17.2	0.8	-13.4	-14.0	1.2	-10.3	14.0	5.2	13.0	3.4	2.6	70	0.601

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.0	28.8	18.7	26.8	18.1	25.1	17.5	20.0	26.5	19.1	24.9	18.2	23.6	3.4	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.9	13.2	22.3	17.0	12.5	21.2	16.1	11.7	20.3	58.3	26.7	55.0	24.8	52.3	23.6	24.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.3	10.8	9.5	DB	-15.2	32.4	5.6	1.8	-19.3	33.7	-22.6	34.7	-25.8	35.7	-29.8	37.0	(4)
(5)			WB	-15.5	22.2	5.5	1.0	-19.5	22.9	-22.8	23.5	-25.9	24.1	-29.9	24.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.6	-0.5	-0.6	4.1	7.8	12.8	15.6	17.8	17.7	13.8	9.6	3.8	1.1
	DBStd	7.77	5.61	5.42	4.23	3.87	3.64	3.37	3.13	3.46	3.03	4.00	3.66	4.06
	HDD10.0	1438	326	297	187	89	16	1	0	0	2	57	188	277
	HDD18.3	3629	584	530	442	317	175	96	48	54	140	272	437	534
	CDD10.0	941	0	1	3	22	102	169	243	239	117	44	1	0
	CDD18.3	88	0	0	0	0	2	13	33	35	4	1	0	0
	CDH23.3	812	0	0	0	0	26	129	311	319	28	0	0	0
	CDH26.7	181	0	0	0	0	1	22	69	87	1	0	0	0
Wind	WSAvg	4.1	5.7	4.9	4.7	3.7	3.2	3.2	3.0	3.0	3.6	4.3	5.1	5.4
Precipitation	PrecAvg	671	48	39	48	36	60	72	87	81	56	43	51	48
	PrecMax	968	103	79	114	67	119	208	207	225	143	97	106	85
	PrecMin	420	3	3	17	1	19	33	5	7	21	8	0	16
	PrecStd	117	25	20	26	17	28	38	48	42	31	24	26	20
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.2	13.5	16.7	21.6	26.0	29.2	30.8	32.6	26.4	21.8	13.3	11.4
		MCWB	7.8	9.1	10.6	13.3	16.9	18.7	19.8	20.1	17.9	15.8	10.0	8.4
	2%	DB	8.3	10.5	13.8	19.0	23.7	26.7	28.7	29.1	23.6	19.1	11.3	9.6
		MCWB	6.8	7.6	9.0	12.3	15.3	17.8	18.4	19.3	16.8	14.2	9.0	7.9
	5%	DB	7.0	7.6	11.6	16.7	22.0	24.6	26.7	26.6	21.6	17.1	9.8	8.3
		MCWB	5.5	5.2	7.7	10.9	14.6	17.2	18.3	18.2	15.7	13.0	8.1	6.8
	10%	DB	5.8	5.5	9.7	14.7	20.1	22.6	24.9	24.7	19.5	15.5	8.5	6.7
		MCWB	4.3	3.7	6.8	10.0	13.9	16.0	17.4	17.6	15.1	12.0	6.9	5.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.2	9.6	11.6	14.2	17.9	20.4	21.5	21.3	18.8	16.6	10.7	9.0
		MCDB	9.7	12.5	15.5	19.8	23.4	25.6	28.8	28.6	24.1	20.6	12.4	10.4
	2%	WB	6.9	7.6	9.5	12.9	16.4	18.9	20.1	20.1	17.6	15.0	9.4	7.9
		MCDB	8.1	10.3	12.9	18.1	22.1	25.0	26.1	27.5	22.1	17.8	10.9	9.3
	5%	WB	5.7	5.4	8.4	11.5	15.4	17.9	19.0	19.0	16.6	13.6	8.2	6.9
		MCDB	6.9	7.2	11.0	15.9	20.3	23.4	24.8	25.0	20.3	16.5	9.6	8.2
	10%	WB	4.4	3.9	7.3	10.2	14.3	16.8	18.0	18.1	15.6	12.3	7.1	5.6
		MCDB	5.5	5.7	9.6	13.7	19.1	21.4	23.4	23.3	19.0	15.0	8.4	6.7
Mean Daily Temperature Range	5% DB	MDBR	4.4	5.5	6.6	8.7	9.8	9.2	10.0	10.0	8.3	7.3	4.8	4.1
		MCDBR	5.3	7.6	9.7	12.0	13.3	12.8	13.7	13.3	11.7	9.5	6.3	4.9
		MCWBR	4.5	5.4	6.3	7.0	6.7	6.1	6.0	5.9	6.0	5.6	4.6	4.0
	5% WB	MCDBR	5.2	7.0	8.9	10.9	11.2	10.9	11.8	11.7	9.9	8.2	6.1	4.7
		MCWBR	4.7	5.2	6.1	6.7	6.3	5.7	5.9	5.8	5.6	5.3	4.9	4.0
Clear-Sky Solar Irradiance	taub	0.308	0.331	0.372	0.415	0.415	0.412	0.430	0.424	0.384	0.360	0.334	0.303	
	taud	2.351	2.329	2.258	2.199	2.241	2.278	2.234	2.271	2.353	2.393	2.402	2.381	
	Ebn at Noon	708	790	817	822	840	845	821	805	799	746	670	655	
	Edh at Noon	64	85	109	130	131	127	131	120	99	79	61	54	
All-Sky Solar Radiation	RadAvg	0.76	1.47	2.49	4.07	4.93	5.25	4.98	4.39	3.14	1.80	0.84	0.56	
	RadStd	0.12	0.26	0.35	0.56	0.57	0.42	0.60	0.43	0.42	0.25	0.12	0.06	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (49 neighbors)		+0.42	N/A	N/A	N/A	N/A	+0.36	N/A	N/A	+53	+18

Nomenclature: See separate page