

GEILENKIRCHEN, Germany

WMO: 105000

Lat: 50.9592N

Lon: 6.0392E

Elev: 76

StdP: 100.41

Time Zone: 1.00 (EUC)

Period: 90-00

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -8.0	(c) -5.9	(d) -10.8	(e) 1.5	(f) -6.6	(g) -8.6	(h) 1.8	(i) -4.7	(j) 12.3	(k) 8.4	(l) 11.2	(m) 7.6	(n) 2.3	(o) 90	(p) 0.516

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.4	30.8	19.7	28.7	19.0	26.6	18.3	20.7	28.2	19.8	26.5	19.0	25.3	3.2	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.2	13.2	23.2	17.2	12.4	22.3	16.4	11.8	21.6	60.0	28.2	56.8	26.4	54.0	25.4	24.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
9.7	8.4	7.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			DB												
			WB	-11.9	23.0	4.1	1.2	-14.9	23.8	-17.3	24.6	-19.6	25.2	-22.5	26.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.7	3.3	4.5	7.2	9.7	13.7	16.3	19.0	18.7	14.9	10.7	6.0	3.7	(6)
(7)		DBStd	6.73	4.76	4.81	3.38	3.77	3.86	3.27	3.20	3.30	2.80	3.70	4.16	4.23	(7)
(8)		HDD10.0	888	209	158	99	51	9	0	0	0	1	37	128	198	(8)
(9)		HDD18.3	2920	465	387	344	258	152	80	29	36	108	236	369	454	(9)
(10)		CDD10.0	1142	2	4	13	43	123	188	280	270	148	59	8	2	(10)
(11)		CDD18.3	132	0	0	0	1	8	18	51	48	6	1	0	0	(11)
(12)		CDH23.3	1353	0	0	1	9	96	204	521	476	44	4	0	0	(12)
(13)		CDH26.7	432	0	0	0	0	18	57	177	171	9	0	0	0	(13)
(14)	Wind	WSAvg	3.0	3.7	3.7	3.5	2.9	2.6	2.6	2.7	2.5	2.7	3.0	3.1	3.5	(14)
(15)	Precipitation	PrecAvg	814	68	65	55	48	62	77	79	84	64	64	69	79	(15)
(16)		PrecMax	987	137	153	114	97	130	160	186	170	158	152	115	174	(16)
(17)		PrecMin	652	5	11	5	1	22	19	30	25	16	33	4	22	(17)
(18)		PrecStd	93	33	32	28	23	25	33	40	42	38	25	28	34	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.0	16.8	19.1	25.0	29.1	31.4	33.5	28.3	23.5	15.6	13.4	(19)	
(20)			MCWB	10.3	10.0	12.0	13.7	18.3	20.9	21.0	19.8	17.6	17.2	12.0	11.1	(20)
(21)		2%	DB	12.1	14.0	16.6	21.2	25.9	28.1	30.8	30.9	24.1	20.0	13.8	12.2	(21)
(22)			MCWB	9.6	9.6	10.9	13.6	17.4	18.9	20.0	19.4	16.9	15.5	11.5	10.1	(22)
(23)		5%	DB	10.9	12.2	14.6	18.8	23.7	25.7	28.5	28.5	21.7	18.1	12.9	11.0	(23)
(24)			MCWB	8.5	8.9	10.1	12.3	15.9	18.0	19.1	19.0	16.1	14.1	10.8	9.3	(24)
(25)		10%	DB	9.6	10.6	12.8	16.2	21.0	23.0	26.3	25.9	19.8	16.3	11.6	9.6	(25)
(26)			MCWB	7.7	8.1	9.5	11.1	14.9	16.6	18.5	18.3	15.3	13.4	9.7	7.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.3	11.2	12.7	16.1	19.5	21.3	22.3	21.7	19.1	17.3	12.9	11.7	(27)
(28)			MCDWB	13.0	14.8	17.5	21.5	26.4	29.1	30.5	30.0	24.4	21.3	14.4	13.0	(28)
(29)		2%	WB	9.9	10.2	11.5	14.1	17.9	20.0	21.0	20.3	17.8	16.0	12.0	10.4	(29)
(30)			MCDWB	11.7	13.1	15.0	19.3	24.2	26.6	28.5	27.5	22.4	19.3	13.6	11.9	(30)
(31)		5%	WB	8.8	9.2	10.6	12.8	16.6	18.5	19.9	19.6	16.7	14.8	11.0	9.3	(31)
(32)			MCDWB	10.7	11.7	13.6	17.5	22.2	24.0	26.9	26.4	20.3	17.3	12.5	11.0	(32)
(33)		10%	WB	7.6	8.3	9.8	11.6	15.2	17.3	18.9	18.7	15.8	13.6	9.9	7.9	(33)
(34)			MCDWB	9.4	10.5	12.7	16.1	20.0	22.0	25.1	25.1	19.2	16.0	11.2	9.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.3	6.1	7.8	9.2	9.8	9.5	10.4	10.5	8.2	7.5	5.5	4.7	(35)
(36)			MCDBR	6.6	8.0	11.2	13.0	14.1	14.4	15.2	15.3	11.3	9.8	6.1	5.7	(36)
(37)			MCWBR	5.2	5.3	6.9	6.6	7.1	7.1	6.7	6.4	5.8	6.2	4.7	4.9	(37)
(38)		5% WB	MCDBR	6.1	6.9	9.0	11.2	13.0	12.6	12.9	13.0	9.8	9.2	5.9	5.4	(38)
(39)			MCWBR	5.1	5.2	5.9	6.2	6.9	6.8	6.1	6.2	5.4	6.4	4.9	5.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.323	0.346	0.378	0.413	0.419	0.420	0.425	0.416	0.387	0.362	0.337	0.318	(40)	
(41)		taud	2.411	2.367	2.285	2.211	2.233	2.250	2.236	2.285	2.353	2.416	2.409	2.382	(41)	
(42)		Ebn at Noon	700	777	814	825	837	838	826	814	797	748	671	638	(42)	
(43)		Edh at Noon	62	83	107	129	132	131	131	119	100	78	62	55	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.76	1.43	2.57	4.11	4.91	5.34	5.05	4.32	3.20	1.88	0.88	0.58	(44)	
(45)		RadStd	0.11	0.28	0.38	0.47	0.45	0.48	0.61	0.42	0.36	0.17	0.11	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (84 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page