

PLAUEN, Germany

WMO: 105690

Lat: 50.4819N

Lon: 12.1300E

Elev: 389

StdP: 96.74

Time Zone: 1.00 (EUC)

Period: 82-03

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-15.5	-12.2	-20.4	0.6	-14.3	-15.9	1.0	-11.8	11.0	5.7	9.7	3.6	1.5	230	0.591

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.7	28.6	18.5	26.4	17.6	24.7	16.7	19.3	26.4	18.3	24.8	17.4	23.3	3.4	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.6	12.4	22.5	15.7	11.7	21.2	14.9	11.1	20.0	56.5	26.6	53.2	25.0	50.3	23.5	22.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.2	8.1	7.2	DB	-18.8	32.4	5.2	1.8	-22.6	33.7	-25.6	34.8	-28.5	35.8	-32.2	37.1	(4)
(5)			WB	-19.4	21.3	5.1	1.2	-23.1	22.1	-26.1	22.9	-28.9	23.5	-32.7	24.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.9	-0.8	-1.2	3.2	6.7	11.5	14.6	16.9	16.8	13.3	8.8	3.4	0.9
	DBStd	7.61	5.53	5.49	4.38	3.75	3.60	3.44	3.12	3.28	3.30	4.02	3.76	4.21
	HDD10.0	1561	336	314	213	112	27	3	0	0	7	69	198	282
	HDD18.3	3864	594	547	469	349	212	121	66	68	154	296	447	540
	CDD10.0	792	0	1	2	13	74	139	214	212	104	32	1	0
	CDD18.3	54	0	0	0	0	1	8	22	22	2	1	0	0
	CDH23.3	708	0	0	0	1	22	114	276	258	36	2	0	0
	CDH26.7	161	0	0	0	0	1	23	64	71	2	0	0	0
Wind	WSAvg	3.3	4.2	3.6	3.6	3.2	2.8	2.7	2.6	2.6	2.9	3.3	3.8	3.9
Precipitation	PrecAvg	733	52	45	50	43	63	76	90	77	65	55	59	59
	PrecMax	963	90	104	124	99	148	140	152	206	124	129	140	121
	PrecMin	542	2	11	12	6	10	28	25	21	25	18	0	21
	PrecStd	108	24	23	27	20	32	28	32	42	24	25	31	27
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.4	13.9	17.7	21.5	25.4	29.4	31.0	31.6	26.5	21.9	14.1	11.7
		MCWB	7.7	9.0	10.5	12.4	16.3	17.9	20.0	19.4	17.3	15.2	10.2	9.0
	2%	DB	8.1	10.3	13.8	18.6	23.6	26.5	28.5	28.6	24.2	18.7	11.6	9.8
		MCWB	6.1	7.3	8.9	11.1	15.1	17.1	18.5	18.9	16.7	13.3	9.1	7.4
	5%	DB	6.8	7.5	10.8	16.1	21.4	24.2	26.3	26.1	22.1	16.5	9.9	8.1
		MCWB	5.0	5.1	7.1	9.9	13.9	16.6	17.8	17.6	15.7	12.2	7.8	6.4
	10%	DB	5.5	5.0	9.1	13.9	19.5	21.9	24.5	24.1	19.8	14.6	8.5	6.6
		MCWB	3.9	3.2	6.2	8.9	12.9	15.3	16.8	16.8	14.7	11.4	6.7	5.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.1	9.5	11.2	13.3	17.4	19.8	20.9	20.6	18.8	16.1	10.9	9.2
		MCDB	9.6	12.9	16.0	20.1	23.6	25.9	28.8	29.5	24.2	21.6	13.1	10.8
	2%	WB	6.4	7.4	9.0	11.6	15.7	18.1	19.4	19.2	17.3	14.2	9.5	7.7
		MCDB	7.9	9.9	13.3	17.2	21.8	24.2	26.4	27.0	22.6	17.9	11.4	9.6
	5%	WB	5.2	5.1	7.6	10.4	14.5	17.0	18.3	18.1	16.3	12.7	7.9	6.4
		MCDB	6.6	7.3	10.4	15.3	20.4	22.2	24.9	25.0	21.1	15.7	9.7	8.1
	10%	WB	3.9	3.5	6.3	9.1	13.3	15.9	17.3	17.1	15.2	11.6	6.8	5.2
		MCDB	5.5	5.0	8.9	13.4	18.8	21.6	23.5	22.8	19.2	14.3	8.4	6.7
Mean Daily Temperature Range	5% DB	MDBR	5.0	6.5	7.2	9.0	10.6	9.7	10.7	10.5	9.6	8.0	5.6	4.4
		MCDBR	5.6	9.0	11.0	13.5	15.2	15.0	15.2	15.0	13.7	11.0	7.8	5.3
		MCWBR	4.8	6.4	7.3	7.9	8.4	7.5	7.5	7.1	7.4	6.8	5.9	4.6
	5% WB	MCDBR	5.2	8.4	10.6	12.0	13.5	13.2	13.4	13.1	12.0	9.7	7.1	5.0
		MCWBR	4.7	6.3	7.4	7.3	7.9	6.9	7.2	6.6	6.8	6.4	5.8	4.5
Clear-Sky Solar Irradiance	taub	0.298	0.321	0.363	0.401	0.404	0.404	0.417	0.410	0.377	0.351	0.324	0.294	
	taud	2.386	2.343	2.296	2.242	2.268	2.292	2.255	2.296	2.368	2.427	2.441	2.403	
	Ebn at Noon	738	810	834	839	853	854	834	822	811	767	701	685	
	Edh at Noon	63	84	106	125	128	126	129	118	98	78	60	54	
All-Sky Solar Radiation	RadAvg	0.80	1.57	2.57	4.04	4.83	5.25	4.99	4.33	3.10	1.83	0.87	0.61	
	RadStd	0.15	0.24	0.36	0.53	0.58	0.45	0.56	0.43	0.44	0.23	0.11	0.07	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (50 neighbors)		+0.40	N/A	N/A	N/A	+0.32	+0.37	N/A	N/A	+60	+20

Nomenclature: See separate page