

WIESBADEN, Germany

WMO: 106330

Lat: 50.050N

Lon: 8.325E

Elev: 141

StdP: 99.65

Time Zone: 1.00 (EUC)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.1	-4.9	-13.1	1.2	-5.2	-9.8	1.7	-2.8	11.6	9.1	10.1	8.8	2.3	10	0.496

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.4	31.7	20.2	29.3	19.2	27.4	18.5	21.2	28.8	20.3	27.2	19.5	25.8	3.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.9	14.0	23.7	18.0	13.2	23.0	17.1	12.4	22.1	62.2	28.6	59.1	27.4	56.2	25.8	24.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.8	7.6	6.7	-9.6	34.7	3.7	1.8	-12.3	36.1	-14.5	37.1	-16.6	38.1	-19.3	39.5		
(5)			-10.6	23.0	3.7	0.8	-13.3	23.6	-15.4	24.1	-17.5	24.6	-20.2	25.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.3	2.4	3.2	7.0	11.8	15.0	18.3	20.4	19.8	15.6	11.2	6.6	3.3	(6)
(7)		DBStd	7.31	4.24	3.69	3.56	3.94	3.82	3.40	3.50	3.17	3.11	3.44	3.37	3.96	(7)
(8)		HDD10.0	909	237	190	105	26	4	0	0	0	1	29	111	208	(8)
(9)		HDD18.3	2800	494	423	353	198	118	43	18	19	94	223	352	465	(9)
(10)		CDD10.0	1366	1	1	11	79	157	248	323	303	169	64	8	1	(10)
(11)		CDD18.3	216	0	0	0	2	13	41	83	64	12	0	0	0	(11)
(12)		CDH23.3	1873	0	0	0	23	106	341	772	539	88	4	0	0	(12)
(13)		CDH26.7	598	0	0	0	2	18	96	286	177	19	0	0	0	(13)
(14)	Wind	WSAvg	2.7	3.1	2.8	3.3	2.9	2.8	2.7	2.7	2.4	2.4	2.3	2.5	2.7	(14)
(15)	Precipitation	PrecAvg	680	52	50	45	42	61	65	71	59	56	58	58	62	(15)
(16)		PrecMax	832	126	126	122	93	121	119	170	126	131	171	97	171	(16)
(17)		PrecMin	491	6	8	6	0	16	22	26	5	13	8	1	10	(17)
(18)		PrecStd	93	25	28	27	21	28	27	35	30	28	32	23	32	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.1	13.4	20.0	25.9	28.9	32.4	35.1	34.0	29.4	23.5	16.2	12.7	(19)
(20)			MCWB	10.6	8.6	11.3	15.6	19.5	20.9	21.3	21.0	17.8	16.1	14.1	10.7	(20)
(21)		2%	DB	11.8	11.5	17.1	23.2	26.2	29.3	32.2	31.0	26.0	19.9	14.2	11.2	(21)
(22)			MCWB	10.1	8.1	10.2	14.2	17.9	19.4	20.4	19.9	16.8	15.2	12.4	9.4	(22)
(23)		5%	DB	9.9	10.1	14.8	21.1	24.1	27.0	29.8	28.3	23.3	17.9	12.9	9.9	(23)
(24)			MCWB	8.3	7.6	9.2	13.4	16.1	19.0	19.5	19.0	16.6	14.5	11.1	8.5	(24)
(25)		10%	DB	8.1	8.8	12.7	19.0	22.0	25.0	27.6	26.1	21.2	16.3	11.2	8.6	(25)
(26)			MCWB	6.7	6.7	8.4	12.2	15.1	18.0	18.6	17.8	15.6	13.7	9.6	7.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.8	10.3	12.1	16.3	20.5	22.6	22.6	22.2	19.7	17.7	15.0	11.6	(27)
(28)			MADB	12.5	12.1	17.8	24.2	27.1	31.0	32.1	30.6	25.4	19.9	15.3	12.2	(28)
(29)		2%	WB	10.1	8.8	10.8	14.8	19.0	20.8	21.2	21.0	18.4	16.1	13.0	10.0	(29)
(30)			MADB	11.4	10.6	15.5	21.7	25.4	27.2	29.1	28.5	23.4	18.8	14.0	10.8	(30)
(31)		5%	WB	8.4	7.8	9.8	13.7	17.4	19.5	20.3	20.0	17.3	15.1	11.2	8.5	(31)
(32)			MADB	9.6	9.8	13.9	20.0	22.4	25.6	27.6	26.2	21.9	17.5	12.5	9.6	(32)
(33)		10%	WB	6.7	6.5	8.8	12.8	15.9	18.5	19.5	19.0	16.3	14.0	10.0	7.2	(33)
(34)			MADB	8.0	8.4	12.1	18.1	20.4	23.9	26.0	24.7	20.2	16.1	11.3	8.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.6	6.0	8.3	9.7	9.5	10.0	10.4	10.3	9.1	7.3	4.9	4.5	(35)
(36)			MCDBR	5.8	8.4	12.4	12.8	12.1	12.8	14.2	13.6	12.2	10.0	6.3	5.7	(36)
(37)			MCWBR	4.7	5.7	7.0	6.6	5.8	5.8	5.4	5.6	5.8	6.1	4.7	4.8	(37)
(38)		5% WB	MCDBR	5.4	7.4	10.7	11.9	11.4	11.8	12.4	11.7	10.0	8.7	6.0	5.6	(38)
(39)			MCWBR	4.6	5.2	6.5	6.3	6.0	5.8	5.1	5.6	5.6	5.7	4.7	4.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.331	0.362	0.399	0.412	0.416	0.419	0.423	0.417	0.389	0.385	0.356	0.329	(40)	
(41)		taud	2.350	2.280	2.193	2.219	2.238	2.257	2.240	2.284	2.344	2.316	2.333	2.346	(41)	
(42)		Ebn at Noon	695	760	794	830	842	841	830	816	801	723	652	636	(42)	
(43)		Edh at Noon	68	92	119	129	132	131	131	120	102	88	69	60	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.79	1.52	2.66	4.20	4.96	5.52	5.22	4.50	3.28	1.92	0.89	0.60	(44)	
(45)		RadStd	0.12	0.24	0.39	0.53	0.53	0.49	0.58	0.42	0.42	0.20	0.11	0.07	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A
(47) Regional (45 neighbors)		(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A

Nomenclature: See separate page