

ANSBACH, Germany

WMO: 107550

Lat: 49.308N

Lon: 10.639E

Elev: 1532

StdP: 13.90

Time Zone: 1.00 (EUC)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.7	17.8	6.5	8.1	16.1	13.1	11.3	21.8	28.6	46.0	25.3	41.8	6.9	40	0.540

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.5	86.3	67.2	82.5	65.6	79.1	64.6	68.9	81.6	67.4	79.0	65.9	76.3	6.6	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.9	97.5	71.6	63.6	93.1	70.7	62.3	89.0	69.8	33.9	81.5	32.7	79.4	31.5	76.4	75.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.5	18.5	16.0	DB	8.8	90.5	5.5	3.0	4.8	92.7	1.6	94.4	-1.5	96.1	-5.5	98.3	(4)
(5)			WB	8.8	72.1	5.8	2.0	4.6	73.5	1.2	74.7	-2.1	75.8	-6.3	77.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	49.1	32.2	33.7	41.4	49.9	55.9	62.5	66.0	65.4	57.3	49.2	40.4	34.5	(6)
(7)		DBStd	13.81	7.90	8.21	6.78	7.22	6.97	6.37	6.31	6.13	6.13	7.02	6.65	7.33	(7)
(8)		HDD50	2282	551	457	274	90	24	1	0	0	8	103	295	479	(8)
(9)		HDD65	6044	1016	877	731	454	294	121	67	71	242	489	738	944	(9)
(10)		CDD50	1962	0	0	8	87	206	376	495	477	227	79	7	0	(10)
(11)		CDD65	249	0	0	0	1	11	46	97	83	11	0	0	0	(11)
(12)		CDH74	2225	0	0	0	15	96	422	857	732	102	1	0	0	(12)
(13)		CDH80	611	0	0	0	2	11	102	263	220	13	0	0	0	(13)
(14)	Wind	WSAvg	7.2	8.5	7.8	8.3	7.0	7.2	6.6	6.7	6.0	6.2	6.6	7.6	8.3	(14)
(15)	Precipitation	PrecAvg	26.9	1.9	1.8	1.9	1.6	2.5	2.8	3.2	2.4	2.1	2.2	2.3	2.2	(15)
(16)		PrecMax	37.0	4.3	4.4	5.3	4.3	6.1	5.8	6.2	5.4	5.0	7.5	5.2	6.4	(16)
(17)		PrecMin	18.0	0.5	0.4	0.3	0.2	0.6	0.9	1.3	0.7	0.4	0.5	0.0	0.4	(17)
(18)		PrecStd	4.2	1.1	1.0	1.1	0.9	1.3	1.2	1.3	1.1	1.0	1.3	1.1	1.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.1	56.7	65.0	75.6	81.5	88.2	92.1	91.1	82.4	72.7	59.7	51.9	(19)
(20)			MCWB	49.1	46.1	50.7	57.4	64.4	70.4	68.6	68.3	63.5	59.2	55.4	49.0	(20)
(21)		2%	DB	48.8	50.2	60.6	71.4	76.8	82.7	86.5	85.8	77.1	67.6	55.8	49.1	(21)
(22)			MCWB	46.6	44.8	48.6	54.8	62.6	66.4	66.8	67.4	62.3	59.1	52.8	47.5	(22)
(23)		5%	DB	45.5	47.1	56.4	67.9	72.5	78.7	82.4	81.6	72.5	63.0	53.1	46.5	(23)
(24)			MCWB	43.6	43.5	46.6	53.7	59.1	64.8	65.3	66.0	60.6	56.9	50.9	45.2	(24)
(25)		10%	DB	42.7	44.4	52.1	64.0	68.9	75.2	78.7	77.4	68.4	59.4	49.9	44.1	(25)
(26)			MCWB	41.2	40.9	45.1	52.3	57.6	63.7	64.1	64.5	59.3	55.3	48.0	43.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.3	48.6	52.6	59.1	66.7	71.2	70.5	70.8	66.2	62.4	57.2	50.2	(27)
(28)			MCDWB	51.4	51.3	61.0	72.6	77.6	83.9	85.2	82.5	75.9	67.4	57.8	51.0	(28)
(29)		2%	WB	46.9	45.9	49.9	56.4	63.9	68.2	68.3	68.9	63.8	59.7	53.8	47.9	(29)
(30)			MCDWB	48.6	48.9	57.7	67.5	74.1	79.2	81.2	81.5	73.4	64.7	55.5	48.9	(30)
(31)		5%	WB	44.1	43.8	47.8	54.5	61.3	66.1	67.0	67.3	62.2	57.9	50.9	45.4	(31)
(32)			MCDWB	45.4	47.0	54.2	65.2	69.5	75.9	78.9	79.1	70.7	62.0	52.6	46.4	(32)
(33)		10%	WB	41.2	41.2	46.0	52.8	58.9	64.0	65.6	65.6	60.5	55.8	48.3	43.2	(33)
(34)			MCDWB	42.2	43.4	51.3	62.6	67.0	73.1	76.2	75.4	67.3	59.0	49.7	43.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.7	10.5	14.1	17.7	16.8	16.5	17.5	17.7	16.0	13.3	9.0	7.8	(35)
(36)			MCDBR	10.2	15.6	22.3	23.7	22.4	23.0	23.9	23.9	22.2	19.1	13.4	10.6	(36)
(37)			MCWBR	8.6	10.7	12.5	11.7	10.6	9.9	9.1	9.2	9.7	11.4	9.9	9.1	(37)
(38)		5% WB	MCDBR	10.2	14.1	18.5	21.5	20.0	21.5	20.4	21.4	19.5	16.5	12.4	10.1	(38)
(39)			MCWBR	9.1	10.5	11.5	11.4	10.3	10.3	8.6	9.3	9.4	10.8	10.0	9.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.299	0.322	0.356	0.387	0.395	0.398	0.405	0.399	0.371	0.348	0.322	0.296	(40)	
(41)		taud	2.439	2.386	2.333	2.275	2.279	2.299	2.274	2.313	2.372	2.432	2.460	2.439	(41)	
(42)		Ebn at Noon	242	261	270	272	274	273	269	266	262	248	229	226	(42)	
(43)		Edh at Noon	20	26	33	39	40	40	40	37	31	25	20	17	(43)	
(44)	All-Sky Solar Radiation	RadAvg	277	541	892	1352	1594	1769	1677	1457	1058	632	311	220	(44)	
(45)		RadStd	46	89	113	179	181	144	158	139	138	76	38	25	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (40 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.72	N/A	N/A	N/A	+36	

Nomenclature: See separate page