

HOHENFELS, GermanyWMO: **107750**Lat: **49.218N**Lon: **11.836E**Elev: **1455**StdP: **13.94**Time Zone: **1.00 (EUC)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.2	14.1	3.9	7.1	9.7	10.1	9.7	16.8	20.1	37.9	17.8	36.7	2.1	290	0.511

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.2	87.5	68.2	83.8	66.4	80.2	65.4	70.2	81.7	68.3	79.5	66.9	77.3	5.5	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.7	103.6	73.1	64.7	96.7	71.1	63.0	90.8	69.9	35.0	82.0	33.5	80.0	32.2	77.5	77.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.3	12.9	11.2	DB	1.8	93.2	6.2	3.4	-2.6	95.6	-6.2	97.6	-9.7	99.5	-14.2	102.0	(4)
(5)			WB	0.9	72.8	6.2	1.8	-3.6	74.1	-7.2	75.2	-10.7	76.2	-15.2	77.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	48.1	30.9	32.6	39.6	48.0	55.3	61.8	65.1	64.8	56.8	47.4	39.7	33.6	(6)
(7)		DBStd	13.93	8.34	8.59	6.64	6.68	6.47	6.25	5.65	5.92	5.95	6.67	6.32	7.28	(7)
(8)		HDD50	2510	594	488	325	114	25	1	0	0	11	130	313	509	(8)
(9)		HDD65	6382	1058	908	787	510	308	135	69	76	253	546	758	974	(9)
(10)		CDD50	1798	0	0	3	54	188	354	470	460	215	50	4	0	(10)
(11)		CDD65	195	0	0	0	0	6	38	73	71	7	0	0	0	(11)
(12)		CDH74	2579	0	0	0	20	153	524	885	887	109	1	0	0	(12)
(13)		CDH80	771	0	0	0	1	25	146	302	283	14	0	0	0	(13)
(14)	Wind	WSAvg	4.0	4.7	4.2	5.1	4.1	4.3	4.3	4.1	3.7	3.3	3.4	3.6	3.7	(14)
(15)	Precipitation	PrecAvg	29.3	2.2	1.9	2.0	1.7	2.7	3.2	3.3	2.9	2.3	2.2	2.4	2.4	(15)
(16)		PrecMax	39.8	4.5	5.2	5.7	3.3	5.9	5.8	5.2	5.7	5.7	7.4	5.2	6.3	(16)
(17)		PrecMin	21.5	0.2	0.4	0.4	0.5	0.5	1.0	0.8	1.1	0.6	0.6	0.1	0.5	(17)
(18)		PrecStd	4.1	1.2	1.1	1.3	0.8	1.3	1.2	1.2	1.2	1.2	1.4	1.1	1.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.2	57.3	64.7	76.7	83.8	89.4	92.8	91.7	82.1	71.6	60.3	51.7	(19)
(20)			MCWB	48.2	48.4	51.1	58.3	64.5	69.4	69.9	68.4	65.0	60.0	56.4	49.0	(20)
(21)		2%	DB	48.4	51.5	60.6	71.7	78.7	84.2	87.6	87.0	77.1	65.9	55.6	48.4	(21)
(22)			MCWB	46.1	45.5	49.0	55.8	62.6	67.4	67.9	68.4	64.1	58.6	52.0	46.9	(22)
(23)		5%	DB	45.0	48.0	55.6	68.0	73.6	79.4	82.7	82.6	73.2	61.6	52.2	46.0	(23)
(24)			MCWB	43.1	44.1	47.1	54.4	59.6	65.3	66.1	66.3	62.5	56.8	49.7	44.4	(24)
(25)		10%	DB	41.4	44.7	51.6	63.9	69.7	75.9	78.7	78.9	69.5	58.0	48.7	43.0	(25)
(26)			MCWB	39.8	41.7	45.6	52.3	57.4	63.8	64.9	65.4	61.1	54.5	46.9	41.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.1	49.2	53.4	59.8	66.6	72.2	71.9	72.9	67.9	62.8	57.2	50.0	(27)
(28)			MCDB	52.0	54.5	61.3	73.5	79.0	83.7	85.0	81.8	76.1	67.4	58.2	50.2	(28)
(29)		2%	WB	46.4	46.5	50.2	57.1	63.8	68.9	69.7	70.4	65.6	59.7	52.9	47.2	(29)
(30)			MCDB	47.8	49.9	57.5	69.4	74.5	79.4	82.1	81.2	74.3	64.4	55.3	48.4	(30)
(31)		5%	WB	43.1	44.1	48.3	54.9	61.2	67.0	68.0	68.2	63.7	57.5	50.0	44.4	(31)
(32)			MCDB	44.7	47.2	54.5	65.8	70.7	77.3	79.6	79.8	71.6	61.4	52.2	45.5	(32)
(33)		10%	WB	39.9	41.7	46.0	53.0	59.0	65.0	66.4	66.5	61.8	55.1	47.6	41.8	(33)
(34)			MCDB	41.2	44.2	50.5	62.5	67.8	74.2	76.4	76.8	68.1	58.0	49.2	42.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.8	14.0	17.5	22.0	21.5	20.6	21.2	22.4	20.3	15.9	10.9	9.2	(35)
(36)			MCDBR	12.9	19.9	27.7	31.8	30.5	29.2	30.1	30.2	26.8	21.8	16.8	12.4	(36)
(37)			MCWBR	10.6	14.4	17.2	17.2	15.2	14.1	12.5	13.2	14.9	15.1	13.0	10.6	(37)
(38)		5% WB	MCDBR	12.5	17.9	24.2	28.6	26.6	26.0	26.0	26.5	23.7	20.6	15.2	11.6	(38)
(39)			MCWBR	10.9	13.6	15.9	16.1	14.1	13.3	11.8	12.9	13.9	15.0	12.4	10.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.300	0.322	0.359	0.392	0.399	0.400	0.409	0.403	0.375	0.351	0.325	0.298	(40)	
(41)		taud	2.424	2.374	2.328	2.269	2.278	2.303	2.274	2.312	2.367	2.427	2.460	2.437	(41)	
(42)		Ebn at Noon	241	261	269	271	273	273	268	264	260	247	229	225	(42)	
(43)		Edh at Noon	20	27	33	39	40	40	40	37	32	25	20	18	(43)	
(44)	All-Sky Solar Radiation	RadAvg	283	555	900	1351	1587	1757	1672	1461	1053	635	313	222	(44)	
(45)		RadStd	47	86	116	177	182	146	159	143	138	76	37	27	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(46)
(47)	Regional (54 neighbors)	N/A	N/A	N/A	N/A	+0.52	+0.68	N/A	N/A	+101 +36	(47)

Nomenclature: See separate page