

HOHENFELS, Germany

WMO: 107750

Lat: 49.218N

Lon: 11.836E

Elev: 444

StdP: 96.11

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.2	-10.0	-15.6	1.0	-12.4	-12.1	1.4	-8.4	9.0	3.3	8.0	2.6	0.9	290	0.511

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.8	30.9	20.1	28.8	19.1	26.8	18.6	21.2	27.6	20.2	26.4	19.4	25.2	2.5	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.3	14.8	22.8	18.2	13.8	21.7	17.2	13.0	21.1	63.4	27.8	60.0	26.7	56.9	25.3	25.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.8	5.8	5.0	DB	-16.8	34.0	3.4	1.9	-19.2	35.3	-21.2	36.4	-23.2	37.5	-25.6	38.9	(4)
(5)			WB	-17.3	22.7	3.4	1.0	-19.8	23.4	-21.8	24.0	-23.7	24.6	-26.2	25.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.9	-0.6	0.3	4.2	8.9	12.9	16.5	18.4	18.2	13.8	8.6	4.3	0.9	(6)	
	DBStd	7.74	4.63	4.77	3.69	3.71	3.60	3.47	3.14	3.29	3.31	3.71	3.51	4.05	(7)	
	HDD10.0	1394	330	271	181	63	14	1	0	0	6	72	174	283	(8)	
	HDD18.3	3546	588	504	437	283	171	75	38	42	141	303	421	541	(9)	
	CDD10.0	999	0	0	2	30	104	197	261	256	119	28	2	0	(10)	
	CDD18.3	108	0	0	0	0	3	21	41	39	4	0	0	0	(11)	
	CDH23.3	1433	0	0	0	11	85	291	492	493	61	1	0	0	(12)	
	CDH26.7	428	0	0	0	1	14	81	168	157	8	0	0	0	(13)	
(14) Wind	WSAvg	1.8	2.1	1.9	2.3	1.8	1.9	1.9	1.8	1.6	1.5	1.5	1.6	1.7	(14)	
(15) Precipitation	PrecAvg	744	57	49	51	42	68	81	85	74	59	55	61	62	(15)	
	PrecMax	1010	114	132	146	83	151	147	131	145	145	187	132	160	(16)	
	PrecMin	545	5	9	10	13	12	26	20	27	15	14	2	12	(17)	
	PrecStd	104	30	28	33	20	33	30	31	30	30	35	28	33	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.2	14.0	18.2	24.9	28.8	31.9	33.8	33.2	27.9	22.0	15.7	10.9	(19)	
		MCWB	9.0	9.1	10.6	14.6	18.1	20.8	21.1	20.2	18.3	15.5	13.6	9.4	(20)	
	2%	DB	9.1	10.8	15.9	22.0	26.0	29.0	30.9	30.6	25.1	18.8	13.1	9.1	(21)	
		MCWB	7.8	7.5	9.5	13.2	17.0	19.7	20.0	20.2	17.8	14.8	11.1	8.3	(22)	
	5%	DB	7.2	8.9	13.1	20.0	23.1	26.3	28.2	28.1	22.9	16.5	11.2	7.8	(23)	
		MCWB	6.2	6.7	8.4	12.5	15.3	18.5	18.9	19.0	16.9	13.8	9.8	6.9	(24)	
	10%	DB	5.2	7.0	10.9	17.7	21.0	24.4	25.9	26.1	20.8	14.4	9.3	6.1	(25)	
		MCWB	4.4	5.4	7.5	11.3	14.1	17.7	18.3	18.6	16.2	12.5	8.3	5.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.0	9.6	11.9	15.4	19.2	22.4	22.2	22.7	20.0	17.1	14.0	10.0	(27)	
		MCDB	11.1	12.5	16.3	23.1	26.1	28.7	29.4	27.7	24.5	19.6	14.6	10.1	(28)	
	2%	WB	8.0	8.1	10.1	13.9	17.6	20.5	20.9	21.3	18.7	15.4	11.6	8.4	(29)	
		MCDB	8.8	10.0	14.2	20.8	23.6	26.3	27.9	27.3	23.5	18.0	13.0	9.1	(30)	
	5%	WB	6.2	6.7	9.1	12.7	16.2	19.4	20.0	20.1	17.6	14.2	10.0	6.9	(31)	
		MCDB	7.1	8.4	12.5	18.8	21.5	25.2	26.4	26.6	22.0	16.3	11.2	7.5	(32)	
	10%	WB	4.4	5.4	7.8	11.7	15.0	18.3	19.1	19.1	16.5	12.8	8.7	5.5	(33)	
		MCDB	5.1	6.8	10.3	17.0	19.9	23.4	24.7	24.9	20.0	14.4	9.6	6.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.4	7.8	9.7	12.2	11.9	11.4	11.8	12.5	11.3	8.8	6.1	5.1	(35)	
		MCDBR	7.1	11.1	15.4	17.7	16.9	16.2	16.7	16.8	14.9	12.1	9.3	6.9	(36)	
	5% WB	MCWBR	5.9	8.0	9.6	9.5	8.5	7.8	6.9	7.3	8.3	8.4	7.2	5.9	(37)	
		MCWBR	6.9	9.9	13.4	15.9	14.8	14.4	14.4	14.7	13.2	11.4	8.4	6.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.300	0.322	0.359	0.392	0.399	0.400	0.409	0.403	0.375	0.351	0.325	0.298	(40)	
		taud	2.424	2.374	2.328	2.269	2.278	2.303	2.274	2.312	2.367	2.427	2.460	2.437	(41)	
	Edh at Noon		760	824	847	853	861	860	845	833	821	779	721	710	(42)	
			64	84	105	123	127	125	127	117	100	80	62	56	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.89	1.75	2.84	4.26	5.00	5.54	5.27	4.61	3.32	2.00	0.99	0.70	(44)	
	RadStd		0.15	0.27	0.36	0.56	0.57	0.46	0.50	0.45	0.43	0.24	0.12	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (54 neighbors)	N/A	N/A	N/A	N/A	+0.29	+0.38	N/A	N/A	+56	+20	

Nomenclature: See separate page