

FURSTENFELDBRUCK, GermanyWMO: **108580**Lat: **48.206N**Lon: **11.267E**Elev: **519**StdP: **95.24**Time Zone: **1.00 (EUC)**Period: **82-98**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-15.1	-12.1	-16.1	1.0	-14.8	-13.4	1.2	-11.7	14.7	8.5	12.7	5.8	1.2	60	0.559

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.1	29.1	18.9	27.1	18.1	25.2	17.2	19.7	27.2	18.8	25.8	17.9	24.1	3.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.0	12.9	23.3	16.1	12.2	21.8	15.2	11.5	20.7	58.3	27.3	55.4	26.0	52.5	24.2	23.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.1	9.3	7.7	-17.7	32.5	4.7	1.7	-21.1	33.7	-23.8	34.7	-26.4	35.7	-29.8	36.9		
			-17.8	21.5	4.6	1.0	-21.1	22.3	-23.8	22.9	-26.4	23.4	-29.7	24.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	8.4	-0.9	-1.2	4.0	7.5	12.1	15.1	18.2	17.5	14.1	9.6	3.1	1.1
	DBStd	7.92	5.96	5.62	4.42	3.42	3.65	3.46	3.09	3.12	3.36	3.74	4.11	4.41
	HDD10.0	1498	338	313	191	89	22	2	0	0	4	52	209	278
	HDD18.3	3706	596	546	444	326	194	108	41	53	134	271	458	536
	CDD10.0	917	0	1	6	13	87	155	255	232	126	40	2	1
	CDD18.3	82	0	0	0	0	1	11	37	27	6	0	0	0
	CDH23.3	908	0	0	0	0	24	124	404	295	58	3	0	0
	CDH26.7	213	0	0	0	0	1	18	117	73	4	0	0	0
(14) Wind	WSAvg	2.8	3.5	3.1	3.5	3.1	2.8	2.5	2.5	2.4	2.5	2.6	2.6	3.0
(15) Precipitation	PrecAvg	971	54	48	62	64	109	126	122	114	79	68	65	60
	PrecMax	1237	136	102	140	155	220	193	249	199	151	138	149	121
	PrecMin	722	3	12	20	17	10	55	22	48	23	21	0	0
	PrecStd	116	30	24	32	36	47	41	47	44	34	30	34	29
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.9	15.8	20.9	20.9	25.9	29.2	32.9	31.8	27.1	23.1	15.2	13.9
		MCWB	8.0	9.6	11.8	12.0	15.5	19.6	20.7	19.4	17.6	15.7	10.5	8.4
	2%	DB	9.9	11.6	16.2	19.0	23.8	26.8	29.9	28.8	25.1	20.0	13.0	11.8
		MCWB	6.9	7.4	9.6	11.0	14.9	17.8	19.3	18.6	17.1	14.1	9.5	8.1
	5%	DB	8.1	8.1	13.1	16.9	21.9	24.8	27.2	26.8	22.9	17.2	10.9	9.8
		MCWB	5.6	5.3	7.8	10.2	13.7	16.8	18.4	18.1	16.5	12.4	8.3	7.0
	10%	DB	6.7	6.0	10.8	14.8	19.8	22.8	25.2	24.8	20.8	15.0	9.0	7.2
		MCWB	4.5	3.9	6.8	9.3	13.2	15.9	17.5	17.3	15.4	11.7	7.2	5.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.4	9.9	12.0	12.5	16.9	20.1	21.5	20.2	18.8	16.2	11.3	10.1
		MCDB	11.9	15.6	20.6	18.8	22.7	28.0	30.3	28.1	25.1	21.6	14.6	12.8
	2%	WB	6.9	7.7	9.7	11.7	15.4	18.5	20.1	19.3	17.6	14.5	9.7	8.3
		MCDB	9.5	11.1	15.2	17.9	22.1	25.1	27.7	27.1	23.4	19.0	12.1	11.1
	5%	WB	5.6	5.4	8.4	10.4	14.2	17.3	19.1	18.4	16.7	13.0	8.6	6.8
		MCDB	7.8	7.7	12.8	15.8	20.3	23.7	26.2	25.5	22.1	16.6	10.7	9.0
	10%	WB	4.3	3.8	7.1	9.5	13.3	16.2	18.1	17.5	15.6	11.9	7.1	5.5
		MCDB	6.2	5.7	10.0	14.1	18.9	21.6	24.3	23.5	19.8	14.5	8.9	7.4
(35) Mean Daily Temperature Range	5% DB	MDBR	6.6	7.6	8.6	9.7	10.4	10.2	11.1	11.0	10.2	8.6	6.8	5.8
		MCDBR	7.7	11.5	13.3	14.9	15.0	14.4	15.6	15.4	13.7	13.1	10.1	8.9
	5% WB	MCWBR	5.6	7.9	7.9	8.5	8.0	7.3	7.0	6.8	7.3	8.0	7.2	6.3
		MCDWR	7.4	10.5	12.3	13.1	13.0	13.1	13.8	13.3	12.3	11.7	9.5	8.0
(40) Clear-Sky Solar Irradiance	taub	taub	0.297	0.321	0.354	0.389	0.398	0.403	0.406	0.400	0.377	0.347	0.317	0.292
		taud	2.451	2.384	2.344	2.273	2.282	2.302	2.286	2.323	2.366	2.443	2.480	2.467
	Ebn at Noon	Ebn at Noon	783	835	859	860	864	860	851	839	825	794	749	740
		Edh at Noon	64	85	104	124	127	126	126	117	101	80	63	56
(44) All-Sky Solar Radiation	RadAvg	1.07	1.95	3.07	4.30	4.96	5.56	5.36	4.71	3.40	2.16	1.17	0.87	(44)
	RadStd	0.14	0.26	0.38	0.57	0.57	0.49	0.49	0.47	0.41	0.26	0.15	0.11	(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
Station Only		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (86 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.37	N/A	N/A	N/A	+0.37	+0.38	N/A	N/A	+61	+20

Nomenclature: See separate page