

LINZ HOERSCHING, Austria

WMO: 110100

Lat: 48.235N

Lon: 14.188E

Elev: 1027

StdP: 14.16

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.1	17.2	7.2	8.3	13.0	12.5	10.8	18.7	29.5	43.5	26.3	40.0	5.0	90	0.524

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.0	88.1	69.1	84.6	67.7	81.7	66.4	70.8	83.6	69.2	81.3	67.6	78.3	6.8	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.6	101.7	74.8	65.2	96.8	73.0	64.1	93.1	71.8	35.3	83.9	33.8	81.3	32.6	78.6	80.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.0	19.8	17.0	6.3	93.8	6.4	2.7	1.7	95.7	-2.1	97.3	-5.7	98.9	-10.3	100.8
			5.8	74.1	6.2	2.0	1.4	75.6	-2.2	76.7	-5.7	77.9	-10.2	79.4
				DB										
				WB										

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	50.1	30.9	34.2	41.9	51.0	59.1	65.2	68.1	67.4	58.9	50.0	40.4	32.9	(6)
(7)		DBStd	14.84	7.78	7.83	7.09	7.34	6.51	6.71	5.72	5.87	5.85	6.42	6.56	7.14	(7)
(8)		HDD50	2293	593	444	262	76	6	0	0	0	3	82	295	532	(8)
(9)		HDD65	5821	1058	863	717	422	205	81	35	42	197	467	737	997	(9)
(10)		CDD50	2319	1	0	10	105	287	455	562	540	271	81	7	0	(10)
(11)		CDD65	371	0	0	0	1	21	86	131	117	15	0	0	0	(11)
(12)		CDH74	3400	0	0	0	38	238	780	1179	1039	124	2	0	0	(12)
(13)		CDH80	1028	0	0	0	3	43	226	395	343	18	0	0	0	(13)
(14)	Wind	WSAvg	6.8	7.4	7.3	8.2	7.3	7.0	6.4	6.3	5.8	6.1	6.0	6.6	6.9	(14)
(15)	Precipitation	PrecAvg	38.3	2.3	2.0	3.0	2.4	4.0	4.5	4.6	4.3	3.4	2.7	2.5	2.5	(15)
(16)		PrecMax	50.2	4.8	4.8	5.6	5.8	9.8	10.5	9.9	13.5	6.8	5.5	5.7	4.8	(16)
(17)		PrecMin	28.9	0.3	0.6	0.7	0.4	0.8	2.0	1.2	1.4	1.3	0.7	0.2	0.7	(17)
(18)		PrecStd	4.5	1.2	1.1	1.4	1.3	2.0	1.7	2.0	2.1	1.3	1.3	1.1	1.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.8	56.1	66.5	78.8	84.3	90.0	92.8	93.2	82.4	72.2	62.5	52.1	(19)
(20)			MCWB	47.8	47.8	52.5	60.1	65.9	70.0	70.3	69.1	66.4	59.7	53.0	47.4	(20)
(21)		2%	DB	48.5	52.0	61.7	73.4	80.4	86.0	88.1	87.8	77.4	66.3	56.5	47.9	(21)
(22)			MCWB	44.5	46.0	50.5	57.6	64.2	69.2	69.5	68.4	64.0	58.0	51.1	44.6	(22)
(23)		5%	DB	44.5	48.4	57.3	69.0	76.0	82.3	84.4	83.8	73.5	62.7	53.2	44.5	(23)
(24)			MCWB	41.6	43.7	48.4	55.6	62.0	66.8	68.0	67.2	62.7	56.3	49.3	42.2	(24)
(25)		10%	DB	41.0	44.7	53.4	64.7	72.0	78.7	80.7	80.2	69.8	59.4	49.4	41.6	(25)
(26)			MCWB	39.0	41.4	46.5	53.5	59.8	65.2	66.5	66.0	60.7	55.0	46.8	39.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.1	49.4	54.3	60.8	68.2	73.4	73.0	71.9	67.6	61.7	54.8	48.1	(27)
(28)			MDCB	53.2	54.5	63.1	75.1	79.3	85.7	86.4	86.0	77.5	68.3	59.8	51.2	(28)
(29)		2%	WB	44.8	46.4	51.5	58.5	65.3	70.2	70.9	69.8	65.4	59.4	52.0	44.9	(29)
(30)			MDCB	48.0	51.0	59.2	71.3	77.3	81.9	83.7	83.8	75.2	64.2	56.2	47.2	(30)
(31)		5%	WB	41.7	44.0	49.5	56.5	63.0	68.2	69.3	68.2	63.8	57.5	49.3	42.2	(31)
(32)			MDCB	43.9	47.6	56.1	67.0	73.6	78.9	81.3	80.3	71.8	61.9	52.3	43.9	(32)
(33)		10%	WB	38.9	41.4	47.3	54.4	61.1	66.5	67.6	66.8	62.0	55.5	46.9	39.9	(33)
(34)			MDCB	40.7	44.2	52.5	63.3	70.2	76.4	77.8	77.3	68.5	59.3	49.0	41.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.9	12.0	15.4	18.3	18.2	18.2	19.0	18.8	16.4	14.0	9.5	8.3	(35)
(36)			MCDBR	13.2	18.2	23.9	26.9	25.6	24.9	26.1	25.9	22.9	19.3	15.8	12.9	(36)
(37)			MCWBR	9.8	12.3	13.9	13.1	11.5	10.1	9.6	9.4	10.6	11.4	10.7	9.9	(37)
(38)		5% WB	MCDBR	12.7	16.7	22.0	24.5	23.4	22.5	23.2	23.2	20.2	17.5	14.3	12.2	(38)
(39)			MCWBR	9.9	11.6	13.4	12.4	11.0	9.8	9.2	9.3	10.1	11.1	10.3	9.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.298	0.323	0.363	0.398	0.406	0.409	0.417	0.411	0.383	0.352	0.326	0.297	(40)	
(41)		taud	2.397	2.348	2.306	2.264	2.281	2.304	2.285	2.318	2.367	2.439	2.465	2.445	(41)	
(42)		Ebn at Noon	246	263	269	270	272	271	267	263	259	250	233	232	(42)	
(43)		Edh at Noon	21	28	34	40	41	40	40	37	32	26	20	18	(43)	
(44)	All-Sky Solar Radiation	RadAvg	336	620	953	1352	1564	1714	1672	1485	1064	683	357	266	(44)	
(45)		RadStd	49	81	117	163	183	151	160	157	138	74	43	32	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (104 neighbors)	+0.94	N/A	N/A	N/A	+0.70	+0.61	N/A	-256	+128	+54

Nomenclature: See separate page