

LINZ HOERSCHING, Austria

WMO: 110100

Lat: 48.235N

Lon: 14.188E

Elev: 313

StdP: 97.62

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.1	-8.2	-13.8	1.2	-10.6	-10.8	1.5	-7.4	13.2	6.4	11.8	4.5	2.2	90	0.524

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.5	31.2	20.6	29.2	19.8	27.6	19.1	21.6	28.7	20.7	27.4	19.8	25.7	3.0	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.2	14.5	23.8	18.4	13.8	22.8	17.8	13.3	22.1	64.2	28.8	60.8	27.4	57.8	25.9	26.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.3	8.8	7.6	DB	-14.3	34.3	3.6	1.5	-16.8	35.4	-18.9	36.3	-20.9	37.1	-23.5	38.2	(4)
(5)			WB	-14.5	23.4	3.4	1.1	-17.0	24.2	-19.0	24.9	-20.9	25.5	-23.4	26.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.0	-0.6	1.2	5.5	10.5	15.0	18.4	20.1	19.7	15.0	10.0	4.7	0.5	(6)	
	DBStd	8.25	4.32	4.35	3.94	4.08	3.62	3.73	3.18	3.26	3.25	3.57	3.64	3.97	(7)	
	HDD10.0	1274	329	247	146	42	3	0	0	0	2	46	164	296	(8)	
	HDD18.3	3234	588	479	398	234	114	45	19	23	109	259	409	554	(9)	
	CDD10.0	1288	1	0	6	58	159	253	312	300	151	45	4	0	(10)	
	CDD18.3	206	0	0	0	1	12	48	73	65	8	0	0	0	(11)	
	CDH23.3	1889	0	0	0	21	132	433	655	577	69	1	0	0	(12)	
	CDH26.7	571	0	0	0	2	24	126	219	191	10	0	0	0	(13)	
(14) Wind	WSAvg	3.0	3.3	3.3	3.7	3.3	3.1	2.9	2.8	2.6	2.7	2.7	3.0	3.1	(14)	
(15) Precipitation	PrecAvg	973	59	52	75	61	101	115	118	110	86	68	64	63	(15)	
	PrecMax	1275	121	122	142	148	250	266	252	344	172	140	145	123	(16)	
	PrecMin	734	7	14	18	9	20	52	31	35	33	17	4	18	(17)	
	PrecStd	115	30	29	35	32	52	42	50	53	33	34	29	29	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.1	13.4	19.2	26.0	29.1	32.2	33.8	34.0	28.0	22.3	16.9	11.2	(19)	
		MCWB	8.8	8.8	11.4	15.6	18.9	21.1	21.3	20.6	19.1	15.4	11.6	8.6	(20)	
	2%	DB	9.2	11.1	16.5	23.0	26.9	30.0	31.1	31.0	25.2	19.1	13.6	8.8	(21)	
		MCWB	6.9	7.8	10.3	14.2	17.9	20.6	20.8	20.2	17.8	14.5	10.6	7.0	(22)	
	5%	DB	6.9	9.1	14.1	20.6	24.5	27.9	29.1	28.8	23.0	17.1	11.8	7.0	(23)	
		MCWB	5.3	6.5	9.1	13.1	16.7	19.3	20.0	19.5	17.0	13.5	9.6	5.7	(24)	
	10%	DB	5.0	7.1	11.9	18.2	22.2	25.9	27.1	26.8	21.0	15.2	9.7	5.3	(25)	
		MCWB	3.9	5.2	8.1	12.0	15.4	18.5	19.2	18.9	15.9	12.8	8.2	4.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.5	9.7	12.4	16.0	20.1	23.0	22.8	22.1	19.8	16.5	12.6	8.9	(27)	
		MCDB	11.8	12.5	17.3	24.0	26.3	29.8	30.2	30.0	25.3	20.1	15.5	10.7	(28)	
	2%	WB	7.1	8.0	10.8	14.7	18.5	21.2	21.6	21.0	18.6	15.2	11.1	7.1	(29)	
		MCDB	8.9	10.6	15.1	21.8	25.2	27.7	28.7	28.8	24.0	17.9	13.4	8.4	(30)	
	5%	WB	5.4	6.7	9.7	13.6	17.2	20.1	20.7	20.1	17.6	14.2	9.6	5.7	(31)	
		MCDB	6.6	8.7	13.4	19.5	23.1	26.1	27.4	26.8	22.1	16.6	11.3	6.6	(32)	
	10%	WB	3.8	5.2	8.5	12.4	16.2	19.2	19.8	19.3	16.7	13.0	8.3	4.4	(33)	
		MCDB	4.8	6.8	11.4	17.4	21.2	24.6	25.5	25.2	20.3	15.2	9.4	5.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.9	6.7	8.5	10.2	10.1	10.1	10.5	10.4	9.1	7.8	5.3	4.6	(35)	
		MCDBR	7.3	10.1	13.3	14.9	14.2	13.8	14.5	14.4	12.7	10.7	8.8	7.2	(36)	
	5% WB	MCWBR	5.5	6.8	7.7	7.3	6.4	5.6	5.3	5.2	5.9	6.4	6.0	5.5	(37)	
		MCWBR	7.1	9.3	12.2	13.6	13.0	12.5	12.9	12.9	11.2	9.7	7.9	6.8	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.298	0.323	0.363	0.398	0.406	0.409	0.417	0.411	0.383	0.352	0.326	0.297	(40)	
		taud	2.397	2.348	2.306	2.264	2.281	2.304	2.285	2.318	2.367	2.439	2.465	2.445	(41)	
	Edn at Noon	Edn at Noon	774	829	848	851	857	854	841	829	818	788	735	730	(42)	
		Edh at Noon	67	88	108	125	128	126	126	117	101	81	64	57	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.06	1.96	3.00	4.26	4.93	5.40	5.27	4.68	3.35	2.15	1.13	0.84	(44)	
	RadStd	RadStd	0.15	0.26	0.37	0.52	0.58	0.47	0.50	0.49	0.44	0.23	0.14	0.10	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (104 neighbors)		+0.52	N/A	N/A	N/A	+0.39	+0.34	N/A	-142	+71	+30	

Nomenclature: See separate page