

AMSTETTEN, Austria

WMO: 110180

Lat: 48.109N

Lon: 14.895E

Elev: 264

StdP: 98.19

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.5	-8.3	-13.9	1.2	-10.9	-10.7	1.5	-7.3	8.4	4.9	7.6	4.1	1.8	280	0.476

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	31.1	21.0	29.1	20.3	27.5	19.5	22.0	29.0	21.0	27.5	20.2	26.0	2.2	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.7	14.9	24.6	18.8	14.1	23.6	18.1	13.4	22.9	65.3	29.1	61.9	27.6	59.0	26.2	25.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.0	6.1	5.4	-14.1	34.5	4.1	1.4	-17.1	35.5	-19.5	36.4	-21.8	37.2	-24.8	38.3		
(5)			-14.4	24.1	3.9	0.9	-17.2	24.7	-19.5	25.3	-21.7	25.8	-24.6	26.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.1	-0.5	1.4	5.4	10.6	15.0	18.6	20.0	19.7	14.9	10.1	5.1	0.8	(6)
(7)		DBStd	8.18	4.40	4.22	4.03	3.94	3.65	3.67	3.26	3.19	3.30	3.68	3.78	4.12	(7)
(8)		HDD10.0	1243	327	241	147	39	4	1	0	0	2	46	153	284	(8)
(9)		HDD18.3	3197	586	473	399	232	116	41	20	23	110	256	398	543	(9)
(10)		CDD10.0	1294	1	0	6	58	158	258	311	299	150	48	6	0	(10)
(11)		CDD18.3	206	0	0	0	1	11	49	73	64	8	0	0	0	(11)
(12)		CDH23.3	1861	0	0	0	22	122	434	650	563	68	2	0	0	(12)
(13)		CDH26.7	553	0	0	0	2	19	124	212	186	9	0	0	0	(13)
(14)	Wind	WSAvg	2.3	2.8	2.6	2.6	2.4	2.2	2.0	2.0	1.8	1.9	2.2	2.5	2.6	(14)
(15)	Precipitation	PrecAvg	1038	64	60	82	67	107	115	128	114	95	68	68	66	(15)
(16)		PrecMax	1326	126	156	145	155	240	282	251	351	220	150	118	117	(16)
(17)		PrecMin	739	6	14	29	8	24	40	51	31	41	7	6	21	(17)
(18)		PrecStd	143	33	36	34	32	52	49	55	63	43	37	28	25	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.4	13.5	19.6	26.1	28.7	32.2	33.9	34.1	27.8	22.3	17.4	11.7	(19)
(20)			MCWB	8.8	8.8	11.9	16.1	18.8	21.7	21.7	20.7	19.8	16.0	12.5	8.9	(20)
(21)		2%	DB	9.3	11.3	16.6	22.8	26.6	29.9	31.1	30.9	25.3	19.2	14.4	8.9	(21)
(22)			MCWB	7.0	7.8	10.5	14.3	18.4	20.8	21.1	20.8	18.6	14.7	11.2	6.9	(22)
(23)		5%	DB	7.1	9.1	14.2	20.6	24.5	27.8	28.9	28.5	23.1	17.3	12.1	7.2	(23)
(24)			MCWB	5.3	6.3	9.2	13.1	17.1	19.5	20.2	20.3	17.6	13.9	10.1	5.8	(24)
(25)		10%	DB	5.2	7.2	11.8	18.4	22.3	25.8	27.0	26.5	20.9	15.5	10.1	5.7	(25)
(26)			MCWB	3.9	5.1	8.1	12.1	15.9	18.6	19.5	19.5	16.4	13.2	8.7	4.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.4	9.7	12.5	16.6	20.2	23.0	23.2	23.1	20.5	17.0	13.0	9.1	(27)
(28)			MCDWB	12.0	12.8	18.3	24.5	26.8	29.6	30.3	30.3	25.9	20.2	16.7	11.0	(28)
(29)		2%	WB	7.2	8.0	10.9	14.9	18.8	21.5	21.9	21.7	19.2	15.4	11.6	7.4	(29)
(30)			MCDWB	9.1	10.9	15.5	21.6	25.1	28.4	29.0	28.6	24.3	18.1	13.9	8.7	(30)
(31)		5%	WB	5.6	6.5	9.8	13.6	17.7	20.3	20.9	20.7	18.1	14.5	10.0	5.8	(31)
(32)			MCDWB	7.0	8.8	13.3	19.6	23.4	26.3	27.4	27.0	22.1	16.7	11.9	7.1	(32)
(33)		10%	WB	4.0	5.2	8.6	12.5	16.5	19.3	20.1	19.9	16.9	13.4	8.7	4.7	(33)
(34)			MCDWB	5.0	7.0	11.5	17.5	21.4	24.4	25.8	25.6	20.1	15.4	10.1	5.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.7	6.4	8.6	10.6	10.1	10.3	10.6	10.8	9.2	7.6	5.0	4.4	(35)
(36)			MCDBR	7.0	10.4	13.9	15.5	14.3	14.2	14.5	14.9	13.0	10.9	8.7	7.1	(36)
(37)			MCWBR	5.1	6.9	7.9	7.7	6.7	5.9	5.6	6.1	6.6	6.5	5.6	5.4	(37)
(38)		5% WB	MCDWB	6.9	9.9	12.8	14.3	13.4	13.1	13.2	13.6	11.9	9.8	8.0	6.8	(38)
(39)			MCWBR	5.2	6.8	7.5	7.3	6.5	5.9	5.4	6.1	6.4	6.2	5.5	5.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.306	0.335	0.379	0.420	0.426	0.430	0.437	0.431	0.401	0.366	0.336	0.306	(40)	
(41)		taud	2.371	2.308	2.248	2.190	2.221	2.248	2.234	2.266	2.315	2.390	2.420	2.416	(41)	
(42)		Ebn at Noon	761	813	829	829	839	835	823	810	798	769	718	716	(42)	
(43)		Edh at Noon	69	92	115	135	136	133	133	124	107	85	67	60	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.07	1.95	3.00	4.24	4.90	5.35	5.24	4.67	3.35	2.17	1.15	0.87	(44)	
(45)		RadStd	0.15	0.25	0.36	0.49	0.56	0.45	0.50	0.50	0.43	0.23	0.14	0.11	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (100 neighbors)		+0.52	N/A	N/A	N/A	+0.42	+0.39	-115	-145	+77	+33

Nomenclature: See separate page