

STIFT ZWETTL, Austria

WMO: 110200

Lat: 48.618N

Lon: 15.204E

Elev: 1658

StdP: 13.84

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.2	11.0	0.4	5.9	4.7	6.9	8.3	12.7	10.4	38.5	9.5	37.8	1.6	230	0.504

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.2	84.3	67.3	80.7	65.9	77.4	64.0	69.1	80.4	67.3	77.7	65.6	75.0	3.4	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.5	100.3	73.8	63.7	94.0	71.5	62.1	88.5	69.9	34.2	80.8	32.7	77.6	31.3	75.4	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.8	7.4	6.2	DB	-1.6	90.6	8.9	3.1	-8.0	92.8	-13.2	94.7	-18.3	96.4	-24.8	98.6	(4)
(5)			WB	-1.8	72.6	8.1	2.4	-7.6	74.3	-12.3	75.7	-16.9	77.0	-22.8	78.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.0	27.7	30.9	37.0	46.0	53.9	60.5	63.5	62.5	54.1	46.1	37.9	30.4	(6)	
	DBStd	14.24	8.58	8.47	7.39	6.75	5.99	6.20	5.44	5.58	5.71	6.51	6.53	8.05	(7)	
	HDD50	2965	691	534	405	153	30	3	0	1	24	153	364	607	(8)	
	HDD65	7060	1156	954	869	571	346	161	94	114	327	584	812	1072	(9)	
	CDD50	1492	0	0	1	32	150	317	420	389	148	34	1	0	(10)	
	CDD65	115	0	0	0	0	2	26	49	37	1	0	0	0	(11)	
	CDH74	1563	0	0	0	11	65	368	574	505	40	0	0	0	(12)	
	CDH80	388	0	0	0	1	6	84	154	141	2	0	0	0	(13)	
(14) Wind	WSAvg	2.3	2.7	2.6	2.6	2.5	2.4	2.2	2.3	2.0	2.0	2.1	2.2	2.4	(14)	
(15) Precipitation	PrecAvg	30.3	1.7	1.5	2.1	2.0	3.4	3.9	4.0	3.8	2.6	2.0	1.9	1.7	(15)	
	PrecMax	43.0	3.6	3.1	4.1	3.6	6.9	8.2	7.6	13.7	6.9	4.7	3.0	3.4	(16)	
	PrecMin	22.3	0.4	0.4	0.6	0.2	0.9	1.7	1.3	1.3	0.6	0.4	0.2	0.5	(17)	
	PrecStd	4.4	0.8	0.8	1.0	1.0	1.4	1.4	1.4	2.4	1.3	1.1	0.7	0.6	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.4	55.5	63.4	75.0	79.5	86.9	89.4	89.4	78.7	68.7	59.1	51.1	(19)	
		MCWB	45.4	45.7	49.7	57.2	62.8	68.3	68.6	68.4	63.8	57.6	51.9	46.1	(20)	
	2%	DB	46.5	50.4	58.0	69.6	75.5	82.1	84.2	83.7	73.9	63.8	54.0	47.2	(21)	
		MCWB	41.9	43.6	47.2	55.1	61.3	66.5	67.4	66.8	62.0	56.1	49.1	43.2	(22)	
	5%	DB	42.7	46.5	53.1	64.8	72.0	78.2	80.1	79.7	69.5	60.2	50.6	43.6	(23)	
		MCWB	39.2	41.5	45.0	52.3	59.3	64.4	65.9	65.6	59.8	54.2	47.0	40.4	(24)	
	10%	DB	39.2	42.5	48.9	60.7	67.9	74.4	76.5	75.6	65.5	56.9	47.5	40.4	(25)	
		MCWB	36.5	38.3	42.9	50.2	57.1	62.6	64.3	63.5	58.0	52.7	45.0	37.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.0	46.8	50.4	58.6	65.6	71.4	71.7	71.3	65.4	59.4	52.6	46.6	(27)	
		MCDB	50.5	53.3	60.9	72.9	76.4	81.8	82.7	82.5	75.0	65.7	56.9	50.2	(28)	
	2%	WB	42.2	44.1	48.1	55.8	62.7	68.1	69.2	68.6	63.0	57.0	49.8	43.6	(29)	
		MCDB	45.9	49.6	56.1	67.4	72.9	78.4	80.5	80.1	71.6	61.7	53.1	46.8	(30)	
	5%	WB	39.5	41.4	45.9	53.4	60.4	66.0	67.3	66.7	61.0	55.1	47.5	40.5	(31)	
		MCDB	42.7	46.2	52.2	62.6	69.9	75.6	77.4	77.1	67.8	59.5	50.0	43.2	(32)	
	10%	WB	36.7	38.7	43.5	51.1	58.1	63.9	65.4	64.8	59.0	53.1	45.1	38.2	(33)	
		MCDB	39.0	42.2	48.4	59.4	66.0	72.3	74.4	73.5	64.5	56.7	47.4	40.3	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.5	13.5	16.4	21.0	21.0	21.3	21.2	21.8	18.5	15.8	10.6	9.9	(35)	
		MCDBR	14.3	19.9	25.9	30.8	29.5	29.5	29.5	30.3	26.4	22.6	17.2	15.2	(36)	
	5% WB	MCWBR	10.9	13.5	16.2	16.9	15.7	14.7	14.0	14.4	15.4	15.1	12.8	12.0	(37)	
		MCWBR	14.0	18.9	23.7	27.7	27.4	26.3	26.5	27.2	23.7	20.6	15.2	14.3	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.294	0.317	0.357	0.396	0.399	0.403	0.411	0.407	0.380	0.350	0.323	0.294	(40)	
		taud	2.389	2.360	2.311	2.251	2.281	2.302	2.278	2.307	2.353	2.416	2.444	2.442	(41)	
	Ebn at Noon		245	265	270	270	273	272	268	264	260	249	232	231	(42)	
		Edh at Noon	21	27	34	40	40	40	40	37	32	26	20	18	(43)	
(44) All-Sky Solar Radiation	RadAvg		313	594	928	1365	1583	1728	1667	1485	1059	654	330	246	(44)	
	RadStd		51	79	122	169	184	152	163	149	137	77	35	27	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (95 neighbors)		+0.92	N/A	N/A	N/A	+0.70	+0.59	N/A	-263	+130	+58	

Nomenclature: See separate page