

LITSCHAU, Austria

WMO: 110210

Lat: 48.955N

Lon: 15.038E

Elev: 557

StdP: 94.81

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.3	-10.7	-16.8	0.9	-13.4	-13.4	1.3	-9.9	5.3	0.5	4.7	-1.2	0.8	110	0.497

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	29.2	19.4	27.2	18.6	25.3	17.6	20.2	26.9	19.2	25.5	18.4	24.0	1.6	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.1	13.9	22.6	17.2	13.1	21.4	16.3	12.4	20.7	60.5	26.8	57.1	25.7	54.2	24.1	23.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
4.4	3.9	3.4	-18.3	32.4	3.9	2.0	-21.1	33.8	-23.4	35.0	-25.6	36.1	-28.4	37.5		
			-18.5	21.9	3.8	1.1	-21.2	22.6	-23.5	23.3	-25.6	23.9	-28.3	24.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.9	-2.3	-0.8	2.8	7.9	12.5	15.9	17.7	17.6	12.7	8.1	3.1	-0.8
	DBStd	8.17	4.76	4.83	4.19	4.36	3.79	3.82	3.36	3.49	3.59	3.91	3.87	4.43
	HDD10.0	1657	383	303	223	88	18	2	0	1	13	85	207	333
	HDD18.3	3892	641	537	481	312	184	92	53	56	172	318	456	592
	CDD10.0	898	0	0	1	27	96	179	239	236	95	25	1	0
	CDD18.3	91	0	0	0	0	3	19	34	33	3	0	0	0
	CDH23.3	908	0	0	0	4	28	191	333	323	29	0	0	0
	CDH26.7	225	0	0	0	0	2	41	89	89	3	0	0	0
Wind	WSAvg	1.4	1.6	1.6	1.6	1.5	1.5	1.3	1.3	1.2	1.2	1.4	1.5	1.5
Precipitation	PrecAvg	700	39	32	47	44	78	92	93	87	61	46	43	37
	PrecMax	1038	90	79	99	82	174	188	186	323	165	121	80	77
	PrecMin	531	5	4	14	2	19	33	30	23	7	7	1	6
	PrecStd	111	20	21	23	23	32	39	34	59	32	27	20	16
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.6	12.8	17.3	23.4	26.1	30.1	31.9	32.2	26.6	20.6	14.3	10.2
		MCWB	7.0	6.7	10.0	14.3	16.9	19.7	19.9	20.0	17.9	14.3	10.9	7.7
	2%	DB	7.9	9.7	14.2	20.3	23.8	27.7	29.1	29.1	23.6	17.6	11.9	8.0
		MCWB	5.4	6.1	8.5	12.7	16.1	19.0	19.3	19.3	16.6	13.4	9.6	6.4
	5%	DB	6.0	7.6	11.7	17.9	21.9	25.5	26.9	26.9	21.1	15.6	10.3	6.5
		MCWB	4.3	5.1	7.3	11.4	15.3	17.6	18.5	18.5	15.6	12.3	8.6	5.0
	10%	DB	4.0	5.6	9.2	15.7	19.9	23.4	24.9	24.7	19.0	13.8	8.6	4.9
		MCWB	2.9	3.5	6.1	10.3	14.0	16.7	17.8	17.4	14.6	11.6	7.4	3.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.4	8.2	10.5	15.0	18.1	21.3	21.5	21.6	18.4	15.1	11.5	8.1
		MCDB	9.5	11.5	15.6	22.1	23.5	27.8	27.9	28.8	24.5	18.5	13.5	9.5
	2%	WB	5.8	6.5	9.1	13.3	16.8	19.7	20.2	20.1	17.1	13.8	10.0	6.6
		MCDB	7.5	9.0	13.1	19.4	22.5	25.8	26.5	27.2	22.4	16.7	11.5	7.9
	5%	WB	4.3	5.2	7.9	12.0	15.7	18.5	19.2	19.0	16.1	12.9	8.8	5.1
		MCDB	5.8	7.6	11.0	16.8	20.7	24.0	25.3	25.3	20.3	15.1	10.0	6.3
	10%	WB	2.9	3.7	6.6	10.8	14.6	17.4	18.3	18.1	15.1	11.9	7.5	3.8
		MCDB	4.0	5.5	8.9	15.1	18.9	22.2	23.7	23.6	18.1	13.6	8.5	4.8
Mean Daily Temperature Range	5% DB	MDBR	4.9	6.7	8.1	10.0	9.9	10.4	10.6	10.8	9.1	7.3	4.9	4.7
		MCDBR	7.2	10.1	13.3	13.6	13.0	13.9	14.3	14.7	12.9	10.3	8.2	7.4
	5% WB	MCWBR	5.5	6.7	8.0	7.1	6.3	6.1	5.8	6.0	6.5	6.3	5.8	5.7
		MCDWR	6.6	9.5	11.8	12.4	11.7	12.3	12.4	13.4	11.3	9.3	7.0	7.1
Clear-Sky Solar Irradiance	taub		0.293	0.315	0.355	0.394	0.397	0.399	0.409	0.404	0.376	0.347	0.321	0.292
		taud	2.390	2.365	2.312	2.250	2.280	2.304	2.277	2.307	2.355	2.414	2.440	2.440
	Ebn at Noon		770	834	853	852	864	862	846	833	821	784	728	724
		Edh at Noon	66	85	106	126	127	125	127	118	101	81	63	56
All-Sky Solar Radiation	RadAvg		0.96	1.84	2.88	4.27	5.00	5.45	5.23	4.66	3.31	2.01	1.00	0.74
	RadStd		0.16	0.24	0.40	0.54	0.58	0.46	0.52	0.47	0.43	0.25	0.12	0.09

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
Station Only	+0.60	N/A	N/A	+1.05	+0.65	+0.51	N/A	N/A	N/A	N/A	
Regional (88 neighbors)	+0.51	N/A	N/A	N/A	+0.38	+0.34	N/A	N/A	+70	+30	

Nomenclature: See separate page