

JAUERLING, Austria

WMO: 110240

Lat: 48.334N

Lon: 15.339E

Elev: 961

StdP: 90.31

Time Zone: 1.00 (EUC)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -13.0	(c) -11.0	(d) -17.0	(e) 1.0	(f) -9.9	(g) -14.0	(h) 1.3	(i) -8.8	(j) 15.3	(k) 0.8	(l) 13.8	(m) 0.0	(n) 3.6	(o) 310	(p) 0.655

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.4	26.1	18.2	24.2	17.5	22.7	16.7	19.1	24.4	18.1	23.1	17.2	21.8	3.6	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.1	13.8	22.1	16.2	12.9	20.8	15.3	12.2	20.0	58.6	24.4	55.2	23.3	52.3	21.9	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 12.0	(b) 10.5	(c) 9.3	(e) -14.4	(f) 28.6	(g) 3.2	(h) 2.2	(i) -16.7	(j) 30.2	(k) -18.6	(l) 31.5	(m) -20.3	(n) 32.7	(o) -22.7	(p) 34.3		
(a) 12.0	(b) 10.5	(c) 9.3	(e) -15.3	(f) 21.0	(g) 3.0	(h) 1.2	(i) -17.5	(j) 21.9	(k) -19.2	(l) 22.6	(m) -20.9	(n) 23.3	(o) -23.1	(p) 24.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.0	-2.9	-1.3	1.7	6.8	11.0	14.6	16.2	16.3	11.5	7.5	2.7	-1.0
	DBStd	8.10	4.88	5.19	4.91	4.78	4.16	4.20	3.90	3.84	3.98	4.67	4.69	4.83
	HDD10.0	1839	399	317	259	117	39	8	2	2	29	106	223	339
	HDD18.3	4209	657	550	515	347	229	126	88	86	207	336	469	598
	CDD10.0	736	0	0	2	19	69	145	196	198	74	28	3	0
	CDD18.3	64	0	0	0	0	2	13	23	24	2	0	0	0
	CDH23.3	258	0	0	0	0	3	48	93	110	4	0	0	0
	CDH26.7	38	0	0	0	0	0	6	12	20	1	0	0	0
Wind	WSAvg	4.7	5.4	5.4	5.1	4.5	4.4	4.0	4.3	4.1	4.3	4.9	5.0	5.2
Precipitation	PrecAvg	665	32	29	43	43	76	90	90	85	58	45	38	34
	PrecMax	896	71	67	99	99	160	227	179	279	154	95	70	67
	PrecMin	455	3	3	8	1	18	44	30	26	21	7	0	8
	PrecStd	106	17	18	24	25	36	38	38	52	28	25	16	16
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.5	11.5	15.2	20.5	23.0	27.2	28.2	29.1	23.3	19.6	15.0	11.4
		MCWB	5.2	5.5	8.4	12.8	15.3	18.7	18.8	18.2	16.7	13.2	9.1	5.8
	2%	DB	8.0	9.1	12.6	17.6	21.0	24.6	25.7	26.2	20.8	17.2	12.7	8.8
		MCWB	4.1	4.2	7.0	11.3	14.9	18.0	18.3	18.0	15.7	12.0	8.1	4.9
	5%	DB	6.0	7.4	10.5	15.3	19.3	22.7	24.0	24.1	18.9	15.4	11.0	7.1
		MCWB	3.3	3.6	6.0	10.0	14.0	16.9	17.5	17.3	14.6	11.2	7.3	4.1
	10%	DB	4.0	5.7	8.3	13.5	17.5	21.0	22.3	22.2	17.2	13.8	9.3	5.5
		MCWB	2.0	2.7	4.9	8.9	12.8	15.8	16.7	16.5	13.7	10.7	6.6	3.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.9	6.5	8.9	13.2	17.1	20.1	20.6	20.3	17.5	14.4	10.2	6.7
		MCDB	8.8	9.5	13.9	19.1	21.6	25.0	25.5	25.7	21.5	17.5	13.3	9.5
	2%	WB	4.8	5.1	7.5	11.7	15.5	18.6	19.0	18.9	16.1	12.8	9.0	5.6
		MCDB	6.9	8.0	11.6	16.6	19.8	23.4	24.4	24.4	20.0	15.9	11.8	7.8
	5%	WB	3.5	4.1	6.4	10.5	14.3	17.4	18.0	17.9	15.0	11.9	7.9	4.6
		MCDB	5.7	6.6	9.6	14.9	18.5	21.9	23.1	23.0	18.4	14.4	10.3	6.7
	10%	WB	2.1	3.0	5.3	9.2	13.2	16.2	17.1	16.9	14.0	10.9	6.8	3.3
		MCDB	4.0	5.5	8.0	12.9	16.9	20.3	21.6	21.6	16.7	13.4	8.9	5.2
Mean Daily Temperature Range	5% DB	MDBR	4.1	4.5	5.3	6.7	6.7	6.7	6.7	6.4	5.4	5.1	4.3	4.2
		MCDBR	6.3	6.4	7.8	8.4	8.7	8.4	8.9	8.5	7.3	7.0	6.6	6.7
		MCWBR	4.2	4.1	4.8	5.1	5.3	5.1	4.7	4.7	4.6	4.2	3.9	4.4
	5% WB	MCDBR	5.8	5.9	7.2	7.8	8.2	7.7	7.9	7.7	6.9	6.3	5.8	6.2
		MCWBR	4.3	4.2	4.7	4.9	5.3	5.1	4.8	4.8	4.6	4.2	4.0	4.6
Clear-Sky Solar Irradiance	taub	0.272	0.293	0.327	0.361	0.364	0.369	0.375	0.371	0.348	0.322	0.299	0.273	
	taud	2.440	2.418	2.392	2.345	2.363	2.371	2.349	2.376	2.422	2.485	2.509	2.485	
	Ebn at Noon	814	871	890	889	897	892	880	868	856	825	775	770	
	Edh at Noon	63	81	99	115	117	117	118	110	95	76	60	54	
All-Sky Solar Radiation	RadAvg	1.03	1.91	2.97	4.28	4.95	5.41	5.25	4.68	3.35	2.12	1.10	0.82	
	RadStd	0.15	0.25	0.37	0.51	0.57	0.47	0.50	0.48	0.43	0.23	0.12	0.09	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (98 neighbors)	+0.52	N/A	N/A	N/A	+0.40	+0.35	-115	-146	+72	+33

Nomenclature: See separate page