

POYSDORF, Austria

WMO: 110320

Lat: 48.669N

Lon: 16.637E

Elev: 676

StdP: 14.34

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.5	16.3	5.6	7.5	12.7	10.5	9.7	17.6	16.5	30.8	14.8	31.5	3.9	270	0.466

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.0	89.3	70.8	85.9	69.3	82.7	67.7	72.2	85.7	70.4	82.9	68.8	80.2	6.6	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.7	104.2	78.4	66.1	98.6	76.0	64.7	93.7	74.5	36.3	86.0	34.7	83.5	33.4	80.3	78.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.4	13.4	11.6	6.7	94.5	6.6	3.3	2.0	96.8	-1.9	98.8	-5.6	100.6	-10.3	103.0
			5.9	74.9	6.1	1.5	1.5	76.0	-2.1	76.9	-5.5	77.8	-10.0	78.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	50.7	30.8	34.4	41.7	51.6	59.4	66.0	69.4	68.8	59.8	50.3	41.5	33.2	(6)
(7)		DBStd	15.24	8.14	8.08	7.45	7.35	6.20	6.25	5.79	5.86	6.12	6.84	7.12	7.63	(7)
(8)		HDD50	2250	595	437	271	69	5	0	0	0	2	83	266	522	(8)
(9)		HDD65	5671	1059	856	722	403	193	63	23	28	176	456	705	987	(9)
(10)		CDD50	2495	0	1	13	118	296	480	602	584	298	92	11	0	(10)
(11)		CDD65	441	0	0	0	1	19	93	160	147	21	0	0	0	(11)
(12)		CDH74	4200	0	0	0	31	209	879	1531	1363	183	4	0	0	(12)
(13)		CDH80	1329	0	0	0	2	29	252	539	476	31	0	0	0	(13)
(14)	Wind	WSAvg	5.1	5.3	5.7	5.9	6.1	5.4	4.7	4.6	4.4	4.5	4.6	5.2	5.1	(14)
(15)	Precipitation	PrecAvg	20.8	1.0	0.9	1.4	1.4	2.3	2.6	2.9	2.4	2.0	1.4	1.4	1.2	(15)
(16)		PrecMax	27.9	2.2	2.4	3.6	3.1	5.5	4.6	8.5	5.8	6.1	3.5	3.1	2.2	(16)
(17)		PrecMin	14.3	0.1	0.1	0.2	0.2	0.7	0.8	0.6	0.6	0.4	0.2	0.1	0.3	(17)
(18)		PrecStd	3.4	0.5	0.6	0.9	0.8	1.1	1.1	1.6	1.5	1.6	0.8	0.7	0.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.1	57.0	67.2	78.2	83.5	90.5	93.4	94.2	83.8	72.7	63.4	52.8	(19)
(20)			MCWB	47.0	48.6	53.5	61.5	66.6	71.2	71.9	70.6	66.6	60.8	55.6	48.1	(20)
(21)		2%	DB	48.5	52.3	62.1	73.0	79.3	86.2	89.2	89.4	79.2	68.1	58.7	49.0	(21)
(22)			MCWB	44.1	46.2	51.0	58.8	65.0	70.3	71.1	70.3	64.6	59.3	53.3	45.3	(22)
(23)		5%	DB	44.8	48.8	57.5	68.9	76.0	82.6	85.9	85.3	75.1	64.5	54.8	45.6	(23)
(24)			MCWB	41.3	43.8	48.6	56.3	63.1	68.1	69.1	68.9	63.3	57.1	50.8	42.5	(24)
(25)		10%	DB	41.8	45.4	53.6	65.1	72.4	79.2	82.5	81.5	71.3	61.0	51.6	42.8	(25)
(26)			MCWB	38.9	41.6	47.0	54.2	60.8	66.1	67.8	67.0	61.5	55.6	48.1	40.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.8	49.3	54.6	62.5	68.4	74.1	74.8	73.5	68.3	62.3	56.4	48.7	(27)
(28)			MCD B	52.4	55.5	64.8	76.7	80.7	86.8	89.6	88.8	79.4	69.4	62.0	52.2	(28)
(29)		2%	WB	44.8	46.8	51.9	59.7	66.2	71.7	72.1	71.5	66.3	60.3	53.8	45.6	(29)
(30)			MCD B	48.2	51.5	60.1	71.3	77.6	83.7	85.8	85.2	76.0	66.2	58.0	48.7	(30)
(31)		5%	WB	41.8	44.3	49.7	57.2	64.2	69.3	70.4	69.8	64.5	58.3	51.0	42.7	(31)
(32)			MCD B	44.6	48.3	56.2	67.0	73.8	79.9	83.0	82.8	72.8	63.6	54.5	45.3	(32)
(33)		10%	WB	39.1	41.8	47.4	55.0	62.1	67.3	68.8	68.1	62.7	56.2	48.5	40.6	(33)
(34)			MCD B	41.5	45.2	53.0	63.6	70.6	77.1	80.0	79.5	70.0	60.4	51.2	42.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.2	11.9	15.2	18.7	18.7	19.5	20.0	20.0	17.2	14.8	10.2	8.5	(35)
(36)			MCDBR	12.9	17.5	22.9	25.1	24.9	24.9	25.9	26.2	23.5	19.9	15.1	12.7	(36)
(37)			MCWBR	9.9	12.0	13.2	12.7	11.8	10.6	9.8	10.1	10.6	11.5	10.2	9.5	(37)
(38)		5% WB	MCD BR	12.6	16.5	21.1	23.6	23.1	22.9	23.5	24.0	20.7	17.9	14.1	12.1	(38)
(39)			MCWBR	10.1	11.9	13.0	12.2	11.3	10.4	9.5	9.9	9.9	11.0	9.9	9.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.315	0.338	0.376	0.420	0.418	0.421	0.430	0.428	0.401	0.372	0.348	0.314	(40)	
(41)		taud	2.367	2.340	2.275	2.181	2.225	2.253	2.231	2.252	2.298	2.351	2.368	2.393	(41)	
(42)		Ebn at Noon	235	256	263	262	268	267	263	257	252	239	219	220	(42)	
(43)		Edh at Noon	22	28	35	43	43	42	42	40	34	28	22	19	(43)	
(44)	All-Sky Solar Radiation	RadAvg	291	548	915	1406	1656	1805	1726	1544	1101	649	328	228	(44)	
(45)		RadStd	40	72	130	145	184	142	173	146	141	84	32	25	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)	
(47)	Regional (81 neighbors)	+1.01	N/A	N/A	+1.44	+0.77	+0.65	-230	-301	+144	+67	(47)

Nomenclature: See separate page