

POYSDORF, Austria

WMO: 110320

Lat: 48.669N

Lon: 16.637E

Elev: 206

StdP: 98.87

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.4	-8.7	-14.7	1.1	-10.7	-11.9	1.4	-8.0	7.4	-0.7	6.6	-0.3	1.7	270	0.466

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.1	31.8	21.6	30.0	20.7	28.2	19.8	22.3	29.9	21.3	28.3	20.5	26.8	3.0	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.8	14.9	25.8	18.9	14.1	24.4	18.1	13.4	23.6	66.5	30.0	62.8	28.6	59.7	26.8	25.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.9	6.0	5.2	-14.0	34.7	3.7	1.8	-16.7	36.0	-18.8	37.1	-20.9	38.1	-23.5	39.5		
(5)			-14.5	23.8	3.4	0.9	-16.9	24.4	-18.9	24.9	-20.9	25.4	-23.3	26.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.4	-0.6	1.4	5.4	10.9	15.2	18.9	20.8	20.5	15.5	10.2	5.3	0.6	(6)
(7)		DBStd	8.46	4.52	4.49	4.14	4.09	3.44	3.47	3.21	3.25	3.40	3.80	3.96	4.24	(7)
(8)		HDD10.0	1250	331	243	151	38	3	0	0	0	1	46	148	290	(8)
(9)		HDD18.3	3151	588	476	401	224	107	35	13	16	98	253	392	548	(9)
(10)		CDD10.0	1386	0	1	7	66	164	267	334	324	166	51	6	0	(10)
(11)		CDD18.3	245	0	0	0	1	11	52	89	82	12	0	0	0	(11)
(12)		CDH23.3	2333	0	0	0	17	116	488	851	757	102	2	0	0	(12)
(13)		CDH26.7	738	0	0	0	1	16	140	299	264	17	0	0	0	(13)
(14)	Wind	WSAvg	2.3	2.4	2.5	2.7	2.7	2.4	2.1	2.1	1.9	2.0	2.1	2.3	2.3	(14)
(15)	Precipitation	PrecAvg	528	25	24	35	35	58	65	73	60	52	35	35	30	(15)
(16)		PrecMax	708	55	60	92	80	139	116	216	148	155	89	78	55	(16)
(17)		PrecMin	362	3	3	5	4	18	21	15	16	9	5	2	7	(17)
(18)		PrecStd	86	13	16	22	20	27	27	40	37	40	21	17	12	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.7	13.9	19.5	25.7	28.6	32.5	34.1	34.6	28.8	22.6	17.5	11.5	(19)
(20)			MCWB	8.4	9.2	11.9	16.4	19.2	21.8	22.2	21.4	19.2	16.0	13.1	8.9	(20)
(21)		2%	DB	9.2	11.3	16.7	22.8	26.3	30.1	31.8	31.9	26.2	20.1	14.9	9.5	(21)
(22)			MCWB	6.7	7.9	10.6	14.9	18.3	21.3	21.7	21.3	18.1	15.2	11.8	7.4	(22)
(23)		5%	DB	7.1	9.3	14.2	20.5	24.4	28.1	30.0	29.6	23.9	18.0	12.7	7.5	(23)
(24)			MCWB	5.1	6.5	9.2	13.5	17.3	20.1	20.6	20.5	17.4	13.9	10.4	5.8	(24)
(25)		10%	DB	5.4	7.4	12.0	18.4	22.4	26.2	28.0	27.5	21.8	16.1	10.9	6.0	(25)
(26)			MCWB	3.8	5.3	8.3	12.4	16.0	18.9	19.9	19.4	16.4	13.1	9.0	4.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.8	9.6	12.6	16.9	20.2	23.4	23.8	23.1	20.1	16.8	13.6	9.3	(27)
(28)			MCD B	11.3	13.1	18.2	24.8	27.0	30.5	32.0	31.5	26.4	20.8	16.7	11.2	(28)
(29)		2%	WB	7.1	8.2	11.1	15.4	19.0	22.0	22.3	21.9	19.0	15.7	12.1	7.6	(29)
(30)			MCD B	9.0	10.9	15.6	21.8	25.3	28.7	29.9	29.6	24.4	19.0	14.5	9.3	(30)
(31)		5%	WB	5.4	6.8	9.8	14.0	17.9	20.7	21.3	21.0	18.1	14.6	10.6	6.0	(31)
(32)			MCD B	7.0	9.1	13.5	19.5	23.2	26.6	28.3	28.2	22.7	17.5	12.5	7.4	(32)
(33)		10%	WB	3.9	5.5	8.6	12.8	16.7	19.6	20.5	20.1	17.1	13.4	9.2	4.8	(33)
(34)			MCD B	5.3	7.3	11.7	17.6	21.4	25.0	26.7	26.4	21.1	15.8	10.7	5.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.1	6.6	8.5	10.4	10.4	10.8	11.1	11.1	9.5	8.2	5.7	4.7	(35)
(36)			MCD BR	7.2	9.7	12.7	13.9	13.8	13.8	14.4	14.6	13.0	11.0	8.4	7.1	(36)
(37)			MCWBR	5.5	6.7	7.4	7.0	6.6	5.9	5.4	5.6	5.9	6.4	5.7	5.3	(37)
(38)		5% WB	MCD BR	7.0	9.2	11.7	13.1	12.8	12.7	13.1	13.3	11.5	10.0	7.9	6.7	(38)
(39)			MCWBR	5.6	6.6	7.2	6.8	6.3	5.8	5.3	5.5	5.5	6.1	5.5	5.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.315	0.338	0.376	0.420	0.418	0.421	0.430	0.428	0.401	0.372	0.348	0.314	(40)	
(41)		taud	2.367	2.340	2.275	2.181	2.225	2.253	2.231	2.252	2.298	2.351	2.368	2.393	(41)	
(42)		Ebn at Noon	740	807	830	827	844	843	828	811	794	754	689	692	(42)	
(43)		Edh at Noon	69	89	111	135	135	132	133	125	108	87	69	60	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.92	1.73	2.88	4.43	5.22	5.69	5.44	4.87	3.47	2.05	1.03	0.72	(44)	
(45)		RadStd	0.12	0.23	0.41	0.46	0.58	0.45	0.55	0.46	0.44	0.26	0.10	0.08	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (81 neighbors)		+0.56	N/A	N/A	+0.80	+0.43	+0.36	-128	-167	+80	+37

Nomenclature: See separate page