

WIEN INNERE STADT, Austria

WMO: 110340

Lat: 48.198N

Lon: 16.367E

Elev: 177

StdP: 99.21

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.7	-5.7	-12.7	1.3	-6.3	-10.2	1.6	-4.2	10.9	5.9	9.8	6.4	3.1	320	0.469

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.4	32.4	21.7	30.6	21.0	28.9	20.2	22.9	30.3	21.9	28.7	21.0	27.2	3.4	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.4	15.4	26.7	19.5	14.6	25.8	18.7	13.8	24.9	68.4	30.6	64.8	28.7	61.6	27.3	26.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.7	7.6	6.8	-9.1	35.3	3.0	2.1	-11.3	36.7	-13.1	38.0	-14.8	39.1	-16.9	40.6		
(5)			-10.1	24.1	2.8	1.1	-12.1	24.8	-13.7	25.5	-15.2	26.1	-17.2	26.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.4	1.6	3.5	7.4	12.8	17.0	20.7	22.8	22.4	17.3	12.2	7.3	2.8		
	DBStd	8.43	4.43	4.74	4.41	4.27	3.75	3.75	3.49	3.37	3.51	3.82	3.94	4.06		
	HDD10.0	921	263	186	104	22	1	0	0	0	1	22	99	224		
	HDD18.3	2614	520	416	340	171	71	19	5	5	61	193	332	482		
	CDD10.0	1778	2	3	23	106	217	322	396	385	218	89	17	1		
	CDD18.3	429	0	0	0	4	29	91	143	132	29	2	0	0		
	CDH23.3	3110	0	0	0	27	172	651	1142	986	128	4	0	0		
	CDH26.7	987	0	0	0	3	28	190	408	337	21	0	0	0		
(14) Wind	WSAvg	3.3	3.6	3.5	3.5	3.4	3.5	3.2	3.4	2.9	3.0	2.9	3.2	3.2		
(15) Precipitation	PrecAvg	649	35	32	48	43	71	78	78	70	66	45	44	38		
	PrecMax	865	87	74	119	99	168	179	226	169	201	97	86	69		
	PrecMin	433	3	0	14	1	18	23	8	15	20	4	0	11		
	PrecStd	112	20	22	28	27	36	38	43	40	41	24	19	17		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.5	15.9	20.2	26.2	29.3	33.2	34.8	35.0	29.1	23.5	18.6	13.9		
		MCWB	9.9	8.8	12.1	16.3	19.9	22.1	22.7	21.4	19.8	16.5	13.4	9.9		
	2%	DB	11.9	13.7	17.9	23.5	27.1	30.9	32.5	32.3	26.7	21.0	16.5	11.8		
		MCWB	8.4	9.0	11.1	15.2	18.6	21.5	21.9	21.4	19.0	15.7	12.4	8.4		
	5%	DB	9.6	11.6	15.7	21.3	25.3	28.9	30.7	30.2	24.6	19.2	14.4	9.7		
		MCWB	6.8	7.9	10.1	14.0	17.7	20.2	21.0	20.8	18.2	14.8	11.2	6.9		
	10%	DB	7.7	9.8	13.6	19.3	23.4	27.1	28.9	28.3	22.8	17.6	12.4	8.0		
		MCWB	5.3	6.7	9.1	12.9	16.6	19.4	20.3	20.0	17.3	14.0	9.9	5.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.5	10.5	13.0	17.2	20.9	23.9	24.3	23.6	20.9	17.9	14.3	10.4		
		MCDB	13.7	14.2	18.5	24.6	27.5	30.5	31.9	32.0	25.7	21.7	17.6	13.1		
	2%	WB	8.6	9.2	11.6	15.7	19.4	22.4	23.1	22.4	19.8	16.5	12.8	8.6		
		MCDB	11.6	12.7	16.5	22.6	25.8	29.2	30.6	29.8	25.0	19.8	15.8	11.5		
	5%	WB	7.0	8.1	10.6	14.5	18.3	21.2	22.0	21.4	18.9	15.4	11.4	7.1		
		MCDB	9.5	11.4	14.8	20.2	24.1	27.1	28.9	28.3	23.6	18.4	14.1	9.4		
	10%	WB	5.5	6.9	9.6	13.6	17.3	20.1	21.1	20.6	17.9	14.4	10.1	5.9		
		MCDB	7.5	9.7	13.3	18.6	22.4	25.9	27.3	26.9	22.0	17.2	12.2	7.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	3.6	4.7	6.2	7.6	7.8	8.0	8.4	8.1	6.7	5.7	3.9	3.6		
		MCDBR	5.7	7.2	9.7	10.6	10.7	10.7	11.2	11.1	9.7	8.1	6.3	6.3		
	5% WB	MCWBR	4.1	4.4	5.1	4.9	4.5	4.1	3.7	3.8	3.9	4.1	3.7	4.3		
		MCWBR	5.7	6.7	8.9	9.8	10.1	9.8	10.5	10.2	9.1	7.4	5.9	6.0		
(40) Clear-Sky Solar Irradiance	taub		0.321	0.345	0.385	0.431	0.429	0.434	0.441	0.440	0.412	0.380	0.352	0.319		
		taud	2.371	2.328	2.247	2.151	2.202	2.229	2.212	2.229	2.275	2.334	2.368	2.396		
	Ebn at Noon		740	801	821	817	835	832	819	801	785	748	691	693		
		Edh at Noon	70	91	115	140	138	135	136	128	111	90	71	61		
(44) All-Sky Solar Radiation	RadAvg		0.98	1.81	2.97	4.46	5.25	5.72	5.52	4.93	3.52	2.15	1.11	0.77		
	RadStd		0.12	0.24	0.39	0.45	0.56	0.43	0.51	0.48	0.43	0.25	0.11	0.09		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (86 neighbors)	+0.55	N/A	N/A	N/A	+0.43	+0.37	-121	-159	+82	+40

Nomenclature: See separate page