

WIEN HOHE WARTE, Austria

WMO: 110350

Lat: 48.2486N

Lon: 16.3564E

Elev: 656

StdP: 14.35

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.9	19.8	8.5	8.7	18.3	13.0	10.9	22.2	28.7	41.6	26.1	40.5	5.6	320	0.502

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.1	89.2	71.2	85.8	69.8	82.7	68.2	72.6	86.2	70.8	83.4	69.1	80.6	7.8	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.8	104.6	79.9	66.2	98.9	78.0	64.7	93.8	76.3	36.6	86.4	35.0	83.6	33.6	80.7	83.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.0	18.8	16.5	12.3	93.9	5.4	3.8	8.4	96.7	5.3	98.9	2.3	101.0	-1.6	103.8
			10.9	75.7	5.3	2.2	7.0	77.3	3.9	78.6	0.9	79.8	-3.0	81.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	52.3	33.3	36.4	43.7	53.2	60.6	67.3	70.7	70.0	61.2	51.7	43.1	35.2	(6)
(7)		DBStd	14.92	8.07	8.19	7.64	7.26	6.33	6.43	5.92	6.00	6.02	6.68	7.07	7.26	(7)
(8)		HDD50	1924	520	384	221	51	2	0	0	0	1	61	224	460	(8)
(9)		HDD65	5189	983	800	661	357	164	49	18	21	143	413	656	924	(9)
(10)		CDD50	2761	2	3	25	147	332	519	641	620	338	114	19	1	(10)
(11)		CDD65	552	0	0	0	3	29	119	194	176	30	1	0	0	(11)
(12)		CDH74	4300	0	0	0	35	229	934	1580	1352	167	3	0	0	(12)
(13)		CDH80	1312	0	0	0	3	30	261	534	458	26	0	0	0	(13)
(14)	Wind	WSAvg	7.6	8.5	8.3	8.4	7.9	8.0	7.3	7.7	6.7	6.9	6.7	7.4	7.6	(14)
(15)	Precipitation	PrecAvg	25.4	1.6	1.5	1.9	1.9	2.7	2.8	2.8	2.6	2.1	1.7	1.9	1.8	(15)
(16)		PrecMax	35.8	4.1	4.4	5.7	5.2	7.6	7.6	9.6	8.3	7.7	5.2	4.2	4.4	(16)
(17)		PrecMin	17.6	0.1	0.0	0.3	0.0	0.4	0.9	0.2	0.6	0.5	0.0	0.0	0.1	(17)
(18)		PrecStd	4.3	0.9	1.0	1.1	1.3	1.6	1.6	1.6	1.7	1.4	1.1	1.0	0.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.8	59.5	68.1	78.4	83.5	90.6	93.5	94.4	83.5	72.8	64.7	55.4	(19)
(20)		0.4%	MCWB	49.0	48.0	54.1	61.2	67.0	72.2	72.3	70.6	67.4	60.8	55.3	48.7	(20)
(21)		2%	DB	52.5	55.2	63.3	73.4	79.4	86.3	89.1	89.0	78.8	67.9	60.5	51.3	(21)
(22)		2%	MCWB	46.0	47.4	51.7	59.5	65.2	70.6	71.4	70.8	65.3	59.0	53.3	46.1	(22)
(23)		5%	DB	48.2	51.3	59.0	69.4	76.4	82.8	85.7	85.1	74.8	64.8	56.3	47.6	(23)
(24)		5%	MCWB	43.4	45.0	49.6	57.0	63.4	68.5	69.8	69.3	63.6	57.5	51.2	43.2	(24)
(25)		10%	DB	44.5	47.7	55.1	65.7	72.9	79.5	82.6	81.4	71.5	61.6	52.7	44.4	(25)
(26)		10%	MCWB	40.4	42.6	47.5	54.9	61.2	66.7	68.4	67.6	61.8	55.9	48.5	40.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.8	50.0	55.4	62.4	68.7	74.1	74.7	74.3	68.5	62.6	56.4	49.5	(27)
(28)		0.4%	MCDWB	55.6	57.4	66.4	75.8	81.3	87.2	88.9	88.5	80.2	69.5	62.3	54.3	(28)
(29)		2%	WB	46.3	47.4	52.6	59.8	66.3	71.9	72.7	71.8	66.5	60.3	54.0	46.6	(29)
(30)		2%	MCDWB	51.1	53.9	61.3	72.0	77.9	84.1	86.8	85.8	76.8	66.1	59.4	51.1	(30)
(31)		5%	WB	43.6	45.3	50.4	57.6	64.2	69.6	70.9	70.1	64.6	58.4	51.3	43.5	(31)
(32)		5%	MCDWB	48.0	51.0	57.6	67.7	74.5	80.8	83.4	82.6	73.0	63.3	55.8	47.0	(32)
(33)		10%	WB	40.7	42.9	48.3	55.7	62.1	67.6	69.1	68.3	62.7	56.5	48.9	41.3	(33)
(34)		10%	MCDWB	44.2	47.4	54.5	64.3	71.3	78.0	80.2	79.8	69.8	60.9	52.3	44.1	(34)
(35)	Mean Daily Temperature Range		MDBR	7.7	10.0	13.3	16.4	16.3	16.7	17.1	17.2	14.3	11.9	8.2	7.2	(35)
(36)		5% DB	MCDBR	12.0	15.4	20.6	22.8	22.2	22.1	22.9	23.4	20.0	16.4	13.2	12.3	(36)
(37)			MCWBR	8.2	9.7	11.8	11.5	10.7	9.7	9.2	9.1	8.9	8.8	8.2	8.5	(37)
(38)			5% WB	MCDBR	11.9	14.8	18.9	21.4	21.1	20.9	21.4	21.8	18.5	14.8	12.2	11.7
(39)		MCWBR		8.7	9.7	11.3	11.2	10.8	9.8	9.4	9.2	8.6	8.7	8.0	8.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.320	0.344	0.385	0.430	0.428	0.432	0.440	0.438	0.410	0.379	0.351	0.319	(40)	
(41)		taud	2.370	2.327	2.247	2.151	2.202	2.229	2.211	2.229	2.275	2.334	2.367	2.394	(41)	
(42)		Ebn at Noon	235	254	261	259	265	264	260	254	249	238	219	220	(42)	
(43)		Edh at Noon	22	29	36	44	44	43	43	41	35	29	23	19	(43)	
(44)	All-Sky Solar Radiation	RadAvg	310	571	939	1413	1662	1813	1748	1560	1115	677	349	244	(44)	
(45)		RadStd	38	76	123	144	180	138	164	151	137	79	34	28	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+1.30	N/A	N/A	N/A	N/A	N/A	-421	N/A	N/A	N/A	(46)
(47)	Regional (85 neighbors)	+0.99	N/A	N/A	N/A	+0.76	+0.67	-223	-288	+142	+70	(47)

Nomenclature: See separate page