

WIEN HOHE WARTE, Austria

WMO: 110350

Lat: 48.2486N

Lon: 16.3564E

Elev: 200

StdP: 98.95

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-8.9	-6.8	-13.1	1.2	-7.6	-10.5	1.6	-5.4	12.8	5.3	11.7	4.7	2.5	320	0.502

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.5	31.8	21.8	29.9	21.0	28.2	20.1	22.5	30.1	21.6	28.5	20.6	27.0	3.5	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.9	14.9	26.6	19.0	14.1	25.5	18.2	13.4	24.6	67.3	30.2	63.6	28.7	60.3	27.0	28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.8	8.4	7.4	-10.9	34.4	3.0	2.1	-13.1	35.9	-14.8	37.2	-16.5	38.3	-18.7	39.9
			-11.7	24.3	3.0	1.2	-13.9	25.2	-15.6	25.9	-17.3	26.6	-19.4	27.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.3	0.7	2.5	6.5	11.8	15.9	19.6	21.5	21.1	16.2	10.9	6.2	1.8		
	DBStd	8.29	4.48	4.55	4.25	4.03	3.52	3.57	3.29	3.34	3.35	3.71	3.93	4.03		
	HDD10.0	1069	289	213	123	28	1	0	0	0	1	34	124	256		
	HDD18.3	2883	546	444	367	198	91	27	10	12	79	229	364	513		
	CDD10.0	1534	1	2	14	82	184	288	356	344	188	63	11	1		
	CDD18.3	307	0	0	0	2	16	66	108	98	17	1	0	0		
	CDH23.3	2389	0	0	0	19	127	519	878	751	93	2	0	0		
	CDH26.7	729	0	0	0	2	17	145	297	254	14	0	0	0		
(14) Wind	WSAvg	3.4	3.8	3.7	3.7	3.5	3.6	3.3	3.4	3.0	3.1	3.0	3.3	3.4		
(15) Precipitation	PrecAvg	646	40	39	47	47	69	72	71	65	54	43	48	45		
	PrecMax	910	105	113	145	131	192	193	245	212	195	132	107	111		
	PrecMin	446	3	1	8	1	10	22	6	15	13	0	0	3		
	PrecStd	108	24	25	27	32	40	40	41	43	36	28	25	22		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.8	15.3	20.1	25.8	28.6	32.6	34.2	34.7	28.6	22.7	18.2	13.0		
		MCWB	9.4	8.9	12.3	16.2	19.4	22.3	22.4	21.5	19.6	16.0	13.0	9.3		
	2%	DB	11.4	12.9	17.4	23.0	26.3	30.2	31.7	31.7	26.0	19.9	15.8	10.7		
		MCWB	7.8	8.6	11.0	15.3	18.5	21.4	21.9	21.5	18.5	15.0	11.8	7.8		
	5%	DB	9.0	10.7	15.0	20.8	24.6	28.2	29.8	29.5	23.8	18.2	13.5	8.6		
		MCWB	6.3	7.2	9.8	13.9	17.4	20.3	21.0	20.7	17.6	14.2	10.7	6.2		
	10%	DB	6.9	8.7	12.8	18.7	22.7	26.4	28.1	27.4	22.0	16.5	11.5	6.9		
		MCWB	4.7	5.9	8.6	12.7	16.2	19.3	20.2	19.8	16.5	13.3	9.2	4.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.9	10.0	13.0	16.9	20.4	23.4	23.7	23.5	20.3	17.0	13.6	9.7		
		MCDB	13.1	14.1	19.1	24.3	27.4	30.6	31.6	31.4	26.8	20.9	16.8	12.4		
	2%	WB	7.9	8.6	11.4	15.4	19.0	22.2	22.6	22.1	19.1	15.7	12.2	8.1		
		MCDB	10.6	12.2	16.3	22.2	25.5	28.9	30.4	29.9	24.9	18.9	15.2	10.6		
	5%	WB	6.4	7.4	10.2	14.2	17.9	20.9	21.6	21.2	18.1	14.6	10.7	6.4		
		MCDB	8.9	10.5	14.2	19.8	23.6	27.1	28.6	28.1	22.8	17.4	13.2	8.3		
	10%	WB	4.9	6.0	9.1	13.2	16.7	19.8	20.6	20.2	17.1	13.6	9.4	5.1		
		MCDB	6.8	8.6	12.5	17.9	21.8	25.5	26.8	26.6	21.0	16.0	11.3	6.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.3	5.6	7.4	9.1	9.1	9.3	9.5	9.5	7.9	6.6	4.6	4.0		
		MCDBR	6.7	8.5	11.4	12.7	12.3	12.3	12.7	13.0	11.1	9.1	7.4	6.8		
	5% WB	MCWBR	4.6	5.4	6.5	6.4	5.9	5.4	5.1	5.1	5.0	4.9	4.5	4.7		
		MCWBR	6.6	8.2	10.5	11.9	11.7	11.6	11.9	12.1	10.3	8.2	6.8	6.5		
(40) Clear-Sky Solar Irradiance	taub		0.320	0.344	0.385	0.430	0.428	0.432	0.440	0.438	0.410	0.379	0.351	0.319		
		taud	2.370	2.327	2.247	2.151	2.202	2.229	2.211	2.229	2.275	2.334	2.367	2.394		
	Ebn at Noon		740	802	822	818	836	833	820	802	786	749	691	693		
		Edh at Noon	70	91	115	140	138	135	136	128	111	90	71	61		
(44) All-Sky Solar Radiation	RadAvg		0.98	1.80	2.96	4.46	5.24	5.72	5.51	4.92	3.52	2.13	1.10	0.77		
	RadStd		0.12	0.24	0.39	0.46	0.57	0.44	0.52	0.47	0.43	0.25	0.11	0.09		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.72	N/A	N/A	N/A	N/A	N/A	-234	N/A	N/A	N/A
(47) Regional (85 neighbors)		+0.55	N/A	N/A	N/A	+0.42	+0.37	-124	-160	+79	+39

Nomenclature: See separate page