

WIEN SCHWECHAT, Austria

WMO: 110360

Lat: 48.1175N

Lon: 16.5814E

Elev: 183

StdP: 99.15

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.0	-7.8	-13.8	1.2	-9.3	-11.1	1.5	-6.3	14.6	6.2	13.3	5.1	3.8	340	0.577

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.4	31.8	21.0	29.9	20.4	28.1	19.5	21.9	29.3	21.1	28.1	20.3	26.7	4.6	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.4	14.4	24.8	18.6	13.8	24.2	17.9	13.1	23.6	64.7	29.4	61.7	28.3	59.0	26.9	25.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.1	10.7	9.6	DB	-13.3	34.5	3.0	2.1	-15.5	35.9	-17.3	37.1	-19.0	38.3	-21.2	39.8	(4)
(5)			WB	-13.8	23.6	3.0	0.9	-15.9	24.3	-17.6	24.8	-19.3	25.3	-21.4	26.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.9	0.2	2.1	6.0	11.2	15.6	19.3	21.2	20.8	16.0	10.8	5.8	1.1		
	DBStd	8.38	4.69	4.80	4.23	3.96	3.45	3.47	3.11	3.14	3.30	3.89	4.09	4.21		
	HDD10.0	1148	304	223	134	33	2	0	0	0	1	38	135	277		
	HDD18.3	2995	562	455	382	215	99	30	9	12	85	236	376	534		
	CDD10.0	1468	1	2	11	69	174	278	348	333	180	62	9	1		
	CDD18.3	273	0	0	0	1	13	58	99	87	14	1	0	0		
	CDH23.3	2342	0	0	0	15	114	493	874	742	101	3	0	0		
	CDH26.7	724	0	0	0	1	13	138	303	252	16	0	0	0		
(14) Wind	WSAvg	4.4	4.8	5.0	5.0	4.6	4.4	4.1	4.2	3.7	4.1	4.1	4.6	4.6		
(15) Precipitation	PrecAvg	575	28	26	38	38	62	71	73	64	58	42	41	33		
	PrecMax	775	62	56	81	89	141	160	191	150	162	93	79	63		
	PrecMin	393	3	1	8	0	16	22	7	8	16	3	2	10		
	PrecStd	95	16	17	23	24	31	33	41	37	40	24	16	14		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.0	15.9	20.0	25.2	28.2	32.4	34.2	34.2	28.8	23.1	18.3	13.0		
		MCWB	9.2	9.1	11.8	15.8	18.7	21.4	21.6	20.8	19.0	16.3	13.2	9.5		
	2%	DB	11.1	13.2	17.3	22.7	26.2	30.1	31.9	31.8	26.1	20.5	15.7	10.8		
		MCWB	7.5	8.5	10.5	14.5	17.9	20.9	21.0	20.8	18.2	15.4	12.0	7.4		
	5%	DB	8.9	11.1	15.0	20.4	24.2	28.1	30.0	29.4	24.0	18.5	13.4	8.3		
		MCWB	6.1	7.2	9.4	13.2	16.9	19.7	20.4	20.0	17.3	14.3	10.7	5.9		
	10%	DB	6.8	9.0	12.9	18.3	22.4	26.2	28.1	27.4	22.0	16.7	11.4	6.6		
		MCWB	4.5	6.1	8.3	12.1	15.8	18.9	19.6	19.3	16.3	13.5	9.1	4.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.8	10.1	12.5	16.4	20.0	23.1	23.1	22.7	20.0	17.2	13.9	9.7		
		MCDB	13.3	14.5	18.5	23.8	26.6	29.7	31.6	30.4	26.3	21.3	17.0	12.6		
	2%	WB	7.7	8.7	11.1	14.9	18.6	21.6	21.9	21.6	19.0	16.0	12.4	7.8		
		MCDB	10.6	12.6	16.0	21.2	24.6	28.4	29.4	29.0	24.5	19.6	15.2	10.2		
	5%	WB	6.1	7.5	9.9	13.8	17.5	20.6	21.1	20.7	18.0	14.9	10.8	6.0		
		MCDB	8.2	10.7	14.3	19.5	23.1	26.8	28.2	27.7	22.5	17.7	13.3	7.8		
	10%	WB	4.6	6.1	8.8	12.7	16.4	19.5	20.2	19.9	17.0	13.7	9.4	4.9		
		MCDB	6.4	8.7	12.4	17.6	21.5	25.2	26.7	26.1	21.4	16.2	11.2	6.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.2	6.6	8.5	9.9	9.8	10.1	10.4	10.4	8.9	7.8	5.5	4.8		
		MCDBR	7.9	9.8	12.8	13.3	13.0	13.0	13.9	13.7	12.3	10.4	8.3	7.9		
		MCWBR	5.5	6.2	7.3	6.8	6.1	5.5	5.2	5.1	5.6	5.8	5.4	5.7		
		MCWBR	7.5	9.2	11.7	12.2	12.0	12.2	12.4	12.3	10.9	9.5	7.8	7.4		
(40) Clear-Sky Solar Irradiance	taub	taub	0.319	0.343	0.381	0.425	0.423	0.427	0.435	0.434	0.407	0.377	0.350	0.318		
		taud	2.378	2.343	2.264	2.170	2.221	2.247	2.228	2.245	2.289	2.346	2.376	2.403		
		Ebn at Noon	744	806	827	823	841	838	825	807	791	753	695	697		
		Edh at Noon	70	90	113	137	136	133	134	126	110	89	70	61		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.98	1.80	2.98	4.50	5.31	5.79	5.59	4.98	3.56	2.16	1.12	0.77		
		RadStd	0.11	0.24	0.39	0.45	0.56	0.43	0.51	0.48	0.43	0.25	0.11	0.09		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.48	N/A	N/A	N/A	+0.45	+0.40	N/A	-126	+95	+51
(47) Regional (85 neighbors)		+0.57	N/A	N/A	+0.84	+0.46	+0.39	-125	-167	+88	+44

Nomenclature: See separate page