

WIEN UNTERLAA, Austria

WMO: 110400

Lat: 48.125N

Lon: 16.419E

Elev: 656

StdP: 14.35

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.9	19.0	6.9	8.0	16.8	11.8	10.3	21.5	31.3	44.8	28.3	42.1	7.0	330	0.524

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.2	89.8	70.7	86.3	69.5	83.3	68.0	72.2	85.9	70.6	83.4	69.1	80.9	8.4	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.6	103.9	78.1	66.1	98.6	77.0	64.7	93.9	75.6	36.3	86.1	34.9	83.8	33.6	81.1	78.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.1	20.9	18.4	11.4	94.6	5.4	3.6	7.5	97.2	4.4	99.3	1.3	101.3	-2.6	103.9
			10.1	74.6	5.2	1.7	6.3	75.8	3.3	76.8	0.4	77.8	-3.4	79.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.4	33.0	36.0	43.5	53.5	60.2	67.7	71.3	70.4	61.4	51.9	43.2	34.9	(6)
	DBStd	15.17	8.25	8.46	8.10	6.92	6.52	6.28	5.86	5.85	6.13	6.84	6.85	7.20	(7)
	HDD50	1950	529	396	226	43	4	0	0	0	2	61	222	467	(8)
	HDD65	5197	992	812	665	347	175	44	14	16	140	407	653	932	(9)
	CDD50	2810	1	4	26	149	320	532	660	633	345	120	19	1	(10)
	CDD65	582	0	0	0	3	26	126	209	184	33	1	0	0	(11)
	CDH74	4688	0	0	0	38	192	968	1758	1503	221	8	0	0	(12)
	CDH80	1483	0	0	0	4	27	262	615	534	41	0	0	0	(13)
(14) Wind	WSAvg	8.4	9.5	9.3	9.3	8.8	8.7	7.8	8.0	7.3	7.5	7.6	8.6	8.7	(14)
(15) Precipitation	PrecAvg	25.6	1.4	1.3	1.9	1.7	2.8	3.1	3.1	2.8	2.6	1.8	1.7	1.5	(15)
	PrecMax	34.1	3.4	2.9	4.7	3.9	6.6	7.0	8.9	6.7	7.9	3.8	3.4	2.7	(16)
	PrecMin	17.0	0.1	0.0	0.6	0.0	0.7	0.9	0.3	0.6	0.8	0.2	0.0	0.4	(17)
	PrecStd	4.4	0.8	0.9	1.1	1.1	1.4	1.5	1.7	1.6	1.6	0.9	0.7	0.7	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.7	60.5	68.5	78.8	83.4	90.2	93.8	94.6	84.7	74.6	64.7	56.1	(19)
		MCWB	48.4	48.4	54.2	61.7	67.6	71.3	71.9	70.9	67.1	61.4	55.6	49.3	(20)
	2%	DB	52.1	56.3	64.1	73.3	79.1	86.3	89.9	89.9	79.9	69.1	60.1	51.4	(21)
		MCWB	45.8	47.7	51.9	59.0	65.3	70.2	71.0	70.2	65.3	59.4	53.4	45.7	(22)
	5%	DB	48.2	51.8	59.7	69.3	75.5	82.9	86.3	85.8	75.8	65.5	56.4	47.5	(23)
		MCWB	43.3	45.1	49.7	56.6	63.3	68.3	69.4	69.1	63.5	57.5	51.3	43.0	(24)
	10%	DB	44.4	47.8	55.9	65.8	72.1	79.7	83.2	82.1	72.2	62.3	52.9	44.5	(25)
		MCWB	40.3	42.6	47.5	54.7	60.8	66.3	68.1	67.4	61.6	56.0	48.8	40.7	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.5	50.4	55.2	62.9	68.9	74.4	74.6	73.8	68.4	62.7	56.7	49.5	(27)
		MCDB	55.4	58.5	66.4	76.4	80.9	85.9	88.4	90.0	82.3	70.7	62.3	55.0	(28)
	2%	WB	46.1	47.6	52.5	59.7	66.3	71.7	72.2	71.6	66.2	60.4	54.5	46.5	(29)
		MCDB	51.3	54.8	62.1	71.9	77.5	83.3	86.2	85.9	77.3	67.5	59.4	51.0	(30)
	5%	WB	43.4	45.4	50.5	57.4	64.1	69.5	70.6	70.0	64.5	58.5	51.7	43.2	(31)
		MCDB	47.6	51.4	58.7	67.8	73.5	80.1	83.8	83.0	74.1	63.9	56.0	46.8	(32)
	10%	WB	40.5	42.8	48.2	55.5	62.1	67.6	69.1	68.4	62.7	56.6	49.1	41.2	(33)
		MCDB	44.1	47.5	55.2	64.5	70.4	77.7	81.0	79.8	70.6	61.4	52.5	44.1	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	8.3	10.3	14.1	16.8	15.8	16.7	17.2	17.2	14.9	12.9	8.8	8.2	(35)
		MCDBR	13.3	16.2	22.0	23.1	21.9	22.0	22.7	23.9	21.7	18.5	13.4	13.4	(36)
	5% WB	MCWBR	9.4	10.2	12.5	11.7	10.4	9.0	8.2	8.6	9.2	9.8	8.3	9.5	(37)
		MCDWR	12.9	15.3	20.8	21.8	20.6	20.8	21.1	22.1	20.2	17.1	12.3	12.7	(38)
(40) Clear-Sky Solar Irradiance	taub		0.319	0.343	0.382	0.427	0.425	0.430	0.437	0.436	0.408	0.377	0.349	0.318	(40)
		taud	2.379	2.338	2.259	2.164	2.215	2.240	2.223	2.240	2.286	2.344	2.377	2.405	(41)
	Ebn at Noon		236	256	262	261	266	265	261	255	251	239	221	221	(42)
		Edh at Noon	22	29	36	44	43	43	43	40	35	28	22	19	(43)
(44) All-Sky Solar Radiation	RadAvg		314	574	946	1420	1674	1825	1762	1572	1124	686	355	246	(44)
	RadStd		37	77	123	142	178	136	161	152	137	78	35	28	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (85 neighbors)	+1.01	N/A	N/A	+1.49	+0.81	+0.68	-216	-288	+153	+77

Nomenclature: See separate page